

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9210190239 DOC. DATE: 92/10/14 NOTARIZED: YES DOCKET #
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362
 AUTH. NAME AUTHOR AFFILIATION
 RAY, H.B. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards application for amends to licenses NPF-10 & NPF-15,
 consisting of proposed TS change NPF-10/15-407, revising
 TS 3/4.7.5, "Control Room Emergency Air Cleanup Sys,"
 including deleting surveillance requirements for heaters.

DISTRIBUTION CODE: A003D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+35
 TITLE: OR/Licensing Submittal: Suppl 1 to NUREG-0737 (Generic Ltr 82-33)

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD5 LA	1 1	PD5 PD	1 1
FIELDS, M.	2 2		
INTERNAL: NRR/DLPO/LHFB11	1 1	OC/LFMB	1 0
REG FILE 01	1 1	RES/DSIR/EIB	1 1
EXTERNAL: NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK.
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 9

AA2



Southern California Edison Company

23 PARKER STREET

IRVINE, CALIFORNIA 92718

HAROLD B. RAY
SENIOR VICE PRESIDENT

TELEPHONE
714-458-4400

October 14, 1992

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: **Docket Nos. 50-361 and 50-362
Proposed Technical Specification Change No. NPF-10/15-407
Control Room Emergency Air Cleanup System
San Onofre Nuclear Generating Station
Units 2 and 3**

This letter requests revision of Technical Specification 3/4.7.5, "Control Room Emergency Air Cleanup System," to delete requirements for duct heaters and diverting valves, and to incorporate some modifications in the Action statement, SURVEILLANCE REQUIREMENTS, and Bases.

Provided as an enclosure to this letter are Amendment Application Numbers 116 and 100 to Facility Operating License Numbers NPF-10 and NPF-15 for San Onofre Units 2 and 3, respectively. The Amendment Applications are comprised of proposed Technical Specification Change NPF-10/15-407 (PCN-407). PCN-407 is the request to revise the Control Room Emergency Air Cleanup System Technical Specification 3/4.7.5.

The proposed change would delete the surveillance requirements associated with heaters in the emergency ventilation supply units because (1) the heaters are not required to maintain the operability of filters in the emergency ventilation supply unit since these filters are not credited in the dose analyses, and (2) the heaters are not necessary to maintain the relative humidity below the required 70% at the filters in the emergency recirculation unit which are credited in the dose analysis. In addition this proposed change includes revisions to the ACTION statement and SURVEILLANCE REQUIREMENTS to be consistent with the design of San Onofre Units 2 and 3.

160081

9210190239 921014
PDR ADOCK 05000361
P PDR

ADD3

Document Control Desk



Should you have any questions regarding this request, please do not hesitate to call me.

Sincerely,

A handwritten signature in cursive script, reading "Harold B. Ray". The signature is written in dark ink and is positioned below the word "Sincerely,".

Enclosure

cc: J. B. Martin, Regional Administrator, NRC Region V
C. W. Caldwell, NRC Senior Resident Inspector, San Onofre Units 1, 2 & 3
M. B. Fields, NRC NRR Project Manger, San Onofre Units 2 and 3.
H. Kocol, California Department of Health Services

Subscribed on this 14th day of OCTOBER, 1992.

Respectfully submitted,

SOUTHERN CALIFORNIA EDISON COMPANY

By:

Harold B. Ray
Harold B. Ray
Senior Vice President


State of California

County of Orange

On 10/14/92 before me, BARBARA A. MCCARTHY, ^{NOTARY PUBLIC} personally appeared HAROLD B. RAY, personally known to me ~~(or proved to me on the basis of satisfactory evidence)~~ to be the person(s) whose name(s) is/~~are~~ subscribed to the within instrument and acknowledged to me that he/~~she/they~~ executed the same in his/~~her/their~~ authorized capacity(ies), and that by his/~~her/their~~ signature(s) on the instrument the person(s), or the entity upon behalf of which the person(s) acted, executed the instrument.

WITNESS my hand and official seal.

Signature Barbara A. McCarthy



James A. Beoletto
Attorney for Southern
California Edison Company

By:

James A. Beoletto
James A. Beoletto