

*Southern California Edison Company*



P. O. BOX 800  
2244 WALNUT GROVE AVENUE  
ROSEMEAD, CALIFORNIA 91770

M. O. MEDFORD  
MANAGER, NUCLEAR LICENSING

January 14, 1985

TELEPHONE  
(818) 302-1749

IE HQ FILE COPY

Director, Office of Nuclear Reactor Regulation  
Attention: Mr. George W. Knighton, Branch Chief  
Licensing Branch No. 3  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362  
Auxiliary Feedwater System Monthly Outage Report  
San Onofre Nuclear Generating Station, Units 2 and 3

Pursuant to License Condition 2.C(26) of Facility Operating License NPF-15 for San Onofre Unit 3, this submittal provides the required monthly report describing any occurrence resulting in the degradation of the Units 2 and 3 Auxiliary Feedwater Systems (AFWS). This report covers the period from November 16, 1984, to December 15, 1984. The component involved, cause of outage, outage duration, and corrective actions taken to return the equipment to operable status are listed.

During the reporting period Unit 3 operated in Modes 1, 2 and 3 from November 30, 1984 to December 15, 1984, and AFWS availability was 100%. Component unavailability for that period was eleven percent. For the remainder of the reporting period Unit 3 was in Modes 4 and 5. Unit 2 was defueled for the entire reporting period. For these periods the duration of equipment outages is not specified and the AFWS is not required to be operable per the Technical Specifications.

In accordance with License Condition 2.C(26), our next report will cover the period from December 16, 1984, to January 15, 1985.

If there are any questions regarding this report, please contact me.

Sincerely,

*FR Huey for M O Medford*

8501210135 850114  
PDR ADDCK 05000361  
R PDR

Enclosure

cc: J. B. Martin, (Regional Administrator  
U.S. Nuclear Regulatory Commission, Region V)

H. Rood, Project Manager, SONGS 2/3, NRR

F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)  
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

IE25  
11

San Onofre Nuclear Generating Station, Units 2 and 3  
 Monthly AFWS Outage Report  
 November 16, 1984 to December 15, 1984

-1-

Date	Unit	Outage	Duration (hours)	Outage Cause	Corrective Action
11/15/84	2	Preventative Maintenance and Design Change Packages (DCP 127.OM, DCP 1257.OE, DCP 1396.OP, DCP 195.OJ)	--	Auxiliary Feedwater Pumps (P-140; P-504) were removed from service to modify the steam inlet piping per DCP 1396.OP, modify the governor controls per DCP 1257.OE, modify the Pump Motor Bear- ings per DCP 195.OJ, install a gravity feed lube oil system per DCP 127.OM, and miscellaneous surveillances	None Required

San Onofre Nuclear Generating Station, Units 2 and 3  
Monthly AFWS Outage Report  
November 16, 1984 to December 15, 1984

-2-

Date	Unit	Outage	Duration (hours)	Outage Cause	Corrective Action
11/16/84	3	Corrective Maintenance	--	Auxiliary Feedwater Pump Turbine K007 was removed from service to repair a steam leak and replace a hinge pin in valve S31301MU005	Replaced hinge pin in valve
11/26/84	3	Corrective Maintenance	--	Auxiliary Feedwater Pump P140 Discharge Valve 3HV4705 was removed from service for failure to meet a stroke test criteria	Lubricated valve stem and adjusted packing on 3HV4705
11/30/84	3	Testing	42	Post Maintenance and Surveillance Operability Testing on S31301MU005 and pump 3P-140 in accordance with Tech Spec 4.7.1.2.1.a.1.	None