

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION
P.O. BOX 128
SAN CLEMENTE, CALIFORNIA 92672

H. E. MORGAN
STATION MANAGER

August 13, 1985

RECEIVED
NRC
1985 AUG 19 PM 1:26



REGION V IRE

TELEPHONE
(714) 492-7700

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
Follow-up Report, Inoperable Fire Doors - July 1985
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, H. E. Morgan (SCE) to J. B. Martin (NRC),
dated July 12, 1985

In accordance with our referenced letter, this submittal provides the follow-up report of fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in July 1985.

Fire doors found inoperable during the July routine surveillances are identified in the Attachment and include: 4 latching mechanism failures; 1 closure mechanism failure; and 5 doors blocked open typically for construction, operation or maintenance activities. As each of these deficiencies was identified, compensatory fire watches, pursuant to Technical Specification 3.7.9, Action Statement 'a', were established. We are continuing previously reported corrective actions to upgrade door latches and closure mechanisms.

As discussed in the referenced letter, the Station Manager issued a letter to Site and Station Management on July 23, 1985, which re-emphasized the Station policy regarding fire doors. The letter outlined the proper procedures for authorization to block open a fire door, required all personnel to be retrained regarding Station fire door policy and procedures, and established Station policy requiring disciplinary action for personnel failing to comply with Station fire door policy and procedures.

8508270102 850813
PDR ADOCK 05000361
S PDR

IE-01

Mr. J. B. Martin

-2-

In accordance with Station practice, investigations were conducted for the 5 fire doors found blocked open. The responsible party was identified for 2 of the 5 doors found blocked open and appropriate actions will be taken.

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in August 1985 will be submitted by September 15, 1985.

If you require any additional information, please so advise.

Sincerely,

H. E. Morgan/maw

Enclosure

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)

U. S. Nuclear Regulatory Commission
-Document Control Desk

Institute of Nuclear Power Operations (INPO)

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF JULY 1985
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 4, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
FH3-103	7/18/85	7/20/85
AC-310	7/18/85	7/19/85
AR-401	7/29/85	- - -
AC-122	7/30/85	7/31/85

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF JULY 1985
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362
(Continued)

II. Closure Mechanism Failures:

Number of doors inoperable - 1, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
FH3-304	7/23/85	7/28/85

5-1-85

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF JULY 1985
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362
(Continued)

II. Doors Blocked Open:

Number of doors inoperable - 4, as follows:

<u>Door Number</u>	<u>Date Found Inoperable (fire watches established within one hour)</u>
AR-312	*
S3-018	7/10/85
AR-313	7/18/85
S3-018	7/20/85
AC-349	7/30/85

*Reported last month as found inoperable on 6/26/85. Restored to operable on 7/3/85.