

**ENCLOSURE 2
ATTACHMENT 25**

SHINE MEDICAL TECHNOLOGIES, INC.

**SHINE MEDICAL TECHNOLOGIES, INC. APPLICATION FOR CONSTRUCTION PERMIT
RESPONSE TO ENVIRONMENTAL REQUESTS FOR ADDITIONAL INFORMATION**

**1-HR-SK-001, REVISION A
SHINE WATER BALANCE DIAGRAM – NON-PROPRIETARY**

SHINE Water Balance Diagram 1-HR-SK-001 – Non-Proprietary

Rev A

Influent: 6070 gal/day	Total Water Use	Effluent: 6070 gal/day
Influent: 222 gal/day	Process Water	Effluent: 222 gal/day
Influent: 3270 gal/day	Potable Water	Effluent: 3270 gal/day
Influent: 2580 gal/day	Boiler Blowdown/Makeup Water	Effluent: 2580 gal/day

