

ENCLOSURE 1

SONGS 1

HYDRAULIC CALCULATION FOR

AFW LINES

FLOW REQUIREMENTS

9009140006 900910  
PDR ADCK 05000206  
F PIC

Southern California Edison Company  <b>INTERIM CALCULATION CHANGE NOTICE (ICCN)                  CALCULATION CHANGE NOTICE (CCN)</b>	ICCN NO./PRELIMINARY CCN NO.		CCN CONVERSION :		CALC. REV. 5	
	CALCULATION NO. DC-2836		CCN NO. CCN- C-1	REV. 4	UNIT. 1	
	CALCULATION TITLE : SONGS-1 HYDRAULIC CALC. FOR AFW LINES - FLOW REQUIREMENTS					
	ORIGINATOR Sharok Khabir			SYS. NO/STAT. SYS. DESIGNATOR AFW		
	PAX 51319	DATE 8-6-90		PAGE 1 OF 1		

1.

REVISE CALC. DC-2836 TO INCLUDE ADDITIONAL SUPPLEMENT C. (ATTACHED.)

INITIATING DOCUMENT (NCR, SPR, OTHER) \_\_\_\_\_

2. OTHER AFFECTED DOCUMENTS (CHECK AS APPLICABLE):

YES  NO OTHER AFFECTED DOCUMENTS EXIST AND ARE IDENTIFIED ON ATTACHED 183/184 FORMS. THE APPLICABLE SOURCE DOCUMENT IS IDENTIFIED AS FOLLOWS:

THIS CCN OR  THE FOLLOWING DOCUMENT: \_\_\_\_\_

3. SCE DESIGN APPROVALS :

NUCLEAR GENERATION SITE DEPARTMENT		NES&L DEPARTMENT	
ORIGINATOR _____	DATE _____	ORIGINATOR <i>Sharok Khabir</i>	DATE 8/30/90
INDEPENDENT REVIEW ENGR. _____	DATE _____	INDEPENDENT REVIEW ENGR. <i>Wesley D. ...</i>	DATE 8/31/90
GROUP SUPERVISING ENGINEER _____	DATE _____	GROUP SUPERVISOR <i>Wesley D. ...</i>	DATE 9/7/90
DISCIPLINE MANAGER _____	DATE _____	DISCIPLINE MANAGER <i>Wesley D. ...</i>	DATE _____

4. CONVERSION TO CCN DATE \_\_\_\_\_

**CALCULATION TITLE PAGE**

Sheet C1-1A

SONGS Unit 1 DCP/MMP No. & Rev. 1-3587.0ISM Calc. No. DC-2836  
 Subject AFW FLOW REQUIREMENT VERIFICATION  
 Engineering System Number \_\_\_\_\_ Primary Station System Designator AFW Q-Class SR  
 Tech Spec Effecting  YES  NO Section No. 3.4.3 Equipment Tag No. \_\_\_\_\_

Computer Program	STANDARD COMPUTER PROGRAM <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	PROGRAM NO.(S)	VERSION/RELEASE NO.
------------------	--	----------------	---------------------


**RECORD OF ISSUES**

SCE DISC. or ESC	REV.	DESCRIPTION	TOTAL NO. of SHEETS	LAST SHEET NO.	ORIG.	IRE	GS	DM	DATE
MECH.	0	AFW FLOW VERIFICATION-Suppl.'c'	65	C1-65	SK	<i>[Signature]</i> 29 AUG 90	<i>[Signature]</i> 9/29	<i>[Signature]</i> 9/29	9/7/90

Space for RPE Stamp, reference alternate calc., and notes as applicable.

This calc. was prepared for the identified DCP/MMP. DCP completion and turnover acceptance to be verified by receipt of a memorandum directing DCN Conversion. Upon receipt, this calc. represents the as-built condition. Memo date \_\_\_\_\_ by \_\_\_\_\_.

**CALCULATION CROSS-INDEX**  
 Subject Calculation No. DC-2836 Suppl. 'c'

Subject Calculation Revision No.	Superseded By Calc. No.	INPUTS These interfacing calculations and /or documents provide input to the subject calculation, and if revised may require revision of the subject calculation.		OUTPUTS Results and conclusions of the subject calculation are used in these interfacing calculations and/or documents.		Does the output interface calc/document require revision? YES / NO	Identify output interface calc/document CCN or DCN TCN/Rev.	Group Supervisor or Station Technical Group Supervising Engineer Signature/Date
		Calc/ Document No.	Rev. No.	Calc/ Document No.	Rev. No.			
0	N/A	DC-3414	0	IMPELLCALC. TH 1	1	YES	N/A	
		DC-2836 Suppl. A	5	DATED 4/22/85 SONGS-1 HYDRAULIC CALC. SUPPL. A	-	NO	N/A	
	N/A	LETTER TO NRC ATWS MITIGATION SYSTEM DATED JULY 23, 1990	-	N/A	-	N/A	N/A	

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	C1-3
PRELIM. CCN NO.	PAGE _____ OF _____
CCN CONVERSION:	
CCN NO. CCN--	C-1

Project or DCP/MMP 1-3587-015M Calc No. DC-2638 Suppl. C

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR ↓
0	SK	8/28/90	CP	2/4/91						

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1.0 PURPOSE	C1-4
2.0 RESULTS/CONCLUSIONS AND RECOMMENDATIONS	C1-5
3.0 ASSUMPTIONS	C1-10
4.0 DESIGN INPUTS	C1-11
5.0 METHODOLOGY	C1-13
6.0 REFERENCES	C1-15
7.0 NOMENCLATURE	C1-16
8.0 COMPUTATIONS	C1-17
FIGURES AND ATTACHMENTS	
FIG. 1-7 CAVITATING VENTURI FLOW LIMIT & SYSTEM CURVES	C1-36
Attachment A DC-2836 Suppl. "A" Pump curves	C1-43
Attachment B Permutit test data	C1-59

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	C1-4
PRELIM. CCN NO.	PAGE ___ OF ___
CCN CONVERSION:	
CCN NO. CCN--	C-1

Project or DCP/MMP 1-3587-015M Calc No. DC-2638 SUPPL C

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/28/90	✓	24A069D						

**1.0 PURPOSE**

The purpose of this calculation is to determine if the auxiliary feedwater system can meet additional flow requirements that were not specified in the previous revision of this calculation.

Supplement "B" was performed to determine if the AFW system can meet the requirements for the following cases:

- . Feedwater line Break Upstream of check valve
- . Feedwater line Break Downstream of check valve
- . Station Blackout
- . Loss of Main Feedwater
- . Pump Runout
- . Water Hammer

This Supplement "C" covers the following additional conditions extracted from Ref.13:

- . Small Break LOCA
- . Steam Generator Tube Rupture
- . Normal Plant Cooldown
- . Steamline Break - Core Response
- . Steamline Break - Containment Response
- . Steamline Break - EQ Outside Containment
- . ATWS
- . Turbine Trip, Loss of Load, Loss of Condenser Vacuum
- . Appendix 'R'

For completeness Supplement 'C' includes the results of supplement 'B' and the margins between the required and expected flows. For specific cases of supplement "B", which are superceded by this calc, the changes are identified in the results section. In addition, this supplement incorporates actual test results (preliminary issue) from the Permutit field tests to provide general agreement with expected field results. In addition, this calculation will form the basis for the test guidelines.

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	PAGE <u>01-5</u> OF _____
PRELIM. CCN NO.	CCN CONVERSION: CCN NO. CCN-- <u>C-1</u>

Project or DCP/MMP 1-3587 OSM Calc No. DC-2638 SUPPL. C

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/28/90	0	29/11/90						

**2.0 RESULTS/CONCLUSIONS AND RECOMMENDATIONS**

2.1 The venturies will meet the AFW flow requirements specified in section 4.0 of this supplement.

Table 2.1 compares expected venturi flow rates with the AFW system flow requirements. It also compares the expected design values to the system design requirements. The difference expressed as margin is based on the use of 5532 and 5531 venturies for each design condition identified in Section 4.0 of this calculation.

2.2 The following events were previously evaluated in the calc. DC-2836 Supplement B and used in this Supplement to define the bounding conditions:

- Case 4.1 - Loss of Normal Feed (Supplement 'B' Case No. 3)
- Case 4.2 - Main Feedwater Line Break Upstream (Supplement 'B' Case No. 5)
- Case 4.3 - Main Feedwater Line Break Downstream (Supplement 'B' Case No. 2)
- Case 4.8 - Station Blackout (Supplement 'B' Case No. 4)
- Case 4.12 - Waterhammer (Supplement 'B' Case No. 1)
- Case 4.13 - Pump Run Out (Supplement 'B' Case No. 6)

2.3 Supplement "B" cases 4.1, 4.2, 4.3, 4.8 are re-evaluated due to the conservative results. Actual data available from the new venturi testing was incorporated.

2.4 Cases presented in this calculation identify bounding cases only. All other pumps and system configurations produce less limiting results and therefore, do not control the design.

2.5 Case 4.11- Appendix "R"

G10W pump curve intersects the most restrictive 5532 cavitation curve at 880 psig & 353 gpm. Since the venturies are cavitating, the flow rates through them cannot exceed 353 gpm. The margin associated with this flow rate is < 1%. This value is conservative because the calculated pressure drops are greater than the actual test data, thus, additional flow is expected during testing.

In addition, opening the bypass around the 4" venturi provides more flow margin. There is ample time during the event to open the by-

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	21-6
PRELIM. CCN NO.	PAGE ____ OF ____
CCN CONVERSION:	
CCN NO. CCN--	C-1

Project or DCP/MMP 1-3587.0/SM Calc No. DC-2638 SUPPL. C

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/28/92	0	29/1/95						

pass valve to allow more flow to the steam generators. G10W pump curve without 4" venturi is plotted on Fig. 7 and it intersects 5532 cavitating venturi curve at 363 gpm & 1010 psig. Additional margin is available if the bypass around the 3" venturies are also opened (opening the bypass valves has the potential to expose the system to water hammer and pump run out conditions). This action will require a revision to the operating procedures.

This flow rate increases the margin from < 1% to 3.7%.

2.6 Case 4.7c Steamline Break Outside Containment.

Pump G10S provides the least flow rate of 315 gpm for this event and is considered the most limiting case with the margin of 12%. The margin is based on a preliminary Westinghouse analysis which determines that the Steamline Break concerns are satisfied with reduced AFW flow rate.

The results of all the cases are identified in Table 2.1.



TABLE 2.1

## AFW REQUIREMENTS, EXPECTED FLOWS AND MARGINS

Design Condition	Required Flows (GPM)	Expected Flows (GPM)	Margin	Bounding Case	Remarks
4.1 Loss of Normal Feed	>185	G10W=255	37%	this Suppl. 'C'	To 3 S/GS @ 1015 psig
4.2 MFW Line Break Upstream of Check Valve	>100	G10W=140	40%	this Suppl. 'C'	To 2 S/GS @ 1015 psig
4.3 MFW Line Break Down-Stream of Check Valve	>175	G10S=210	20%	Case 2 Suppl. 'B' G10S Cavitate	To 2 S/GS @ 15 psia
4.4 Small Break LOCA	>185	G10W=255	37%	Bound by Case 4.1 Supplement 'C'	To 3 S/GS @ 1015 psig
4.5 S/G Tube Rupture	a) >120	G10W=312	160%	this suppl. 'C'	To 2 S/GS @ 250-750 psia. G10S cavitate @ 319 gpm & 730 psig
	b) >120	G10S=242	101%	Ditto	Ditto
4.6 Normal Plant Cooldown	a) >185	G10W=295	59%	Case 4.6 this calc. Suppl. 'C'	To 3 S/GS @ 125-923 psia
	b) >185	G10S=319	72%		G10S controls @ < 500 psig
4.7 Steamline Break Outside Containment	a) >150	G10W=255	70%	Case 4.1 above	To 3 S/GS @ 1015 psig
	b) >280	G10W=352	26%	this suppl. 'C'	To S/GS @ 700 psia
	c) >280	G10S=319	14%	this suppl. 'C'	To 3 S/GS @ 15-700 psia, G10S controls* @ < 500 psig
	d) >215	G10+G10S=393	82%	Ditto	To 3 S/GS @ 875 psia
	e) >215	G10W=310	44%	Ditto	cavitate To 3 S/GS @ 875 psia

DC-263850pp1 & C1-7  
SK 8/28/90  
CRP 2444-50

TABLE 2.1

AFW REQUIREMENTS, EXPECTED FLOWS AND MARGINS

Design Condition	Required Flows (GPM)	Expected Flows (GPM)	Margin	Bounding Case	Remarks
4.8 Station Blackout	>185	G10=300	62%	Case 8.6 above	To 3 S/GS @ 923 psia
	>185	G10W=295	59%	Case 8.6 above	To 3 S/GS @ 923 psia
4.9 ATWS	>185	G10W=255	37%	Case 8.1 above	To 3 S/GS @ 1015 psig
4.10 Turbine Trip Loss of Load, Loss of condenser vacuum	>185	a) G10W=295	59%	Case 4.6 above Suppl. 'C'	To 3 S/GS @ 125-923 psia. Both pumps cavitate as press. decreases. G10S controls @ < 500 psig
		b) G10S=319	72%	Case 4.6 above	
4.11 Appendix 'R'	>185	G10W=295	59%	This suppl. C	To 3 S/GS @ 923 psia
a) 4" venturi bypass closed	>350	G10W=353	<1%	This suppl. 'C'	To 3 S/Gs @ 15 psia
b) 4" venturi bypass open	>350	G10W=363	3.7%	Case 4.11 above	To 3 S/GS @ 15 psia
c) 3" venturi bypass also open	>350	G10W=450	28%	this suppl. 'C'	To 3 S/Gs @ 15 psia
4.12 Water Hammer	<450	G10+G10S +G10W=397	-	This Suppl. 'C'	To 3 S/GS @ 15-1030 cavitate @ less than 450 gpm
4.13 Pump Runout	<420	G10S=319	-	Case 6 Suppl. 'B'	To 3 S/GS @ 15-1030 psia. Cavitate @ less than 420 gpm
4.14 Steamline Break Core Response	<1419	G10W=352	-	Case 3 Suppl. 'B'	To 3 S/GS @ 15 psia cavitate @ less than 420 gpm

DC-2638 Suppl. C  
 SK 8/19/92  
 CL-8  
 CR 29AUG92

TABLE 2.1

AFW REQUIREMENTS, EXPECTED FLOWS AND MARGINS

Design Condition	Required Flows (GPM)	Expected Flows (GPM)	Margin	Bounding Case	Remarks
4.15 Steamline Break Inside Containment	<500	G10W=352	-	Case 3 Suppl. 'B'	To 3 S/GS @ 15 psia cavitate @ less than 500 gpm

\*Shown as point in time when G10 not available, however, above S/G pressure at 500 psig G10 is available.  
 Note: Where pressure ranges are shown the highest pressure was used to establish flow & margins.

DC-2638 Suppl. 'C' 21-9  
 SK 8/21/50  
 CLK DESIGN

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	C1-13
PRELIM. CCN NO.	PAGE ___ OF ___
CCN CONVERSION:	
CCN NO. CCN--	C-1

Project or DCP/MMP 1-3587.01SM

Calc No. DC-2638 Suppl. 'C'

Sheet No. \_\_\_\_\_

Subject AFW FLOW VERIFICATION

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR ↓
0	SK	8/21/90	0	29A&9D						

**3.0 ASSUMPTIONS**

1. Auxiliary Feedwater temperature is 70°F.
2. Venturi recovery factors will be the same as those reported during the calibration testing of the new AFW venturi.
3. Line losses and flow coefficients for the three venturies are assumed equal for stating that the flows through each branch are the same.
4. Flow requirements identified in this Supplement are in addition to the cases identified as limiting in the DC-2836 Supplement B.
5. Flow around cavitating venturies is assumed zero. The bypass around the 3" venturies will be closed. For the Appendix 'R' Case 4.11b the bypass around the 4" venturi will be opened when needed.
6. The pumps system pressure curves at inlet to venturies are based on the original manufacture curves, which are assumed correct.
7. Pressure drop in suction piping is negligible.

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	PAGE <u>C1-11</u> OF
PRELIM. CCN NO.	
CCN CONVERSION:	CCN NO. <u>CCN-- C-1</u>

Project or DCP/MMP L-3587.DISM Calc No. DC-2638 SUPPL. C

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/28/90	0	29 AUG 90						

**4.0 DESIGN INPUTS**

Venturies are sized to meet the following parameters:

- 4.1 Loss of Normal Feed  
 AFW Flow >185 GPM to 3 S/Gs @1030 psia.  
 Bound by Case No. 3 Ref. 1
- 4.2 Main Feedline Break- Upstream of check valve  
 AFW Flow >100 GPM to 2 S/GS @ 1030 psia.  
 Bound by Case No. 5 Ref. 1
- 4.3 Main Feedline Break- Downstream of check valve  
 AFW Flow >175 GPM to 2 S/G @ 15 psia.  
 Bound by Case No. 2 Ref. 1
- 4.4 Small Break LOCA  
 AFW Flow >185 GPM to 3 S/GS @ 1030 psia (Ref. 6)
- 4.5 Steam Generator Tube Rupture  
 AFW >120 GPM to 2 S/GS @ 250-750 psia (Ref. 7)
- 4.6 Normal Plant Cooldown  
 AFW Flow >185 GPM to 3 S/GS @ 125-923 psia  
 (Ref. UFSAR 9.2 and 6.5)
- 4.7 Steam Line Break Outside Containment (Ref. 9)  
 G10W Flow >165 GPM to 3 S/GS @ 1030 psia  
 G10W Flow >280 GPM to 3 S/GS @ 700 psia  
 G10W Flow >280 GPM to 2 S/GS @ 15 - 700 psia  
 G10W Flow >215 GPM to 3 S/GS @ 875 psia
- 4.8 Station Blackout  
 G10W Flow >185 GPM to 3 S/GS @ 923 psia (Ref. 8)  
 G10 Flow >185 GPM to 3 S/GS @ 923 psia (Ref. 8)  
 Bound by Case No. 4 Ref. 1
- 4.9 ATWS  
 AFW FLOW >185 GPM to 3 S/G @ 1030 psia (Ref. 12)
- 4.10 Turbine Trip, Loss of Load, Loss of Condenser Vacuum  
 G10W Flow >185 GPM to 3 S/GS @ 125-923 psia  
 Bound by Case No. 4 Ref. 1

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	C1-12
PRELIM. CCN NO.	PAGE _____ OF _____
CCN CONVERSION:	
CCN NO. CCN-- C-1	

Project or DCP/MMP 1-3587.2ISM Calc No. DC-2638 SUPP

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/28/90	Q	29A x 90						

4.11 Appendix 'R'

AFW Flow >185 GPM to 3 S/GS @ 923 psia Bound by Case No. 3 Ref. 1  
 AFW Flow > 350 GPM to 3 S/GS @ 15 psia (Ref. 11)

4.12 Water Hammer (Ref. UFSAR 8.5)

AFW Flow <450 GPM (total) to 3 S/GS @ 15-1030 psia  
 Bound by Case No. 1 Ref. 1

4.13 Pump Runout

G10S Flow <420 GPM to 3 S/GS @ 15-1030 psia  
 Bound by Case No. 6 Ref. 1

4.14 Steamline Break - Core Response (Ref. 11)

AFW Flow <1419 GPM to 3 S/GS @ 15 psia  
 Bound by Case No. 3 Ref. 1

4.15 Steamline Break Inside Containment

AFW Flow <500 GPM to 3 S/GS @ 15 psia  
 Bound by Case No. 1 Ref. 1

AFW pump system curves ( based on manufacturers curves and field test )  
 and permutit venturi curves have been used to determine the margins  
 available above the system design requirements. (Ref. 1, 2 and 6).

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	C1-13
PRELIM. CCN NO.	PAGE OF
CCN CONVERSION:	
CCN NO. CCN--	C-1

Project or DCP/MMP J-3587-0ISM Calc No. DC-2638Suppl. C

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/28/90	0	29AUG 90						

5.0 METHODOLOGY

Calculate AFW flow rates for each of the design conditions, Section 4.0, for the new venturies by using the following steps.

- 5.1 Identify AFW conditions covered by the calculation DC-2836 Supplement B.
- 5.2 Identify AFW conditions bound by the existing analyses. This is accomplished by a comparison between the additional AFW flow requirements and those AFW flows in the Supplement B at the same steam generator pressures.
- 5.3 The remaining conditions are analyzed per the following steps:
  - 5.3.1 Plot pumps G10S and G10W curves using Ref. 2
  - 5.3.2 Plot cavitating venturi curves using Wyle test results (attachment B)
  - 5.3.3 Calculate system coefficient ( $K_{sys}$ ) from Ref. 1 & 2. per the following steps:
    - 5.3.3.1 Calculate the highest line losses from the pump through the discharge control valve to the steam generator venturi. (line losses from the pump to the first branch to other FCV's are based on the longest pipe run and full flow)
    - 5.3.3.2 Calculate pressure drop across pump discharge valve and flow control valve using full flow through pump discharge valve and third through FCV. ( branch piping downstream of the pump discharge valve to the FCV's are assumed to have the same pressure drop to the steam generators)
  - 5.3.4 Calculate total system pressure drop using the equation  $\Delta P = P_{sig} + K_{sys} \cdot Q^2 + \text{Elev. Difference}$  for various flows (Q values are chosen from pump curves to plot  $\Delta P$ ).
  - 5.3.5 Plot new system curves using  $\Delta P$  above.

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	C-14
PRELIM. CCN NO.	PAGE _____ OF _____
CCN CONVERSION:	
CCN NO. CCN--	C-1

Project or DCP/MMP L-3587-01SM Calc No. DC-26585uppl.C

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/28/90	0	29A x 90						

- 5.3.6 Determine flow rates from intersections of the system curves with either the bounding pump curve or the cavitating venturi curve.
- 5.3.7 Determine the lowest flow from step 5.3.7 above. Calculate the AFW flow margins by comparing calculated and required flows for a venturi 5531 or 5532. (Wyle numbers)
- 5.3.9 Enter AFW flow rates and margins in Table 2-1.
- 5.3.10 Based on engineering judgement, determine if the margin is acceptable for this system.



NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	C1-15
PRELIM. CCN NO.	PAGE _____ OF _____
CCN CONVERSION:	
CCN NO. CCN--	C-1

Project or DCP/MMP 1-3587.01SM Calc No. DC-2836 Suppl. C

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	6/22/90	0	29A/290						

**6.0 REFERENCES**

1. Calculation DC-2836 Supplement 'B' dated 5/9/90.
2. Calculation DC-2836 Supplement 'A' dated 3/22/90.
3. Westinghouse Feedline break reanalysis with reduced auxiliary feed flow dated 5/9/90 (SCE-90-578).
4. UFSAR chapters 6, 15 and 16 are used to identify additional AFW flow requirements.
5. Impell calc. TH1 "Dedicated Safe Shutdown System" Job No. 0310-007-1372. Dated 4/22/85.
6. SONGS 1 Small Break LOCA WCAP-9600, W NSSS Small Break Report 6/1979.
7. Letter to NRC Emergency Procedure Upgrade, May 20, 1982.
8. Station Blackout, SCE Doc. 90050 Rev. 1.
9. Steamline Break Outside Containment WCAP.11294.
10. Appendix 'R' Letter to NRC, Fire Protection Program, dated May 21, 1985.
11. Steamline Break Core Response UFSAR 6.2.
12. ATWS, Letter to NRC, ATWS Mitigation System, July 1990.
13. Design Calculation DC-3414 Rev. 0 "AFW Flow Requirements"
14. Preliminary Engineering Package 1-3587.01SM
15. DC-2836 Rev 5.
16. Crane Technical paper 410.

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	C1-10
PRELIM. CCN NO.	PAGE ____ OF ____
CCN CONVERSION:	
CCN NO. CCN--	C-1

Project or DCP/MMP 1-3587-0ISM Calc No. DC-2638 SUPPL. C

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR ↓
0	SK	8/24/90	Ⓟ	29 AUG 90	△					
△					△					

**7.0 NOMENCLATURE**

GPM - Gallons Per Minute

$K_{sys}$  - System Pressure Loss Coefficient

$K_v$  - Pressure Loss Coefficient for Venturi (Non cavitating)

PD - Pump Discharge Pressure psig

$P_{S/G}$  - Static Pressure psig Steam Generator

S/G - Steam Generator

$\Delta P$  - Pressure Drop for System

Q - Flow (GPM)

$P_{discharge}$  - Pump discharge pressure (psig)

$P_s$  - Pump suction pressure (psig)

$P_L$  - Piping pressure loss (psi)

additional nomenclature is identified in the in the body of the calculation.

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	PAGE <u>C1-17</u> OF
PRELIM. CCN NO.	
CCN CONVERSION:	
CCN NO. CCN--	<u>0-1</u>

Project or DCP/MMP 1-3587 OISM

Calc No. DC-2638 Suppl. C'

Sheet No. \_\_\_\_\_

Subject AFW FLOW VERIFICATION

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/22/90	0	29A1690						

**8.0 COMPUTATIONS**

The pump and system curves used in the previous revisions of this calculation are further corrected for the actual venturi test data from Wyle labs. The reference point of the pump and system curves is moved to the venturi inlet to provide direct reading of the cavitation curves.

To reference the pump curves at the venturi inlet, the pressure drops due to the elevation changes and line losses between the pump discharge and the venturi inlet have to be subtracted from the discharge pressure for the design flow rates.

- A. Calculate the pressure drop  $\Delta P$  due to elevation changes:

Pipe elevation at venturi            23.17 Ft @ FE 3066 (highest venturi)  
 Discharge pump elevation            16.83 Ft @ G10s (lowest pump)

$$\Delta H = 6.34 \text{ Ft (Maximum height)}$$

Convert  $\Delta H$  to psi,  $\Delta P = 6.34 \text{ Ft} * 0.4328 \text{ psi/Ft} = 2.74 \text{ psi}$

- B. Calculate line losses to the venturi

Compare calculated line losses to the field data from the cycle 10 return the service testing.

The field test data indicated a pressure drop of;

26 psi @ 325 gpm ( from pump discharge to control valves)

- C. Compare the above field data to calculate line losses by determining the line losses from control valves to venturies. Use the below simplified sketch for calculating  $\Delta P$  from one pump to one of the venturies. The Pump G-10 flow path the Steam Generator B was selected because it has the highest resistance (The calc will be conservative for cases sensitive to lower pump curves).

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	PAGE <u>21-18</u> OF <u>    </u>
PRELIM. CCN NO.	CCN CONVERSION:
	CCN NO. CCN-- <u>C-1</u>

Project or DCP/MMP ] - 3587.0] SM Calc No. DC-2836 Suppl. "C"


Subject AFW flow requirement verification

Sheet No.     

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE
0	SK	8/28/90	D	29 NOV 90					

REV. INDICATOR

FIGURE 1  
 SYSTEM SCHEMATIC



NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	PAGE <u>C1-19</u> OF <u>    </u>
PRELIM. CCN NO.	
CCN CONVERSION:	
CCN NO. CCN-- <u>C-1</u>	

Project or DCP/MMP 1-3587.015M Calc No. DC-2638 SUPPL C

Subject AFW FLOW VERIFICATION

Sheet No.     

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/28/90	⊙	29 AUG 90						

- D. Calculate  $\Delta P$  from pump discharge to the control valve inlets at 325 gpm. 325 gpm was selected to provide a direct comparison with the test data.

Convert  $C_v$  values of the motor operated and control valves to K values:

$$K_{\text{control valve}} = 891 d^4 / C_v^2 \quad (\text{Ref. 16}) \quad \text{Eq. 1}$$

where  $C_v = 28.8$  (Ref. 15 page 11) and  $d = 3''$

$$K_{\text{control valve}} = 87$$

$$K_{\text{MOV}} = 8.72, \text{ where } C_v = 91 \text{ (Ref. 15 page 11)}$$

- E. Convert line losses to K values:

$$K = f L/D \quad (\text{Ref. 16}) \quad \text{Eq. 2, where } f=0.018, D=0.25 \text{ Ft}$$

$L = 221 \text{ Ft}, K = 16$  and,  
 $L = 327 \text{ Ft}, K = 23.5$

- F. Determine total K:

$$K_{\text{total}} = K_{\text{line}} + K_{\text{mov}} = 16 + 8.72 = 24.72$$

$$K_{\text{total}} = K_{\text{control valve}} + K_{\text{line to venturi}} = 23.5 + 87 = 110.5$$

- G. Calculate  $\Delta P =$  pump to control valve inlet (K control valve not included based on Ref. 16).

$$\Delta P = 0.00001799 * K * B * Q^2 / d^4 \quad \text{Eq. 3}$$

$\Delta P$  pump to branch:

Solve the above equation for the following;

$$B = 62.35 \text{ lb/ft}^3, Q = 325 \text{ gpm}, d = 3''$$

$$K_{\text{total}} = 24.72$$

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	C1-20
PRELIM. CCN NO.	PAGE ____ OF ____
CCN CONVERSION:	
CCN NO. CCN--	C-1

Project or DCP/MMP1 3587-015M Calc No. DC-2638 SUPPL. 'C'

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/28/90	0	29A x 90						

$\Delta P = 36.15 \text{ psi}$

$\Delta P$  branch to Control Valve inlet:

$B = 62.35 \text{ lb/ft}^3$  ,  $Q = 108.33 \text{ gpm}$  ,  $d = 3''$

$K_{\text{total}} = 23.5$

$\Delta P = 3.8 \text{ psi}$

Therefore; the pressure drop from the pump discharge to the inlet to the venturies at 325 gpm is;

$36.15 \text{ psi}$   
 $+ 3.8 \text{ psi}$   


---

 $39.95 \text{ psi}$

- H. Comparing the field data to the calculated values;
- $(39.95/25) = 59.8\%$  difference
- This difference indicates that the calculation will be conservative for the cases sensitive to lower pump curves. Cases that are not conservative will be identified and corrected for higher expected pressures. It can be expected that the test results will be 15 psi higher at the inlet to the control valve for this flow rate.
- I. The  $\Delta P$  for the control valve is calculated to determine the pressure venturi inlet.
- $\Delta P = 14.14$  from eq. 2
- where  $B = 62.35 \text{ lb/ft}^3$  ,  $Q = (325/3) = 108 \text{ gpm}$  ,  $d = 3''$  ,  $K = 87$
- Therefore, line losses to the venturi inlet are;
- $\Delta P = 39.95 + 14.14 = 54 \text{ psi @ } 325 \text{ gpm}$ .
- J. Create a pressure loss table, 8-1, as a function of pump flow: Based on the above formula,

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	C1-21
PRELIM. CCN NO.	PAGE ___ OF ___
CCN CONVERSION:	
CCN NO. CCN-- C-1	

Project or DCP/MMP 1-3587-015M Calc No. DC-2638 SUPPL. C

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/28/90	Ø	29AUX90						

Line Loss Table 8-1

Pump Flow (gpm)	$\Delta P$ pump to branch	$\Delta P$ branch to Venturi	Total Loss
50	0.86	0.42	1.3
100	3.4	1.7	5.1
150	7.7	3.82	11.5
200	13.7	6.8	20.5
250	21.4	10.6	32
300	30.8	15.3	46.1
350	41.9	20.82	62.7
400	54.8	27.82	82
450	69.3	34.4	103.7
500	85.6	42.5	128.1

Based on the above values in table 8-1 revise the pump curves to show the venturi as a function of pump flow. The table is created by reducing the pressure at the pump discharge by the values in the table 8-1.

K. The revised system pressure curves at inlet to venturi are shown on:

- Table 8-2 G10W
- Table 8-3 G10S
- Table 8-4 G10

G10 + G10S curves were generated graphically by adding the resultant pump curves of G10 and G10S.

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	C1-22
PRELIM. CCN NO.	PAGE ____ OF ____
CCN CONVERSION:	
CCN NO. CCN--	C-1

Project or DCP/MMP 1-3587-01SM

Calc No. DC-2638 Suppl. C

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/21/90	Q	29 AUG 90						

G10W system pressure curve at inlet to venturi Table 8-2

System Flow (gpm)	Disch. Press. (psig)*	Line Loss to Venturi	Δelev pump to venturi	Pump press. @ venturi (psig)
0	1315	-	2.7	1312.3
50	1310	1.3	2.7	1306
100	1290	1.3	2.7	1286
150	1260	11.5	2.7	1246
200	1200	20.5	2.7	1177
250	1130	32	2.7	1095
300	1050	46.1	2.7	1001
350	590	62.7	2.7	885
400	830	82	2.7	745
450	705	103.7	2.7	599

\* Discharge pressure were extracted from Fig.9 Page 57 of Reference 2.

G10S system pressure curve at inlet to venturi Table 8-3

System Flow (gpm)	Disch. Press. (psig)**	Line Loss to Venturi	Δelev pump to venturi	Pump press. @ venturi (psig)
0	1225	-	2.7	1222.3
50	1205	1.3	2.7	1201
100	1170	5.1	2.7	1162.2
150	1110	11.5	2.7	1095.8
200	1010	20.5	2.7	986.8
250	900	32	2.7	865.3
300	780	46.1	2.7	771.2
350	640	62.7	2.7	574.6
400	480	82	2.7	395.3



NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO.	C-23
PRELIM. CCN NO.	PAGE ___ OF ___
CCN CONVERSION:	
CCN NO. CCN--	C-1

Project or DCP/MMP 1-3587.0ISM

Calc No. DC-2688 Suppl. C'

Sheet No. \_\_\_\_\_

Subject AFW FLOW VERIFICATION

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR ↓
0	SK	6/28/90	0	29 AUG 90						

\*\* Discharge pressures were extracted from Fig.3 Page 51 of Reference 2.

G10 system pressure curve at inlet to venturi Table 8-4

System Flow (gpm)	Disch.Press. (psig)*	Line Loss to Venturi	Δelev pump to venturi	Pump press. @ venturi (psig)
0	1305	-	2.7	1302.3
50	1280	1.3	2.7	1276.4
100	1245	5.1	2.7	1237.2
150	1210	11.5	2.7	1195.8
200	1170	20.5	2.7	1146.8
250	1130	32	2.7	1095.3
300	1070	46.1	2.7	1021.2
350	1000	62.7	2.7	935
400	930	82	2.7	845.3

\* Discharge pressure were extracted from Fig. 3 page 51 of Ref. 2.

G10 + G10S system pressure curve at inlet to venturi Table 8-5

System Flow (gpm)	Disch.Press. (psig)**	Line Loss to Venturi	Δelev pump to venturi	Pump press. @ venturi (psig)
200	1210	6.8	2.7	1200
300	1175	15.3	2.7	1152
400	1120	27.8	2.7	1089

\*\* Discharge pressure were extracted from Fig. 3 page 51 of Ref. 2.

Line losses were based on 1/2 the flow through the branch and 1/3 through the Venturi piping.

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	C1-24
PRELIM. CCN NO.	PAGE OF
CCN CONVERSION:	
CCN NO. CCN--	C-1

Project or DCP/MMP 1-3587-015M Calc No. DC-2638 SUPPL. C

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/28/90	0	29 AUG 90						

- Calculate the elevation change from 3" venturi to the steam generators.

The elevation of the steam generator = 41.37 Ft  
 Elevation of the lowest venturi (FE 3076) = 21.67 Ft

$$\Delta H = 19.7 \text{ Ft}$$

Convert to psi = 19.7 ft \* 0.4329 psi/ft = 8.53

- M. Determine the pressure drop from the venturi outlet to the steam generator:

L = 174.5 Elev. to steam generator B

convert L to K:

$K = f L/D$ , where  $f = 0.018$  and  $D = 0.25 \text{ Ft}$

K = 12.56

- N. Calculate  $\Delta P$  for pump flow of 325 gpm from Eq.3:

$\Delta P = 2.04$  per single flow branch  
 where  $B = 62.35 \text{ lb/ft}^3$ ,  $Q = 325/3 = 108 \text{ gpm}$ ,  $D = 3"$

- O. Calculate the  $\Delta P$  for the venturies.

Refine the venturi test data and determine the  $K_v$  values for each venturi.

$$K_v = \Delta P/Q^2$$

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	C1-25
PRELIM. CCN NO.	PAGE ___ OF ___
CCN CONVERSION:	CCN NO. CCN-- C-1

Project or DCP/MMP 1-3587-DISM Calc No. DC-2638 SUPP.C Sheet No. \_\_\_\_\_  
 Subject AFW FLOW VERIFICATION

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/28/90	Ø	29 AUG 90	△					
△					△					

From the test data (see attachment A):

Table 8-6

ΔP	Q <sub>test</sub>	K <sub>v</sub>	Venturi
86.9	106.8	7.62E-3	5530
55.6	84.2	7.84E-3	
32.2	61.4	8.54E-3	
27.3	55	9.03E-3	
		$\overline{K_{v,ave}} = 8.26E-3$	
100.1	101.5	9.7E-3	5531
67.3	82.3	9.94E-3	
39.4	62.4	1.01E-2	
29.9	54.4	1.01E-2	
		$\overline{K_{v,ave}} = 9.96E-3$	
73.6	105.1	6.67E-3	5532
47	84.7	6.55E-3	
29	62.9	7.33E-3	
21.5	54.5	7.24E-3	
		$\overline{K_{v,ave}} = 6.95E-3$	

P. . Based on the above K<sub>v</sub> values create a system loss table for the maximum and minimum loss from the venturi outlet to the steam generator.

Convert K<sub>v</sub> to ΔP using K<sub>v</sub> = ΔP/Q<sup>2</sup> solving for ΔP;  
 $\Delta P = K_v \cdot Q^2$

$\Delta P = \Delta P_{venturi} + \Delta P_{piping}$

$K_v = 9.96 \cdot 10^{-3} (5531)$

$K_v = 6.95 \cdot 10^{-3} (5532)$

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	C1-26
PRELIM. CCN NO.	PAGE ____ OF ____
CCN CONVERSION:	
CCN NO. CCN-- C-1	

Project or DCP/MMP 1-3587-01SM Calc No. DC-2638-Supp.C

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/21/90	0	29 AUG 90						

System Loss Table 8-7

Pump Flow rate(gpm)	Single Venturi Flow(gpm)	$\Delta P$ line Loss(psi)	Max. $\Delta P$ (psi)	Min. $\Delta P$ (psi)
50	16.6	0.043	2.7	1.9
100	33.3	0.19	11	7.72
150	50	0.43	24.75	17.37
200	66.6	0.77	44	30.88
250	83.7	1.2	68.75	48.26
300	100	1.7	99	69.5
350	116	2.4	134.75	94.59
400	133.33	3.1	176	123.5
450	150	3.9	222.7	156.37

8.1 Case 4.1. Loss of Normal Feed ( @ S/G pressure of 1030 psia)

This case is identified in the calc. DC-2835 Supplement "B" as case number 3. (Ref. 1).

. Calculate the system losses as a function of flow.

Calculated  $\Delta P$  for the system curves have to be adjusted for elevation changes from the venturries to steam generators.

Loss due to elevation = 8.5 psid

$\Delta P$  Max. and Min. venturi (Table 8-5)

$$P = P_{s/g} + \Delta P + \text{Elev. Loss}$$

$$P = 1015.3 + 8.5 + \Delta P = 1023.8 + \Delta P$$

Qcurve	System Curves		G10W	Based on Figure 2 % Margin
	Max. Ppsig	Min.		
150	1052	1044	252-265	39%
250	1097	1077		
350	1164	1123		
450	1254	1187		

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	C1-27
PRELIM. CCN NO.	PAGE OF
CCN CONVERSION:	CCN NO. CCN-- 0-1

Project or DCP/MMP 1-3587.0ISM Calc No. DC-2638 Suppl. C

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/20/90	Q	29AUG90						

Ppsig = System pressure based on (Qcurve/3) per steam generator

Psig = Ps/g + ΔP + Elev. loss

% Margin = % calculated based on the ratio of the minimum flow rate requirements and the Qcalc.

PS/G = 1030 psia = 1015.3 psig

% margins of 36% is based on pump G10W.

8.2 Case 4.2 Main Feedwater Line Break Upstream.

At the time of break flow out of the broken line increases until it reaches cavitation flow rate. By using attachment "A" cavitating  $K_v$  can be determined as follow:

$$Q^2 = K_v * \Delta P$$

$$\Delta P = 1168.5 \text{ psid}, Q = 136.3 \text{ gpm}, K_v = 15.9$$

Using Ref. 1 method obtain the following:

$$Q_T = 2 * Q_{\text{unaffected S/G}} + Q_{\text{throughout the break}}$$

$$Q_T = 2 * Q_1 + Q_2$$

$$Q_T = 2 * K_{1,2} * (P_D - P_{S/G} - \Delta P_{EL})^{1/2} + K_{CAVITATION} * (P_D + (14.7 - P_v))^{1/2}$$

$$K_{1,2} = 1 / (K_{sys})^{1/2} = 9.8, \text{ where } K_{sys} = K_v + K_{sys \text{ without venturi}}$$

$$K_{1,2} = 1 / (5.12E-4 + 9.96E-3)^{1/2} = 9.8, K_{sys} = 5.12E-4$$

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	CI-27
PRELIM. CCN NO.	PAGE ____ OF ____
CCN CONVERSION: C-1	
CCN NO. CCN--	

Project or DCP/MMP 1-3587-0ISM Calc No. DC-2638 SUPPL. 'C'

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/28/92	0	29AUG92						

Venturi	$\Delta P$ (psid)	Q(gpm)	$K_{cavitation}$
5530	1168.5	136.3	3.99
5531	1175.7	139.7	4.07
5532	1178.2	136.5	3.98

Use  $K_{cavitation} = 4$

$K_{CAVITATION} = (K_v)^{1/2} = 4$ , where  $K_v = 15.9$

$\Delta P$	$2 * Q_1$	$Q_2$	$Q_T$
1200	259	139	398
1190	250	139	389
1180	243	138	381
1170	235	138	373
1160	227	137	364
1140	209	136	345
1100	168.5	133.5	302
1050	96.5	130.5	227
1026	0	129	129

Plot above  $\Delta P$  and  $Q_T$ .

This curve intersects with pump G10W at 270 gpm @ 1075 psig. Extending this point to the 5532 venturi curve at 390 gpm & 1075 psig. One third (out the break) of this value subtracted from 270 equals to 140 gpm (to 2 S/Gs). Therefore AFW flow to 2 S/Gs is 140 gpm with a margin of 40%.

8.3 Case 4.3 MFW Break Downstream

This case is identified in the calc. DC-2835 Supplement 'B' as Case No. 2 (Ref. 1).

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	C1-28
PRELIM. CCN NO.	PAGE _____ OF _____
CCN CONVERSION:	
CCN NO. CCN--	C-1

Project or DCP/MMP L-3587 OISM Calc No. DC-2688 Suppl. C

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	2/28/90	0	29 AUG 90						

Venturi	$\Delta P$ (psid)	Q(gpm)	$K_{cavitation}$
5530	1168.5	136.3	3.99
5531	1175.7	139.7	4.07
5532	1178.2	136.5	3.98

Use  $K_{cavitation} = 4$

$K_{CAVITATION} = (K_v)^{1/2} = 4$ , where  $K_v = 15.9$

$\Delta P$	$2 * Q_1$	$Q_2$	$Q_T$
1200	259	139	398
1190	250	139	389
1180	243	138	381
1170	235	138	373
1160	227	137	364
1140	209	136	345
1100	168.5	133.5	302
1050	96.5	130.5	227
1026	0	129	129

Plot above  $\Delta P$  and  $Q_T$ .

This curve intersects with pump G10W at 267 gpm.

G10+G10S cavitate at 393 gpm .

Margin for this case for G10W is 167%.

8.3 Case 4.3 MFW Break Downstream

This case is identified in the calc. DC-2835 Supplement 'B' as Case No. 2 (Ref. 1).

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	PAGE <u>C1-29</u> OF <u>    </u>
PRELIM. CCN NO.	CCN CONVERSION:
	CCN NO. CCN-- <u>C-1</u>

Project or DCP/MMP 1-3587.0ISM Calc No. DC-2638 suppl. 'C'

Subject AFW FLOW VERIFICATION

Sheet No.     

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/28/90	0	29A-J6 90						

By inspection of Fig.1, it is evident that pump G10S is the limiting pump at steam generator pressure of 15 psia. The maximum flow expected can be determined from the intersection of G10S reduced pump curve and the 5532 venturi cavitation curve. Total flow of 315 gpm or 210 gpm to 2 steam generators with a margin of 20%. Adding more pressure to the pump curve will allow more flow to pass through the break and less flow is available to the steam generators. However, this change is very small not calculated.

**8.4 Case 4.4 Small Break LOCA**

This case is in addition to the cases identified in the Supplement B of calc. DC-2836 (Ref. 1).

The AFW flow requirement for this case is bound by the case number 4.1 of this Supplement 'C' with AFW flow rate of 255 gpm with a margin of 37%.

**8.5 Case 4.5 Steam Generator Tube Rupture**

Afw flow is manually terminated to one steam generators because of a postulated failure. For this case, the Max. K for one path to the steam generator is  $K = 9.9E-3$ .

Determine the system curve when 1/2 of the flow goes through the branch.

From the Table 8-7 create  $\Delta P +$  line losses column based on the 1/2 of the pump flow.



NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	C-130
PRELIM. CCN NO.	PAGE _____ OF _____
CCN CONVERSION:	
CCN NO. CCN--	C-1

Project or DCP/MMP 1-3587. OISM

Calc No. DC-2638 SUPPL. C'

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/21/90	Q	25/11/90						

	pump flow gpm	gpm	flow each psi	ΔP Max. psi	Δ line Total psi	S/G press.
100	80		24.75	0.43	25.2	768.7
200	100		99	1.7	100.7	844.2
300	150		222.7	3.9	226.6	970.1
400	200		396	6.8	402.8	1146.3

System curve is plotted based on the above data and it intersects G10W and G10S at 312 gpm and 255 gpm respectively. These correspond to 160% and 101% margins.

8.6 Case 4.6 Normal Plant Cooldown

This case is bound by the AFW flow rate assumed tin the LONF at an AFW flow rate of 185 GPM. Pump G10W expected flow is calculated below:

$$P = P_{s/g} + \Delta P + \text{elev. loss} = 923 - 14.7 + 8.5 + \Delta P$$

$$P_{s/g} = 923 \text{ psia}$$

$$P = 916.8 + \Delta P \text{ from Table 8-7}$$

Qcurve	Ppsig Max.	Min.	G10W	G10S*	Margins
150	945	938	305-295	319	59%-72%
250	990	970			
350	1058	1017			
450	1148	1080			

\* G10S controls @ < 500 psig  
 Ppsig = System pressure based on (Qcurve/3) per steam generator

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	C1-31
PRELIM. CCN NO.	PAGE ____ OF ____
CCN CONVERSION:	
CCN NO. CCN--	C-1

Project or DCP/MMP 1-3587-05M Calc No. DC-2638 Suppl. 'C'

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/28/90	Ø	29 AUG 90	△					
△					△					

$Psig = Ps/g + K_{sys} * Q^2_{curve} + Elev. loss$

% Margin = % calculated based on the ratio between the minimum flow rate requirements and Qcalc.

$PS/G = 923 psia = 908 psig$

% margins of 72% & 59% are used for pumps G10S and G10W respectively.

8.7 Case 4.7 Steamline Break Outside Containment

- The AFW flow rate for this case at steam generator pressure of 1030 psia is bound by the existing LONF analysis (Case No. 4.1 of this Suppl. C) except AFW minimum flow is 150 gpm with expected G10W flow of 255 gpm with 70% margin).
- The minimum AFW flow rate for this case at steam generator pressure of 685 psig is 280 gpm per Ref. 14 Section 2. The pump G10W expected flow is as follow: (Ref. 1 Case 2)

DATA:  $P = Ps/g + \Delta P + Elev. loss, P = 685 + \Delta P, \Delta P$  from Table 8-5  
 $P = 693.5 + \Delta P$

Qcurve	System Curve		From Figure 6		Margin
	Ppsig	G10W	G10S	*	
	Max.	Min.			
150	718	710.8	352	319	72%-26%
250	762	742			
350	828	788			
450	916	850			

\* G10S controls @ < 500 psig  
 G10 + G10S and G10W pumps cavitate @ this pressure range.

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	01-32
PRELIM. CCN NO.	PAGE _____ OF _____
CCN CONVERSION:	
CCN NO. CCN--	C-1

Project or DCP/MMP 1-3587-0ISM Calc No. DC-26385 SUPPL. C'

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/28/90	Ø	29 AUG 90						

Ppsig = System pressure based on (Qcurve/3) per steam generator

Psig = Ps/g + K<sub>sys</sub> \* Q<sup>2</sup>curve + Elev. loss

% Margin = % calculated based on the difference between the minimum flow rate requirements and Qcalc.

PS/G = 700 psia = 685 psig

% margins of 72% & 26% are used for pumps G10S and G10W respectively.

- AFW flow >215 GPM to 3 S/GS @ 875 psia

P = P<sub>s/g</sub> + Elev. loss + ΔP, ΔP from Table 8-5

P = 875 - 14.7 + ΔP + 8.5

P = 868.6 + ΔP

Qcurve	Ppsig		G10W	G10 + G10S *	Margin
	Max.	Min.			
150	893	886	310-323	393	44%-82%
250	937	917			
350	1003	963			
450	1091	1025			

\* Value is taken from G10 +G10S pump curve with the 5532 cavitating venturi curve.

Ppsig = System pressure based on (Qcurve/3) per steam generator

Psig = Ps/g + K<sub>sys</sub> \* Q<sup>2</sup>curve + Elev. loss

% Margin = % calculated based on the difference between the minimum flow rate requirements and Qcalc.

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	PAGE <u>21</u> OF <u>33</u>
PRELIM. CCN NO.	CCN CONVERSION:
	CCN NO. CCN-- <u>C-1</u>

Project or DCP/MMP 1-3587.0ISM Calc No. DC-2638 SUPPL. C

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/28/90	Ø	24 Nov. 90						

PS/G = 875 psia = 860 psig

% margins of 44% and 82% are used for pumps G10S + G10 and G10W respectively.

8.8 Case 4.8 Station Blackout

This case is similar to case 8.6, except that flows are adjusted for the steam generator pressure of 923 psia and determined by intersection of the new system curve with G10 pump curve. G10W flow rate is 295 gpm and G10 flow rate is 300 gpm with margins of 59% - 62% respectively.

8.9 Case 4.9 ATWS

This case is bound by the case 4.1 of this Supplement 'C'. The expected G10W flow rate is 255 with a 37% margin.

8.10 Case 4.10 - Turbine Trip, Loss of Load and Loss of Condenser Vacuum

This case is covered by case 4.6 in Section 8.6.

The G10W flow rate is 295 gpm with a margin of 59%. Pump G10S flow rate is 205 gpm with a 10% margin.

8.11 Case 4.11 Appendix 'R'

- Flow rate of >185 GPM to 3 S/Gs @ 923 psia is bound by Case 4.6 of this Supplement 'C'. The AFW flow rate expected from G10W is 295 gpm with a margin of 59%.
- Flow rate of >350 GPM to S/GS @ 15 psia.

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	C1-34
PRELIM. CCN NO.	PAGE OF
CCN CONVERSION:	
CCN NO. CCN-- C-1	

Project or DCP/MMP 1-3587.0ISM Calc No. DC-2836 Suppl. 'C'

Subject AFW FLOW VERIFICATION

Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/20/90	⊙	29 AUG 90	△					
△					△					

- Flow rate of >350 GPM to S/GS @ 15 psia.

Steam generators are used as once through heat exchangers in the Appendix 'R' analysis. For this scenario the required AFW is 350 GPM. (G10W powered from DSS diesel Ref. 5).

W new analysis requires a minimum of 350 GPM to achieve a cold shutdown at the steam generator pressures of 15 psia (Ref. 11).

G10W pump curve intersects the 5532 cavitation curve at the pump discharge pressure of 870 psig and flow rate of 367 gpm. The margin associated with this flow rate is < 1%.

With the AFW venturi bypass valves open this margin will be increased from < 1% to 8.6 %. (See Fig 7 for the intersection of the 5532 cavitating venturi and the G10W pump curve without venturi, @ AFW flow rate of 380 GPM)

- 8.12 Case 4.12 waterhammer (G10 + G10S + G10W) to 3 steam generators (G10W partial flow of <57 GPM).

This case is identified as a case number 1 in calc, DC-2836 Supplement 'B' (Ref. 1).

By definition (Ref. 1) AFW venturiers were designed to deliver flows not to exceed 140 + 0/-5 GPM per steam generator. However, pumps G10 + G10S are expected to cavitate @ 402 gpm Max. which would be below 420 gpm Max.

- 8.13 Case 4.13 Pump Runout

This case is identified as a case number 6 in calc. DC-2836 Supplement 'B' Figure 2-1. (Ref. 1)

The expected AFW pump G10S cavitating flow rate is 315 GPM for the 5532 venturi and 321 gpm for the 5531 venturi.

- 8.14 Cases 4.14 & 4.15 Steamline Break - Core Response and Steamline & Break - Inside Containment.

NES&L DEPARTMENT  
**CALCULATION SHEET**

ICCN NO./	PAGE <u>C1-35</u> OF <u>35</u>
PRELIM. CCN NO.	CCN CONVERSION:
	CCN NO. CCN-- <u>C-1</u>

Project or DCP/MMP 1-3587.01SM Calc No. DC-2638 SUPPL. C

Subject AFW FLOW VERIFICATION


Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SIC	8/28/90	0	29/10/90						

The AFW flow requirements for steamline break core response are bound by those assumed in the feedline break events as discussed in the PEP 1-3587.01SM Safety Evaluation (Ref. 14).

Steamline break analysis assumes an AFW flow rate of 500 GPM initiated at time zero to maximize of secondary side inventory that is released. The AFW flow rate is then reduced at 10 minutes to 250 GPM by operator action. Therefore, a reduction in AFW flow rate due to resized venturies are bound by the LONF event. The 500 GPM limit is bound by the 450 GPM water hammer limit (Ref. 1).


PRESSURE AT VENTURI INLET AND CAVITATION LIMIT CURVES.



Q (GPM) TOTAL FLOW  
FIG. 1

Handwritten notes and scribbles at the bottom right of the page, including the number '20' and some illegible characters.

CASE 8-1 - LOSS OF NORMAL FEED TO VENTURI PRESS. OF 1030 PSIA




Q (GPM) TOTAL FLOW  
FIG. 2

Q1-37  
C-1  
5/28/21  
C/A  
2/2/21



CASE 8-2 - MAINFEED LINE BREAK UPSTREAM CHECK VALVE @ 516 PRESS. OF 103 PSI




Q (GPM) TOTAL FLOW  
FIG. 3

270

390

5/1/52  
S.E.  
S.E. 8/28/51  
C-1  
C-1-38

CASE B.5- STEAM TUBE RUPTURE @ SIG PRESS. 250-750 PSIA




Q (GPM) TOTAL FLOW  
FIG. 4

C1-39  
C-1  
SL 9/21  
A  
2-1-1

DC-28  
50 APR 1960  
20 Squares to the Inch

CASE 8.6 - NORMAL PLANT COOL DOWN @ PILESS - 125 - 923 PSI A




Q (GPM) TOTAL FLOW  
FIG. 5

C-40  
SR 8/28/9  
A.D.  
25.12



FIG. 6  
Q (GPM) TOTAL FLOW



CASE 8.7. STEAMLINE BLEAK OUTSIDE MAINTENANCE @ 515 GPM PRESS. 700-875

PUMP DISCHARGE PRESS. @ VENTURI INLET (PSIG)

SYSTEM  
 500 PSIA  
 700 PSIA  
 875 PSIA

20 Squares to the Inch  
 C1-41  
 03/02/85  
 251

DC-2836 SUPPLY C-1


PUMP DISCH. PRESS.

0  
100  
200  
300  
400  
500  
600  
700  
800  
900  
1000  
1100  
1200

Q (GPM) TOTAL  
FIG. 7.

0  
100  
200  
300  
400  
500

WC-2836 SUPPLY C



5531  
5532  
C1-42  
SK  
8/28/90  
CK  
29A3545

CASE 8-11 APDIX R

# CALCULATION SHEET

ICCN NO./

PRELIM. CCN NO.

PAGE C143 OF     

CCN CONVERSION:

CCN NO. CCN-- C-1

Project or DCP/MMP 1-3587.0ISM Calc No. DC-2836 Suppl. c'

Subject AFW Flow REQUIREMENT VERIFICATION

Sheet No.     

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/28/90	↖	29 AUG 90	△					
△					△					

ATTACHMENT A

SUPPLEMENT A DC-2036 REV. 30 KRP  
 BY K. PEABODY DATE 3/5/60  
 CHK BY LLV DATE 3/22/96  
 SHI 24-45 OF 60

EFFICIENCY PERCENT

BRAKE HP


GALLONS PER MINUTE

TOTAL HEAD IN FEET

AUXILIARY FEEDWATER PUMP,  
 TURBINE DRIVEN, PERFORMANCE CURVES

SP. GR. = 1.00 @ 1400 RPM

AMP. SP. GR. = 1.00



G-10

16-22  
 CI-44  
 5282190  
 25 AUG 60

CONTRACTOR BECHTEL  
 CUSTOMER SO. CAL. EDISON


ITEM NO. P.O. 6-109887  
 IMPELLER PATTERN M-6149 M-6150/S1  
 MAXIMUM DIAMETER 8  
 RATED DIAMETER 8  
 MINIMUM DIAMETER 7

TEST PERFORMANCE CURVE NO. 42768-SP

SUPPLEMENT A DC-2036 Rev. 30 KLP  
 BY K. PFAHL DATE 3/22/90  
 CHK BY H.A. Giff DATE 3/22/90  
 SHT R4-16 OF 60

SIZE 2" TYPE RF JIC STAGES 10  
 R.P.M. 3570 DATE 5/13/86  
 PUMP NUMBER 42768-SF

**G10S PUMP CURVE**  
 ATTACHMENT 2  
 PERFORMANCE ALSO APPLIES TO PUMP NUMBER NH 43212



61512/90 CK 2/10/90



OXFORD PUMPS

OPRESSOR

HUNTINGTON PARK, CA

'1A

516

CONTRACTOR \_\_\_\_\_

SUPPLEMENT A DC-2836 Rev. 10 KLP  
TEST PERFORMANCE CURVE NO. \_\_\_\_\_

CUSTOMER WESTINGHOUSE NES

By K. PFAHL DATE 3/15/90

ITEM NO. \_\_\_\_\_ P.O. MN 4747-D

CHK BY A. Uff DATE 3/22/90

IMPELLER PATTERN H-7844 H-7881

SIZE 3" TYPE HF STAGES 11

MAXIMUM DIAMETER 8-9/16" 8-9/16"

R.P.M. 3585 DATE 7/25/85 1/21/86

RATED DIAMETER 8" 8"


SHT RA 47 OF 60

PUMP NUMBER 51658-01

MINIMUM DIAMETER 7-9/16" 7-9/16"

G10W PUMP CURVE  
ATTACHMENT 3

PERFORMANCE ALSO APPLIES TO PUMP  
NUMBER MN 43206



C1-416  
SK 5/13/85  
29 Nov 90

# INSERVICE PUMP TEST RECORD

SUPPLEMENT A DC-2836 REV. 30 KLP

By K. PFAHL DATE 3/15/90 CDM Encode No. \_\_\_\_\_

Test Procedure Used \_\_\_\_\_

ATCH. 3

CHK BY RA DATE 3/22/90

Test Date \_\_\_\_\_

Unit \_\_\_\_\_

SHT RA-48 OF 60

Record No. \_\_\_\_\_

1 Plant Tag No. <u>2-252-1-10</u>	2 Pump Name (System) <u>AMV Feedwater</u>
3 Tested By <u>J. K...</u>	4 Reason for Test <u>COLD SHUT DOWN TEST (18 Months)</u>
5 Plant Power <u>M-1 (&lt;25%)</u>	6 Reference IST Record No./Date <u>6-10-5-87</u>
7 Test Frequency <u>COLD SHUT DOWN</u>	8 Date Last Tested <u>2-14-89</u>
	9 Run Time Before Test <u>&gt; 25 MIN.</u>

HYDRAULIC DATA	INSTRUMENT ID (ENTER "C" FOR CALC'D VALUE)	CALIBRATION DUE DATE	UNITS	SET REF.	REFERENCE VALUE	TEST VALUE	ACCEPTABLE RANGE
10 Prestart Suction Pressure (Pa)	<u>M2-5353</u>	<u>8/16/89</u>	<u>PSI</u>		<u>15.2</u>	<u>15.2</u>	<u>&gt; 0</u>
11 Speed (N)	<u>M2-5639</u>	<u>9/27/89</u>	<u>PPM</u>		<u>4374</u>	<u>4402</u>	<u>4400 ± 10</u>
12 Discharge Pressure (Po)	<u>M2-4349</u>	<u>9/18/89</u>	<u>PSI</u>		<u>1120</u>	<u>1080</u>	<u>NA</u>
13 Running Suction Pressure (Pi)	<u>M2-5357</u>	<u>8/16/89</u>	<u>PSI</u>		<u>13.5</u>	<u>12.1</u>	<u>&gt; 0</u>
14 Differential Pressure (Po - Pi)	<u>C</u>	<u>NA</u>	<u>PSI</u>		<u>1106.5</u>	<u>1167.9</u>	<u>1100 to 1200</u>
15 Motor Current (A)	<u>NA</u>	<u>NA</u>	<u>NA</u>		<u>NA</u>	<u>NA</u>	<u>NA</u>
16 Flow Rate (Q)	<u>C</u>	<u>C</u>	<u>GPM</u>		<u>300</u>	<u>296.4</u>	<u>300 ± 10</u>

**Calculations**

$FTL 3453$        $FTL 3455$        $FTL 3454$        $\Delta P = 1080 - 12.1 = 1067.9$   
 (M2 5353 / 11-3-89)    (M2 5351 / 11-3-89)    (M2 5354 / 11-3-89)    *Throttled Flow*  
 $Y = 30.57 \text{ W/C}$        $35.1 \text{ W}$        $32.1 \text{ W}$   
 $Q = 95.7 \text{ gpm}$        $102.6 \text{ gpm}$        $98.1 \text{ gpm}$   
 $Q_{test} = 296.4 \text{ gpm}$       where  $Q = 300 \sqrt{\frac{Y}{300 \text{ W/C}}}$       + See Test procedure 301-xxvii


MECHANICAL DATA		Vibration Instrument ID <u>T29620/3620A</u>			Calibration Due Date <u>11-11-89</u>			
Vibration Axis		Displacement (Mils)			Velocity (IPS)			
		REFERENCE VALUE	TEST VALUE	ACCEPTABLE RANGE	REFERENCE VALUE	TEST VALUE	ACCEPTABLE RANGE	
17 Point No. 1	Horiz. (0 Deg.)	<u>0.38</u>	<u>.4</u>	<u>0-1</u>	<u>0.16</u>	<u>.1</u>	<u>NA</u>	
	18 Point No. 1	Vert. (90 Deg.)	<u>0.22</u>	<u>.2</u>	<u>0-1</u>	<u>0.10</u>	<u>.1</u>	
		19 Point No. 1	Axial	<u>0.32</u>	<u>.38</u>	<u>0-1</u>	<u>0.23</u>	<u>.2</u>
20 Point No. 2	Horiz. (0 Deg.)	<u>0.22</u>	<u>.2</u>	<u>0-1</u>	<u>0.09</u>	<u>.1</u>		
	21 Point No. 2	Vert. (90 Deg.)	<u>0.12</u>	<u>.19</u>	<u>0-1</u>	<u>0.13</u>	<u>.15</u>	
		22 Point No. 2	Axial	<u>0.32</u>	<u>.28</u>	<u>0-1</u>	<u>0.10</u>	<u>.14</u>

23 Lubrication Level/Pressure: Bulls Eye  Chicken Feeder  Other Sightglass/Wick  Sat  UnSat

24 BEARING TEMPERATURES		Point No. 1			Point No. 2		
Instrument ID	Cal. Due Date	TIME	TEMP	% CHANGE	TIME	TEMP	% CHANGE
Date Last Taken	<u>Test test</u>	1	<u>0</u>	<u>91.5</u>		<u>0</u>	<u>124.2</u>
Reference Data Record No.	<u>Test test</u>	2	<u>10</u>	<u>91.7</u>	<u>.2</u>	<u>10</u>	<u>124.7</u>
Reference Temperature	<u>21 91.7°F</u> <u>22 125.1°F</u>	3	<u>20</u>	<u>91.9</u>	<u>.4</u>	<u>20</u>	<u>125.5</u>
Max. Allowable Temperature	<u>&lt; 160°F</u>	4	<u>30</u>	<u>92.0</u>	<u>.5</u>	<u>30</u>	<u>126.1</u>

25 REQUIRED ACTION <u>None</u>	26 NCR NO AND/OR M O NO <u>None</u>
27 ENGINEER PERFORMING OPERABILITY ANALYSIS <u>None</u>	28 SUPERVISING ENGINEER OR DESIGNEE <u>None</u>

# AUXILIARY FEEDWATER SYSTEM



01-28  
 5/23/2015  
 2341000

AS1008500  
0293M.AUT

**FIGURE 1 - Ref. 8**  
**SUPPL. A DC-2836 REV. 3/0**  
 JLP

NOTE 1: TYPICAL OF FOUR LOW FLOW SWITCHES (FSL-2306, 2307, 2308, 2309)

FIGURE 1  
SD-S01-620-01-5

MADE BY K. PEHLER DATE 3/15/90

01-4954818/15  
3/8/85

DTE BASED ON DESIGN PUMP CURVES




FIGURE 2




FIGURE 3

TOTAL PUMP FLOW

Q (GPM)

PUMP DISCHARGE PRESSURE

P (PSIG)

NOTE: BASED ON DESIGN PUMP CURVES

CLM/BJS 05-10

418

CHRYSLER  
4/18/75  
01-10

NOTE: BASED ON DESIGN PUMP CURVES




FIGURE 4

IMPLEMENT A DC-2836 PUMP NAME B72 PUMP RATE 3.15/GD




FIGURE 5

NOTE: BASED ON DESIGN PUMP CURVES  
 2-10-52  
 5/8" 25-10  
 2-10-52




FIGURE 6

SERVO PUMP BASED ON DESIGN PUMP CURVES  
 C1-53 SE (REV 9)  
 3/29/63







FIGURE 7

Handwritten notes on the left margin: 'S/G P = 1025 PSIG' and 'BASED ON DESIGN PUMP CURVES'.

10512  
3/9/75 17  
NOTE BASED ON DESIGN PUMP CURVES



SUPPLEMENT A DC-2836 REV. 3/0

MADE BY K. PEACH DATE 3/15/70




FIGURE 10

29 AUG 93  
C-56 S/G/12/15

rip




FIGURE 11

C1-57  
5/28/75  
D  
29A0090




FIGURE 9

NOTE: BASED ON DESIGN PUMP CURVES

29 JAN 90  
21.58  
3/17/90  
SCN/SD

NES&L DEPARTMENT  
**CALCULATION SHEET**

CCN NO./	CI-59
PRELIM. CCN NO.	PAGE _____ OF _____
CCN CONVERSION:	CCN NO. CCN-- C-1

Project or DCP/MMP 1-3587.015M Calc No. DC-2836 Suppl. c'

Subject AFW Flow REQUIREMENT VERIFICATION Sheet No. \_\_\_\_\_

REV	ORIGINATOR	DATE	IRE	DATE	REV	ORIGINATOR	DATE	IRE	DATE	REV. INDICATOR
0	SK	8/28/90	CF	29/11/90						

ATTACHMENT B

CI-59 SK  
 8/28/90

WYLE

Procedure No. 4703

Page No. 13

# DATA SHEET

CUSTOMER PERMUTIT  
Test Title: \_\_\_\_\_

Specimen VENTURI

Lab No. \_\_\_\_\_  
S/N: 5530  
Date: 8/10/90

Part No. \_\_\_\_\_

RUN NO.	Q (GPM)	TI (DEG. F)	P1 (PSI)	P2 (PSIA)	P3 (PSI)	P1-P2 (PSID)	P1-P3 (PSID)			
	136.3	84	1155.4	1.23	923.5	1168.5	231.9			
	136.3	84	1158.8	1.68	772.6	1171.4	386.2	Q - FLOWRATE		
	136.8	84	1162.5	.74	688.2	1176.1	474.3	TI - INLET TEMP		
	136.8	83	1162.7	.67	573.8	1176.3	588.9	P1 - INLET PRESSURE		
	127.7	84	1163.4	372.7	1038.8	805.0	401.6	P2 - THROAT PRESSURE		
	84.2	89	1152.7	827.0	1097.1	340.0	812.6	P3 - OUTLET PRESSURE		
	61.4	88	1153.7	986.7	1121.5	181.3	970.2			
	55.0	88	1160.8	1030.1	1133.5	145.0	1018.5			
	36.4	88	1158.3	1111.4	1142.8	61.2	156.6			
	106.8	88	1150.8	604.3	1063.9	526.8	537.1			
	126.8	83	995.7	.81	718.0	1009.2	271.7			
	120.8	83	901.9	.83	511.5	915.4	390.4			
	112.0	83	775.8	.84	450.6	789.3	325.2			

CI-60  
8/8/90  
SK @ 2016831700

DATA SHEET

CUSTOMER  
Test Title:

PERMIT

Specimen VENTURE 1

Part No. \_\_\_\_\_

Job No. \_\_\_\_\_  
S/N 11-9531  
Date 8/10/90

RUN NO.	Q (GPM)	TI (DEG. F)	P1 (PSI)	P2 (PSIA)	P3 (PSI)	P1-P2 (PSID)	P1-P3 (PSID)			
	139.7	86	1162.7	1.28	<del>888.1</del>	1175.7	274.6			
	139.9	80	1166.1	.76	764.1	1179.6	402.0	Q - FLOWRATE		
	139.9	83	1166.1	.73	625.2	1179.7	540.9	T1 - INLET TEMP		
	140.3	85	1169.8	.76	533.9	1183.3	635.9	P1 - INLET PRESSURE		
	121.1	86	1166.1	627.0	104.6	553.4	<del>1183.3</del>	P2 - THROAT PRESSURE		
	101.5	83	1152.7	784.3	1050.6	382.7	<del>1183.3</del>	P3 - OUTLET PRESSURE		
	82.3	83	1155.2	921.0	1087.9	248.5	<del>1183.3</del>			
	62.4	83	1158.8	1029.6	1119.4	143.5	<del>1183.3</del>			
	54.4	83	1159.0	1065.5	1129.1	107.8	<del>1183.3</del>			
	36.1	83	1161.3	1129.5	1146.9	46.1	<del>1183.3</del>			
	129.6	83	999.1	1.15	752.7	1012.3	246.4			
	123.6	83	904.9	1.10	662.6	918.1	242.3			
	114.7	83	775.5	1.16	502.2	788.6	275.3			

CI-61  
SIC 8/10/90  
CIC 2510090



# DATA SHEET

CUSTOMER PERMUTIT  
 Test No: \_\_\_\_\_

Specimen VENTURI

Part No. \_\_\_\_\_

Job No. \_\_\_\_\_  
 S/N 5532  
 Date 8/10/90

RUN NO.	Q (GPM)	TI (DEG. F)	P1 (PSIG)	P2 (PSIA)	P3 (PSIG)	P1-P2 (PSID)	P1-P3 (PSID)			
	136.5	83	1166.1	2.2	926.5	1178.2	239.6			
	136.1	86	1164.9	1.10	749.0	1178.1	415.9	Q - FLOWRATE		
	136.1	86	1164.9	1.10	659.5	1178.1	510.4	TI - INLET TEMP		
	136.1	86	1164.9	1.0	538.5	1178.2	626.4	P1 - INLET PRESSURE		
	136.1	87	1164.9	.87	403.2	1178.3	761.6	P2 - THROAT PRESSURE		
	136.1	87	1164.9	.83	246.1	1178.4	918.8	P3 - OUTLET PRESSURE		
	127.3	88	1168.3	426.3	1036.9	756.3	<del>1178.4</del>			
	105.1	81	1165.4	673.9	1091.8	505.8	<del>756.3</del>			
	81.7	81	1166.6	860.9	1119.6	320.0	<del>470</del>			
	62.9	83	1162.5	998.4	1133.5	178.4	<del>320.0</del>			
	54.5	87	1166.1	<del>1124.6</del>	1144.6	131.5	215			
	31.6	87	1168.6	<del>1124.6</del>	1161.1	39.7	<del>1178.4</del>			
	126.6	83	999.7	2.12	662.4	1011.9	327.3			
	120.4	83	903.7	1.81	561.0	916.2	312.7			
	112.2	83	777.9	1.23	427.5	791.0	350.4			

C1-62  
 SK 8/10/90  
 2018831700

# DATA SHEET

CUSTOMER PERMUTIT  
 Test Title: \_\_\_\_\_

Specimen \_\_\_\_\_  
 \_\_\_\_\_  
 Part No. \_\_\_\_\_

Job No. \_\_\_\_\_  
 S/N S/N: N-5530  
 Date 8/15/90

PT. NO.	Q (GPM)	T1 (DEG. F)	P1 (PSIG)	P2 (PSIA)	P3 (PSIG)	P1-P2 (PSID)	P1-P3 (PSID)			
1.	135.6	77	1140.5	.89	822.2	1153.9	318.3	Q - FLOWRATE		
2.	106.7	81	696.7	.78	517.8	710.2	178.9	T1 - INLET TEMP		
								P1 - INLET PRESSURE		
								P2 - THROAT PRESSURE		
								P3 - OUTLET PRESSURE		

C1-63  
 S/N: 1/28/90  
 EE 8/20/90

**DATA SHEET**

CUSTOMER PERMUTIT  
 Test Title: \_\_\_\_\_

Specimen \_\_\_\_\_  
 \_\_\_\_\_  
 Part No. \_\_\_\_\_

Job No. \_\_\_\_\_  
 S/N N-5532  
 Date 8/15/90

PT. NO.	Q (GPM)	T1 (DEG. F)	P1 (PSIG)	P2 (PSIA)	P3 (PSIG)	P1-P2 (PSID)	P1-P3 (PSID)			
1.	129.9	80	1055.1	.78	247.5	1068.6	807.6			Q - FLOWRATE
2.	106.7	80	699.8	.69	304.7	713.4	395.1			T1 - INLET TEMP
										P1 - INLET PRESSURE
										P2 - THROAT PRESSURE
										P3 - OUTLET PRESSURE

C1-65  
 SKB 8/28/90

**DATA SHEET**

CUSTOMER PERMUTIT  
Test Title: \_\_\_\_\_

Specimen \_\_\_\_\_

Job No. \_\_\_\_\_

S/N N-5531

Part No. \_\_\_\_\_

Date 8/15/90

PT. NO.	Q (GPM)	T1 (DEG. F)	P1 (PSIG)	P2 (PSIA)	P3 (PSIG)	P1-P2 (PSID)	P1-P3 (PSID)			
			<del>698.6</del>							
1.	109.1	79	1003.8	.64	4885	712.3	210.1	Q - FLOWRATE		
2.	130.0	79	1003.8	.74	516.1	1017.4	487.7	T1 - INLET TEMP		
								P1 - INLET PRESSURE		
								P2 - THROAT PRESSURE		
								P3 - OUTLET PRESSURE		



*CI-64*  
*SK 8/15/90*

ENCLOSURE 2

PERMUTIT  
CAVITATING VENTURI  
OUTLINE DRAWING

CUSTOMER TAG NUMBER	PERM SERIAL NO	PIPE SIZE	BETA RATIO	DESIGN		OPERATING		DESIGN FLOW RATE (CAVITATING MODE)	MATERIAL	THROAT DIAMETER (")
				PRESSURE	TEMP	PRESSURE	TEMP			
FE-3066	N-5530	3" SCH 80	.1262	1330 PSIG	200 °F	1160 PSIG	60 °F	140 GPM @ 60 °F	WATER	0.366"
FE-3076	N-5531	3" SCH 80	.1262	1330 PSIG	200 °F	1160 PSIG	60 °F	140 GPM @ 60 °F	WATER	0.366"
FE-3077	N-5532	3" SCH 80	.1262	1330 PSIG	200 °F	1160 PSIG	60 °F	140 GPM @ 60 °F	WATER	0.366"

BILL OF MATERIAL			
ITEM	QTY	DESCRIPTION	MATERIAL
1	1	ELEMENT - BODY	ASTH A-182, F304 S.S.
2	6	1/2" - 6000# THREADEDLETS	ASTH A-182, F304 S.S.
3	2	3" - 600# RFWN FLANGE	ASTH A-105, C.S.
4	1	NAMEPLATE	ASTH A-240, 300 SERIES S.S.
5	6	1/2" PIPE PLUGS	ASTH A-182, F304 S.S.
6	4	DRIVE PINS	300 SERIES S.S.



The revised Vendor Document incorporates changes associated with a Change Change Package (CCP) # 1-3587-0151 M Rev A

This Vendor Document revision does not reflect any approved sheet modification and is not associated with a CCP or PCR.

Approved by: *[Signature]* Date: 8/25/90

1 APPROVED-SUBMIT ORIGINAL FOR SGE SIGNATURE

2 APPROVED

3 APPROVED EXCEPT AS NOTED-MAKE CHANGES AND RESUBMIT MFG. MAY PROCEED

4 NOT APPROVED, CORRECT AND RESUBMIT FOR REVIEW

5 "INFORMATION ONLY" DO NOT RETURN TO SUPPLIER

SOUTHERN CALIFORNIA EDISON CO

DRAWINGS ARE REVIEWED AND APPROVED FOR ARRANGEMENTS AND CONFORMANCE TO SPECIFICATION ONLY. APPROVAL DOES NOT RELIEVE THE SUBMITTER FROM THE RESPONSIBILITY OF ADEQUACY AND SUITABILITY OF DESIGN, MATERIALS AND/OR EQUIPMENT REPRESENTED.

DATE: 8-20-90  
C.D.M.

NOTES:

- GOVERNING CODE: ANSI/ASA B31.1 1989 EDITION.
- ESTIMATED WEIGHT - 130 LBS.
- HYDROTEST PRESSURE - 1995 PSIG. (1.5 X DESIGN PRESSURE).
- \*\* - INDICATES MATERIAL IDENTIFICATION MARK (APPROXIMATE LOCATION).
- TAP SET NUMBERS ON BOC: ADJACENT TO EACH TAP SET. USE LOW STRESS INTERRUPTED DOT DIE STAMP. TAP SET ORIENTATION IS IN HORIZONTAL PLANE WITH TAP SET #1 @ 90°, #2 @ 270°. EACH 'TAP SET' CONSISTS OF THREE (3) TAPS, THE UPSTREAM, THE THROAT AND THE RECOVERY TAP.
- PIPE PLUGS (ITEM 5) WILL BE SCREWED HAND TIGHT IN THE THREADED TAP SOCKET FOR SHIPMENT. THESE SOCKETS WILL THEN BE COVERED WITH TAPE PRIOR TO FINAL PACKAGING.
- THE TERM 'REFERENCE' IMPLIES 'FOR INFORMATION ONLY'.
- \*\* - THE THROAT DIAMETER AS NOTED IS FOR REFERENCE ONLY. THE AS BUILT/CALIBRATED DIMENSION WILL BE RECORDED LATER.
- THE FOLLOWING DESIGN CONDITIONS ARE ALSO APPLICABLE IN ADDITION TO THE DESIGN FLOW RATE (CAVITATING MODE) NOTED IN THE TABLE ON THIS DRAWING.

CASE	INLET PRESSURE (PSIG)	Δ P (PSID)	FLOWRATE (GPM)	TEMP (°F)	CAVITATING
1	1160	N/A	140, +0, -5	60	YES
2	775	N/A	100, +40, -0	60	YES
3	N/A	< 35	55	60	NO
4	N/A	< 65	62.5	60	NO

1810-AA319-D 0018-1

DO NOT SCALE THIS DRAWING - USE DIMENSIONS ONLY

THIS PRINT AND THE IDEAS WHICH IT CONTAINS ARE THE EXCLUSIVE PROPERTY OF THE PERMUTIT COMPANY, INC. THIS DRAWING IS TO BE USED ONLY IN ACCORDANCE WITH THE PROPOSAL, JOB, OR CONTRACT FOR WHICH IT WAS PROVIDED. IF THE PROPOSAL IS NOT ACCEPTED, IT IS THE CUSTOMER'S RESPONSIBILITY TO RETURN THIS PRINT TO THE PERMUTIT COMPANY, INC. THE USE OR DISTRIBUTION OF THIS PRINT WITHOUT THE WRITTEN APPROVAL OF THE PERMUTIT COMPANY, INC. WILL BE CONSIDERED TO BE A VIOLATION OF IT'S RIGHTS.

REV	BY	DATE	REVISIONS	REV	BY	DATE	REVISIONS
1	JVP	5-23-90	ADDED NOTE # 1, NCS 5-23-90, LCP 5-23-90.				
2	JVP	5-29-90	REVISED PLAN VIEW, NCS 5-30-90, LCP 6-1-90.				
3	JVP	6-6-90	RESTORED VENTURI BODY (ITEM 1) TO ONE-PIECE DESIGN, REVISED PLAN VIEW, NCS 6/6/90, LCP 6/6/90.				

SOUTHERN CALIFORNIA EDISON  
SAN ONOFRE  
NUCLEAR GENERATING STATION  
UNIT #1

S.C.E. P.O. # 8P030009

OUTLINE DRAWING  
3" CAVITATING VENTURI  
AUX. FEEDWATER SYSTEM

PERMUTIT JOB NO. A177057457

**PERMUTIT**  
A GE COMPANY

DRAWING NO. 556-34380  
REV. 3