

RS-1-62

# Calculation Title Page

DKH P. 79 of 154  
7/25/90 86 167


Project SONGS-1 Job Order No. 3587 Discipline MECH.  
 Subject AFW FLOW VENTURE SIZING  
 Calculation No. SUPPL. B DC-2836 QA Class SR No. Pages 62+8a <sup>4A, 6A, 8, 6</sup>  
 Responsible Engineer R. O. [Signature] Date 3/23/90  
 Independent Review Engineer [Signature] Date 5/9/90

### ORIGINAL ISSUE

	NAME	DATE	SIGNATURE
Group Leader	<u>I. KATTER</u>		
Discipline Sup. Engineer	<u>M. WHARTON</u>		
Professional Engineer (if required)			

### RECORD OF REVISIONS

NO.	REASON FOR REVISION	DATE	RESP. ENGR.	IRE	GL	DSE	PE



PROFESSIONAL ENGINEER'S SEAL

901022  
PDR A  
900730  
05000206  
PNU

ENGINEERING DEPARTMENT  
**CALCULATION SHEET**

P 80-159  
 SUPPL B 87 167

SUBJECT: AFW FLOW VENTURI SIZING DESIGN CALCULATION NO. DC-2836 REVISION 5

J.O. NO. \_\_\_\_\_ MADE BY R. A. [Signature] DATE 3/22/90 CHK. BY \_\_\_\_\_ DATE \_\_\_\_\_

### TABLE OF CONTENTS

1.0	PURPOSE	R5-3
2.0	RESULTS	R5-4
3.0	ASSUMPTIONS	R5-7
4.0	METHODOLOGY	R5-8
5.0	DESIGN INPUT	R5-9
6.0	REFERENCES	R5-11
7.0	NOMENCLATURE	R5-13
8.0	CALCULATIONS	R5-15

### FIGURES AND ATTACHMENTS

FIGURE 1	CAVITATING FLOW LIMITS	R5 - 42
FIGURE 2	CAVITATING VENTURE FLOW LIMITS	R5 - 43
FIGURE 3	PUMP & SYS. CURVES, CASES 3, 4 & 5	R5 - 44
FIGURE 4	COMP. OF CASE 1 AND 2 FLOWS WITH LIMITS	R5 - 45
A	AFW P&ID	R5-46
B	-VENTURE DWG	R5-47
C	SYSTEM DESCRIPTION	R5-48
D	WESTINGHOUSE LETTER (REF 5)	R5-50
E	E-MAIL WESTINGHOUSE CALL. (REF 4)	R5-52
F	VENTURE TEST DATA	R5-54
G	DC-2836 CALCULATIONS	R5-57
H	GIG W PUMP CURVE	R5-60
I	DC-2836 SUPPL. A CALCULATIONS	R5-61

DWG. NO. R5-61

ENGINEERING DEPARTMENT  
CALCULATION SHEET

DK# 7/25/90  
SUPPL. B 88 167  
DC-2386 REVISION 0

SUBJECT: AFW FLOW VENTURI SIZING DESIGN CALCULATION NO. \_\_\_\_\_

J.O. NO. \_\_\_\_\_ MADE BY R. A. Luffe DATE 3/22/90 CHK. BY [Signature] DATE 5/9/90

1.0 PURPOSE

THE PURPOSES OF THIS CALCULATION ARE TO SIZE THE VENTURIS THAT LIMIT AUXILIARY FEEDWATER (AFW) TO THE STEAM GENERATORS AND DETERMINE MARGINS FOR THE REVISED AFW FLOW LIMITS AND VENTURI DESIGNS DUE TO THE CHANGED VENTURI SIZE AND FLOW REQUIREMENTS, THIS SUPPLEMENT SUPERCEDES FLOW RATES AND MARGINS CALCULATED IN PREVIOUS REVISIONS OF THIS CALCULATION.

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEETDKH  
7/25/90 P. 82 of 159  
89 167SUBJECT: AFW FLOW VENTURE SIZING DESIGN CALCULATION NO. DC-2886 SUPPL. B REVISION 0J.O. NO. \_\_\_\_\_ MADE BY R. A. Wiff DATE 3/22/90 CHK. BY 0 DATE 5/9/902.0 RESULTS

1. THE VENTURIS WILL MEET ALL AFW FLOW REQUIREMENTS. TABLE 2-1 COMPARES EXPECTED VENTURE FLOW RATES WITH FLOW RATE LIMITS AND PROVIDES MARGINS FOR EACH DESIGN CONDITION.
2. VENTURIS WILL HAVE THROAT DIAMETERS OF APPROXIMATELY 0.377 INCH. (SUPPLIER WILL DETERMINE EXACT DIAMETER.)
3. THE REQUIRED VENTURE PRESSURE DROPS AND PRESSURE DEPENDENT FLOW LIMITS ARE PROVIDED IN TABLE 2-2.
4. THE RECOMMENDED VENTURE SIZE IS 140 +0, -10 GPM AT 1160 PSIG INLET PRESSURE.
5. IT WILL NOT BE NECESSARY TO EQUALIZE FLOW AMONG THE STEAM GENERATORS NOR ISOLATE BLOWDOWN IF THE REVISED FLOW LIMITS FOR POSTULATED FEEDWATER LINE BREAK EVENTS ARE INCORPORATED.
6. DUE TO CHANGES IN VENTURE SIZE AND FLOW REQUIREMENTS, THE FLOW RATES AND MARGINS CALCULATED IN THIS REVISION SUPERCEDES THOSE OF PREVIOUS REVISIONS.

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET 4a OF 62 SHEETS

DICK P. 83 d 159  
7/25/90 90 167  
SUPPL. B  
DESIGN CALCULATION NO. DC-2836 REVISION 0

SUBJECT: AFW FLOW VENTURI SIZING

J.O. NO.

MADE BY

R. G. W.

DATE

5/10/90

CHK. BY

Q

DATE

10/11/90

7. THIS CALCULATION DOES NOT CHANGE TECHNICAL SPECIFICATIONS OR THE OPERATING LICENSE, BUT DOES CONSIDER PROPOSED REVISIONS TO AFW FLOW LIMITS THAT WILL BE IMPLEMENTED PRIOR TO INSTALLING NEW AFW FLOW VENTURIS, AS NOTED IN TABLE 2-1.  
*SURVEILLANCE PROCEDURES, Rev 5/10/90*
8. RESULTS FOR A 140 GPM FLOW VENTURI, BASED ON BEST ESTIMATES OF VENTURI PRESSURE LOSSES ARE PRESENTED ON FIGURE 2-1.
9. RESULTS FOR A 140 GPM FLOW VENTURI, BASED ON MAXIMUM ALLOWABLE VENTURI PRESSURE LOSSES ARE PRESENTED ON FIGURE 2-2.
10. CASE 5 CONDITIONS, BASED ON MAXIMUM ALLOWABLE PRESSURE LOSSES, ARE PRESENTED ON FIGURE 2-3.


DWG. NO.

Made By R. J. [Signature] Date 5-21-96

Ckd By \_\_\_\_\_ Date \_\_\_\_\_

DKH  
SUMM. 5712548  
Calc No. DC-2836 Rev. 9/16/96

Sh R5-6A of 62




TOTAL AFW FLOW (GPM)  
FIGURE 2-1  
SUMMARY PLOT BEST ESTIMATE  
LOSSES FOR FLOW VENTURIS

Made By R.A. W.P. Date 5-21-86

Ckd By \_\_\_\_\_ Date \_\_\_\_\_

Calc No. 06-2036 Rev. 1/67  
supp 3 7/25/86 85 of 159

Sh RS-68 of 62



ENGINEERING DEPARTMENT  
CALCULATION SHEET

7/25/90  
DKH P. 86 of 49  
93 167

SUBJECT: AFW FLOW VENTURE SIZINGDESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO. \_\_\_\_\_

MADE BY R. A. WDATE 3/29/90CHK. BY ADATE 5/9/90

TABLE 2-1

## VENTURE FLOW RATES + MARGINS

DESIGN CONDITION	FLOW LIMIT (GPM)	EXPECTED FLOW (GPM)	MARGIN	BOUNDING CASE
1. ANY PUMP TO ANY DEP. RESSURIZED. S.G.	< 150/SG	130-140 PER SG	7% TO 13%	① (G10+G10S)
2. G10W OR G10S TO 2 DEPRESS. S.G. WITH A FW LINE BREAK	> 87.5/SG (175 TOTAL)	206-212 TOTAL	18% TO 21%	② (G10S)
3. G10W OR (G10+G10S) TO 3 S.G. AT 1015 PSIG	> 61.7/SG (185 TOTAL)	260-265 TOTAL	41% TO 43%	③ (G10W)
4. G10 TO 3 S.G. AT 1015 PSIG	> 55/SG (165 TOTAL)	268-263 TOTAL	62% TO 59%	
5. G10W OR (G10+G10S) TO 2 SG AT 1015 PSIG WITH A FW LINE BREAK	> 50/SG (100 TOTAL)	146 TOTAL	46%	③ (G10W)
6. G10S	< 420 TOTAL	335-320 TOTAL	20% TO 24%	

① BOUNDING CASE IS (G10+G10S + PARTIAL G10W). ALL OTHER CASES PROVIDE LESS FLOW

② VALUES ARE FOR G10S. G10W PROVIDES MORE FLOW + MORE MARGIN

③ VALUES ARE FOR G10W. (G10+G10S) PROVIDES MORE FLOW + MORE MARGIN

④ MARGINS ARE BASED ON PROPOSED (REF. 4 AND 5) CHANGES TO FLOW REQUIREMENTS. CURRENTLY APPROVED FLOW LIMITS (REF. 3) AND THEIR ASSOCIATED MARGINS ARE:

CASE 2 : 250 GPM TOTAL (-18% TO -21%)

CASE 5 : 125 GPM TOTAL (17%)

DWG. NO.



ENGINEERING DEPARTMENT  
CALCULATION SHEET7/2/90  
DK# P. ST. GEN.  
SUPPL B 94 167  
DC-2836 REVISION 0SUBJECT: AFW FLOW VENTURI SIZINGDESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO. \_\_\_\_\_

MADE BY R. W. J.DATE 3/2/90CHK. BY DDATE 5/9/90

## TABLE 2-2

VENTURI FLOW DEPENDENT PRESSURES  
OR PRESSURE DROPDESIGN  
CONDITION1. (G10+G10S) TO ANY  
DEPRESS. ST. GEN.  
(INCLUDES PARTIAL  
G10 W FLOW)

140+0, -10 GPM AT 1160 PSIG

2. G10 W OR G10S TO 2  
DEPRESS. ST. GEN.  
WITH A FW BREAK

GREATER THAN 100 GPM AT 775 PSIG

3. G10 W OR (G10+G10S)  
TO 3 ST. GEN @ 1015 PSIG

LESS THAN 40 PSID LOSS AT 62 GPM

4. G10 TO 5 ST. GEN  
AT 1015 PSIG

BOUNDED BY CASE 3

5. G10 W OR (G10+G10S)  
TO 2 ST. GEN AT  
1015 PSIG WITH AFW BREAK

BOUNDED BY CASE 3


6. G10S

BOUNDED BY CASE 1

DWG. NO.

Made By P. J. [Signature] Date 5-21-96  
 Ckd By \_\_\_\_\_ Date \_\_\_\_\_

SUM. 3  
 Calc No. DC-2836 Rev. 6/5/167  
 Sh 25-6A of 62 7/25/90  
 DKH




TOTAL AFW FLOW (GPM)  
 FIGURE 2-1  
 SUMMARY PLOT BEST ESTIMATE  
 LOSSES FOR FLOW VENTURIS

Made By R.A. W Date 5-21-96

Ckd By \_\_\_\_\_ Date \_\_\_\_\_

SUPAC 13 P 89 Feb 199  
Calc No. 06-2036 Rev. 960 167  
Sh R5-68 of 62 DK4  
7/25/90



TOTAL AFW FLOW (GPM)  
FIGURE 2-2  
SUMMARY PLOT - MAXIMUM VENTURI  
PRESSURE LOSSES

ENGINEERING DEPARTMENT  
**CALCULATION SHEET**

SHEET 25-62 OF 62 SHEETS

7/25/90  
 DKH P. God 09  
 97 167

SUBJECT: AFW FLOW VENTURE SIZING

DESIGN CALCULATION NO. DC-2836 SUPPL. B REVISION 0

J.O. NO.

MADE BY R. C. Hoff

DATE 5-21-90

CHK. BY

DATE




FIGURE 2-3

CASE 5 CONDITIONS BASED  
 ON MAXIMUM VENTURI ΔP

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

DK4 PA 159  
7/25/90 98 167  
SUPPL. B DC 283 6 REVISION 0

SUBJECT: AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. \_\_\_\_\_

J.O. NO. \_\_\_\_\_ MADE BY P.A. Wiff

DATE 3/22/90 CHK. BY Ø

DATE 5/9/90

3.0 ASSUMPTIONS

1. AUXILIARY FEEDWATER TEMPERATURE IS 70°F
2. VENTURI RECOVERY FACTORS WILL BE THE SAME AS THOSE REPORTED DURING THE CALIBRATION TESTING OF THE EXISTING AFW VENTURIS
3. AFW FLOW REQUIREMENTS FOLLOWING POSTULATED FEEDWATER LINE BREAKS WILL BE REDUCED TO THE VALUES PROVIDED IN 5.1.2 AND 5.1.5.
4. THE EFFECTS OF FRICTION AND ELEVATION LOSSES ARE NEGLIGIBLE WHEN CALCULATING CAVITATING VENTURI FLOW, THESE EFFECTS WILL BE ACCOUNTED FOR WHEN CALCULATING NON-CAVITATING FLOW TO THE STEAM GENERATORS. (THE VALIDITY OF THIS ASSUMPTION WILL BE VERIFIED IN THE CALCULATION)
5. LOSSES AND FLOW COEFFICIENTS OF THE THREE VENTURIS AND THE THREE AFW LOOPS ARE EQUAL

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEETDKH P. 92/89  
7/25/90 99/167  
SUPPL. BSUBJECT AFW FLOW VENTURI SIZINGDESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO. \_\_\_\_\_

MADE BY R.O. HDATE 5/7/90CHK. BY DDATE 5/9/904.0 METHODOLOGY

4.1 DETERMINE THE CAVITATING FLOW COEFFICIENT FOR THE EXISTING VENTURI DESIGN, USING DATA FROM REFERENCE 6.

4.2 DETERMINE AN AVERAGE NON-CAVITATING PRESSURE LOSS COEFFICIENT FOR THE EXISTING VENTURIS, USE REFERENCE 1 TEST DATA.

4.3 RESIZE THE FLOW VENTURIS FOR MAXIMUM FLOW RATES OF 150, 145, 140, AND 135 GPM, BASED UPON THE PUMP CURVE FOR  $(G_{10} + G_{105} + G_{10W})$  TAKEN FROM REFERENCE 6. FOR EACH SIZE VENTURI, CALCULATE:

- CAVITATING FLOW COEFFICIENT (C),
- NON-CAVITATING PRESSURE LOSS COEFFICIENT (K<sub>V</sub>),
- AREA, AND DIAMETER OF BORE.

4.4 CALCULATE FLOW RATES FOR EACH OF THE DESIGN CONDITIONS OF 5.1 FOR EACH SIZE VENTURI.

4.4.1 FLOW RATES ARE BASED ON THE INTERSECTIONS OF THE BOUNDING PUMP CURVES FOR EACH CASE OF 5.1 AND EITHER THE CAVITATING FLOW CURVE OR THE SYSTEM

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEETDKLH  
7/25/90P. 93 of 109  
SUPP. B 95 167  
DESIGN CALCULATION NO. 022236 REVISION 0

SUBJECT: AFW FLOW VENTURI SIZING

J.O. NO.

MADE BY

R.A. H

DATE 5/7/90

CHK. BY

D

DATE

5/4/90

CURVES FOR EACH SIZE VENTURI

4.4.2 SYSTEM CURVES ARE DEVELOPED BY ADJUSTING THE FLOW COEFFICIENT OF THE EXISTING SYSTEM (REFERENCE 2) TO ACCOUNT FOR THE CHANGE IN THE VENTURI FLOW COEFFICIENT.

4.4.3 THE SYSTEM CURVES FOR CASE 5, WHICH PROVIDES FLOW TO A BREAK AND TWO PRESSURIZED STEAM GENERATORS, ACCOUNTS FOR BOTH THE EFFECTS OF MODIFIED KV AND C FOR EACH SIZE VENTURI.

4.4.4 DETERMINING MARGINS IN PRESSURE LOSS FOR EACH OF THE CASES.

4.5 DETERMINING MARGINS FOR EACH CASE BY COMPARING CALCULATED AND REQUIRED FLOWS FOR A VENTURI OF 140 GPM (+0), -10 GPM DESIGN. (130 GPM) VALUES ARE EXTRAPOLATED.

4.6 DETERMINING REQUIRED AND RECOMMENDED PRESSURE-FLOW AND PRESSURE LOSS-FLOW RELATIONS FOR THE RECOMMENDED VENTURI SIZE.

NOTE - FOR CONSERVATISM, MAXIMUM FLOW LIMITS WILL BE EVALUATED USING THE LARGER OF DESIGN OR ACTUAL PUMP CURVES. MINIMUM FLOW LIMITS WILL BE EVALUATED USING THE SMALLER OF DESIGN BASIS OR ACTUAL

PUMP CURVES.

DWG. NO.

5.0 DESIGN INPUT SHEET

Design Requirements  
 Design Input Change

PAGE 0599 OF 62

DESIGN CALCULATION  
 SUPPL. 13  
 DC 2836

DKH  
 7/25/90 P. 94 of 159  
 Job 167

SUBJECT <b>AFW FLOW VENTURI SIZING</b>		PROJECT <b>501</b>
QUALITY CLASS <b>SR</b>	SEISMIC CLASS <b>A</b>	SPECIFICATION REFERENCE

Design Input **5.1 THE VENTURIS MUST BE SIZED TO MEET THE FOLLOWING CRITERIA:**

**5.1.1 MAXIMUM FLOW PER UNPRESSURIZED STEAM GENERATOR WITH PUMPS G10 AND G10S OPERATING - 150 GPM (REF. 3, pg. 3)**

**5.1.2 MINIMUM FLOW TO TWO UNPRESSURIZED STEAM GENERATORS WITH AN FW LINE BREAK FROM EITHER PUMP G10 W OR G10S - 175 GPM (REF. 4)**

**5.1.3 MINIMUM FLOW TO THREE STEAM GENERATORS AT 1015 PSIG FROM EITHER G10 W PUMP OR G10 AND G10S PUMPS - 185 GPM (REF. 3, pg. 2)**

**5.1.4 MINIMUM FLOW TO THREE STEAM GENERATORS AT 1015 PSIG FROM G10 PUMP ALONE - 165 GPM (REF. 3, pg. 2)**

LOW 3/28/90  
 (AT 1015 PSIG)

**5.1.5 MINIMUM FLOW TO TWO STEAM GENERATORS WITH A FEEDLINE BREAK FROM PUMP G10 W OR PUMPS G10 AND G10S - 100 GPM (REF. 5, pg. 6)**

**5.1.6 MAXIMUM FLOW PUMP G10S - 420 GPM (REF. 3, pg. 3)**

RESPONSIBLE ENGINEER <i>R.A. [Signature]</i>	DATE 3/22/90	INDEPENDENT REVIEW ENGINEER <i>[Signature]</i>	DATE 5/9/90	GROUP LEADER	DATE
---	-----------------	---	----------------	--------------	------



DESIGN INPUT SHEET

Design Requirements  
 Design Input Change

PAGE OF  
RS-10 02

DR# 7/25/90 P. 95 of 49  
1020167  
DESIGN CALCULATION  
SUPPL 3  
DC2836-0

SUBJECT <b>AFW FLOW VENTURE SIZING</b>		PROJECT <b>501</b>
QUALITY CLASS <b>SR</b>	SEISMIC CLASS <b>A</b>	SPECIFICATION REFERENCE

Design Input

5.2 CONDITION 5.1.1 SHALL ALSO CONSIDER FLOW FROM PUMP G10W AT ITS LOW FLOW TRIP POINT.

5.3 G10W LOW FLOW SIGNAL TO START PUMPS G10 AND G10S IS 57 GPM (REF. 6, pg. R4.29)

5.4 THE THROAT DIAMETER OF THE EXISTING VENTURES IS 0.440, +0, -.005 IN. (REF. 7)

5.5 ALL PUMP CURVES ARE TAKEN FROM REFERENCE 6, WHICH MODIFIED PUMP CURVES IN REFERENCE 2, TO CONSIDER BOTH DESIGN AND ACTUAL PERFORMANCE AND THE EFFECTS OF TURBINE INLET PRESSURE CONTROL ON G10 PUMP PERFORMANCE.

Flow Rates

5.6 ALL MAXIMUMS SHOULD INCLUDE MARGIN (REF. 9)

RESPONSIBLE ENGINEER <b>R. A. [Signature]</b>	DATE <b>3/24/90</b>	INDEPENDENT REVIEW ENGINEER <b>[Signature]</b>	DATE <b>5/9/90</b>	GROUP LEADER	DATE
--	------------------------	---	-----------------------	--------------	------

ENGINEERING DEPARTMENT  
CALCULATION SHEETDK4  
7125190 P 910159  
104 167  
SUPPL. B  
DC-2836 REVISION 0

SUBJECT: AFW FLOW VENTURE SIZING

DESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO.

MADE BY

R. A. W. J.

DATE

3/22/90

CHK. BY

0

DATE

5/9/90

7. DRAWING 1810-AA 319-M007 (PERMUTIT NO. 556-34196 REV 0), PERMUTIT, PARAMUS N J
8. TECHNICAL PAPER No. 410, "FLOW OF FLUIDS THROUGH VALVES, FITTINGS, AND PIPE", CRANG CO., CHICAGO, IL.
9. DESIGN CRITERIA FOR AUXILIARY FEEDWATER SYSTEM MODIFICATIONS, M86315 REV. 7, SCE.

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET
 DWT P. 884-59  
 7/25/90  
 SUPPL. B  
 105/167

 SUBJECT: AFW FLOW VENTURI SIZING DESIGN CALCULATION NO. DC 2836 REVISION 0

 J.O. NO. \_\_\_\_\_ MADE BY R.A. W DATE 3/22/90 CHK. BY Ø DATE 5/9/90
7.0 NOMENCLATURE

- A - FLOW AREA
- AFW - AUXILIARY FEEDWATER
- C - FLOW COEFFICIENT FOR VENTURI WHEN  
CAVITATING ( $C \equiv Q^2 / \Delta P$ )
- D - DIAMETER
- °F - DEGREES FAHRENHEIT
- FW - FEEDWATER
- $g_c$  - NEWTON'S CONSTANT =  $32.2 (L^M / LBF) (FT / SEC^2)$
- GPM - GALLONS PER MINUTE
- IN - INCH
- K - PROPORTIONALITY CONSTANT FOR PRESSURE LOSS
- $K_{SYS}$  - SYSTEM PRESSURE LOSS COEFFICIENT ( $K \equiv \Delta P / Q^2$ )
- $K_V$  - PRESSURE LOSS COEFFICIENT FOR VENTURI  
WHEN NOT CAVITATING ( $K \equiv \Delta P / Q^2$ )
- P - STATIC PRESSURE
- $P_0$  - PUMP DISCHARGE PRESSURE
- $P_0$  - TOTAL PRESSURE
- PSI - POUNDS PER IN<sup>2</sup>
- PSID - POUNDS PER IN<sup>2</sup> PRESSURE DROP
- PSIG - POUNDS PER IN<sup>2</sup> GAUGE
- R - RECOVERY FACTOR
- SG - STEAM GENERATOR

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

DKH  
7/25/90 P. 99 of 59  
1060167

SUBJECT: AFW FLOW VENTURI SIZING DESIGN CALCULATION NO. DC-2836 SUPPL. B REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY R. Q. WJ DATE 3/22/90 CHK. BY R DATE 5/9/90

- $P_v$  - VAPOR PRESSURE
- $Q$  - VOLUMETRIC FLOW RATE
- $V$  - VELOCITY
- $\Delta P$  - PRESSURE DROP
- $\rho$  - DENSITY

150, 145, 140, 135 - VENTURI SIZES BASED ON  
 MAXIMUM DESIGN FLOW RATE OF VENTURI  
 SUBSCRIPTS

- T - TOTAL (SMALL THREE STEAM GENERATORS)
- 1, 2, 3 - ANY OF THREE INDIVIDUAL STEAM GENERATORS

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEETDKH  
7/25/90 P. 1001/139  
1070/167  
SUPPL. B  
DC-2836 REVISION 0

SUBJECT: AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. 0

J.O. NO. \_\_\_\_\_ MADE BY D. A. Hoff DATE 3/22/90 CHK. BY 0 DATE 5/9/90B.O CALCULATIONSB.1 EXISTING VENTURES

THE MAXIMUM FLOW RATE WILL OCCUR WITH PUMPS G10 AND G10S OPERATING AND PARTIAL FLOW COMING FROM PUMP G10W AT THE LOW FLOW PUMP G10 + G10S START SIGNAL LEVEL.

FIGURE 1 (FIGURE 10 OF REFERENCE 6), SHOWS THAT THE (G10 + G10S + G10W) PUMP CURVE INTERSECTS THE VENTURI CURVE AT 555 GPM AND 1090 PSIG. THUS, THE CURRENT VENTURIS LIMIT SG FLOW TO 555 GPM OR  $555/3 = 185$  GPM / STEAM GENERATOR.

FOR A CAVITATING VENTURI, FLOW IS LIMITED BY FLUID FLASHING.

$$\therefore \Delta P = P_{\text{INLET}} - \text{VAPOR PRESSURE} \quad (1)$$

$$\Delta P = \frac{\rho V^2}{2g_c} = \frac{\rho \left( \frac{Q^2}{A^2} \right)}{2g_c} \quad (2)$$

@ 70 °F VAPOR PRESSURE = 0.4 PSIA (REF. 8)

$$\Delta P = 1090 + 14.7 - 0.4 = 1104 \text{ PSID.}$$

$$\text{IF } \frac{\rho}{A^2 2g_c} \equiv C, \text{ THEN}$$

$$\Delta P = \frac{Q^2}{C} \quad (3)$$

DWG. NO. \_\_\_\_\_

ENGINEERING DEPARTMENT  
CALCULATION SHEETDkt  
7/25/90 P. total of 19  
108 V167SUBJECT: AFW FLOW VENTURI SIZING DESIGN CALCULATION NO. SUPPL-B REVISION 0  
DC-2836J.O. NO. \_\_\_\_\_ MADE BY R. A. [Signature] DATE 3-22-90 CHK. BY 0 DATE 5/9/90

$$\text{REARRANGING, } C = \frac{Q^2}{\Delta P} \quad (4)$$

FOR THE CURRENT VENTURI

$$C = 185^2 / 1104 = 30.99$$

THE THROAT DIAMETER OF THE EXISTING  
VENTURI = 0.440" (REF. 7)

∴ THE AREA OF THE EXISTING VENTURI

$$= \frac{\pi}{4} (.440/12)^2 = 1.056E-3 \text{ ft}^2$$

ENGINEERING DEPARTMENT  
CALCULATION SHEETDKH  
7/25/90  
1090167

SUBJECT: AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. SUPPL. B DC-2836 REVISION 0

J.O. NO.

MADE BY

L.A. WJ

DATE 3/22/90

CHK. BY

D

DATE 5/9/90

B.2 NON-CAVITATING VENTURI PRESSURE LOSSES

WHEN FLOW ENTERS A VENTURI, ITS STATIC PRESSURE DROPS, AS VELOCITY INCREASES, REACHING A MINIMUM AT THE THROAT. IF CAVITATION DOES NOT OCCUR, MOST OF THE PRESSURE LOSS IS RECOVERED IN THE VENTURI EXIT.

$$\text{FROM BERNOLLI, } P_0 - P = \frac{\rho V^2}{2g_c} = \frac{\rho}{2g_c} \left( \frac{Q}{A} \right)^2 \quad (5)$$

THE IRREVERSIBLE LOSSES ARE:

$$(1-R) \frac{\rho}{2g_c} \left( \frac{Q}{A} \right)^2 \quad (2), \text{ WHERE } R = \text{RECOVERY FACTOR}$$

DEFINING  $K'_V \equiv (1-R) \equiv \text{NON-CAVITATING LOSS FACTOR}$ 

$$\text{THUS } \Delta P = K'_V \frac{\rho}{2g_c} \left( \frac{Q}{A} \right)^2 \quad (6)$$

OR COMBINING ALL CONSTANTS INTO  $K_V''$ 

$$\Delta P = K_V'' \left( \frac{Q}{A} \right)^2 \quad (7)$$

$$\text{IF } K'_V \equiv \Delta P / Q^2 \quad (8)$$

FOR ANY GIVEN VENTURI

$$\text{OR } \Delta P = K_V Q^2 \quad (9)$$

ENGINEERING DEPARTMENT  
CALCULATION SHEET

DKH  
7/25/90 P. 103 of 119  
110 0167

SUBJECT: AFW FLOW VENTURI SIZING DESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY R. G. [Signature] DATE 3/22/90 CHK. BY [Signature] DATE 5/9/90

TEST DATA FROM REFERENCES 1 AND 2 SHOWN:  
TABLE 8-1

Q (GPM)	$\Delta P$ (PSI)	$K_v$ (CALCULATED FROM EQ (4))	VENTURI SIZE
39.49	5.49	3.52 E-3	5413
60.30	13.97	3.84 E-3	5413
42.67	5.64	3.09 E-3	5414
62.58	13.04	3.33 E-3	5414
40.0	6.79	4.24 E-3	5415
61.52	16.39	4.33 E-3	5415

AVG.  $K_v$  @ 50 TO 62 GPM (AREA OF INTEREST)  
 $\approx 3.8 \text{ E-3}$

USE THIS VALUE TO DETERMINE LOSSES DUE TO VENTURI, WHEN OPERATING ON THE SYSTEM CURVES.

THERE ARE THREE SCENARIOS IN WHICH THE NON-CAVITATING LOSSES THRU THE VENTURIS MIGHT AFFECT VENTURI SIZING, NAMELY:

- 185 GPM TO 3 SGS = 61.7 GPM/SG (SEG 5.1.3)
- 165 GPM TO 3 SGS = 55.0 GPM/SG (SEG 5.1.4)
- 100 GPM TO 2 SGS = 50.0 GPM/SG (SEG 5.1.4)

FROM EQ (5)  $\Delta P_{\text{VENTURI}} =$   
 @ 50 GPM  $\Delta P = 3.8 \text{ E-3} + 50^2 = 9.50 \text{ PSI}$

@ 55 GPM  $\Delta P = 3.8 \text{ E-3} + 55^2 = 11.50 \text{ PSI}$

@ 61.7 GPM  $\Delta P = 3.8 \text{ E-3} + 61.7^2 = 14.47 \text{ PSI}$

DWG. NO.



ENGINEERING DEPARTMENT  
CALCULATION SHEET

DKH  
7/25/90 P. 104 of 119  
111 167  
SOPPL. B  
DC-2836 REVISION 0

SUBJECT: AFW FLOW VENTURIS SIZING DESIGN CALCULATION NO. 0

J.O. NO. \_\_\_\_\_ MADE BY R.A. Hoff DATE 3/24/90 CHK. BY 0 DATE 5/9/90

8.3 RESIZE VENTURIS

RESIZE VENTURIS FOR THE FOLLOWING FLOW RATES: 150, 145, 140 AND 135 GPM AS FOLLOWS:

1) OBTAIN PRESSURE CORRESPONDING TO EACH FLOW RATE FROM (G10+G10S+G10W) PUMP CURVE. (FIGURE 1.)

2) CALCULATE A VENTURI FLOW COEFFICIENT (C) FOR EACH FLOW RATE SIZE OF VENTURI USING THE EQUATION:  $C = \frac{Q^2}{P - P_v}$  (10)

$$C = \frac{Q^2}{P + 14.7 - 0.4} = \frac{Q^2}{P + 14.3}$$

Q (GPM)	TABLE 8-2 P (PSIG)	C
150	1159	19.41
145	1167	18.02
140	1174	16.70
135	1184	15.36

FROM EQUATIONS (2) AND (10)

$$Q^2 \sim A^2 \Delta P \sim C \Delta P \quad (11)$$

$$\therefore A^2 \sim C \quad (12)$$

$$A \sim \sqrt{C} \quad (13)$$

$$D \sim C^{1/4} \quad (14)$$

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

7/25/90  
DKH P. 105 of 159  
112 157  
SUPPL. 5  
DC2836 REVISION 0

SUBJECT: AFW FLOW VENTURE SIZING

DESIGN CALCULATION NO. \_\_\_\_\_

J.O. NO. \_\_\_\_\_ MADE BY R. Q. W. DATE 3/22/90 CHK. BY Ø DATE 5/4/90

FROM SECTION 8.1,  $C_{EXISTING} = 30.99$   
 $A_{EXISTING} = 1.056E-3 \text{ ft}^2$   
 $D_{EXISTING} = 0.440 \text{ IN}$

RATIONG BY EQUATIONS (12) AND (13) YIELDS THE

FOLLOWING:

VENTURE SIZE	TABLE 8-3 A (FT <sup>2</sup> ) * E3	D (IN)
185 (EXIST) GPM	1.056	0.440
150	0.835	0.391
145	0.804	0.384
140	0.774	0.377
135	0.743	0.369

FROM EQ. (8);  $KV \cdot \frac{\Delta P}{Q^2} \& C = Q^2 / \Delta P$  (FROM (10))

$\therefore KV \sim 1/C$  (15)

CALCULATING K FROM KV OF 8.2, RATIONG BY 1/C (EQ. 15)

VENTURE SIZE	TABLE 8-4 KV
185	3.8E-3
150	6.07
145	6.55
140	7.07
135	7.67

NOTE - DURING THE REST OF THIS CALCULATION, VENTURES WILL BE IDENTIFIED BY MAXIMUM FLOW THEY WILL PASS. OR

150, 145, 140, OR 135

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEETS 21 OF 62 SHEETS

DKH  
7/25/90 P. 104 of 159  
SUPPL. B 113 167

SUBJECT: AFW FLOW VENTURI SIZING DESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY R. A. [Signature] DATE 3/22/90 CHK. BY [Signature] DATE 5/9/90

CALCULATE EFFECT OF NEGLECTING PRESSURE LOSSES BETWEEN PUMPS AND VENTURIS WHEN CALCULATING VENTURI FLOW RATES.

FROM PAGES 80 TO 81 OF REFERENCE 2:  
AT A FLOW OF 131 GPM / SG

PUMP DISCH PRESSURE = 1244.7 PSIG  
VENTURI INLET PRESSURE = 1224.1 PSIG  
20.6 PSIG

% ERROR =  $20.6 / 1224.1 = 1.7\%$

VENTURIS SIZING IS BASED ON INLET PRESSURE,  
∴ RESULTS WILL BE ≤ 1.7% CONSERVATIVE FOR ALL CASES IN WHICH IT IS DESIRABLE TO LIMIT FLOW. (CASES 1, 5, AND 6). THERE WILL BE NO EFFECT ON CASES 3 AND 4, BECAUSE VENTURIS DO NOT CAVITATE IN THESE CASES. CASE 2 WILL BE CALCULATED CORRECTLY BECAUSE VENTURI SPECIFICATION AND CALCULATION ARE BOTH BASED ON VENTURI INLET PRESSURE.

ENGINEERING DEPARTMENT  
CALCULATION SHEETDKH  
7/25/90 P. 1078 159  
114 167  
SUPPL B  
DC 2836 REVISION 0SUBJECT: AFW FLOW VENTURI SIZINGDESIGN  
CALCULATION NO. 0

J.O. NO.

MADE BY

R. E. W.

DATE 3/22/90

CHK. BY

0

DATE 5/9/90

8.4 CALCULATE FLOW RATES AT EACH DESIGN  
CONDITION

FLOW RATES WILL BE PROVIDED FOR EACH VENTURI SIZE AT EACH OF THE FOLLOWING DESIGN CONDITIONS:

1. CASE 1 (SEC 5.1.1) MAX. FLOW  $(G_{10} + G_{10S} + G_{10W})$   
TO 3 UNPRESSURIZED S.G.S (MAX = 150 GPM/SG)
2. CASE 2 (SEC 5.1.2) MIN. FLOW  $G_{10W}$  OR  $G_{10S}$   
TO 2 UNPRESS. S.G.S + 1 BREAK (MIN = 175 GPM/2SG)
3. CASE 3 (SEC 5.1.3) MIN. FLOW  $G_{10W}$  OR  $(G_{10} + G_{10S})$   
TO 3 S.G.S @ 1015 PSIG (MIN = 185 GPM/3 SG)
4. CASE 4 (SEC 5.1.4) MIN. FLOW  $G_{10}$  TO  
3 S.G.S @ 1015 PSIG (MIN = 165 GPM/3 S.G.S)
5. CASE 5 (SEC 5.1.5) MIN. FLOW  $G_{10W}$  OR  $(G_{10} + G_{10S})$   
TO 2 S.G.S @ 1015 PSIG + 1 BREAK (MIN = 100 GPM)
6. CASE 6 (SEC 5.1.5) MAX FLOW  $G_{10S} = 420$  GPM

8.4.1 CASE 1 MAX.  $(G_{10} + G_{10S} + G_{10W})$  FLOW  
TO 3 S.G.S

BY DEFINITION (SEE 8.3) FLOWS ARE  
150, 145, 140 & 135 GPM.

ENGINEERING DEPARTMENT  
**CALCULATION SHEET**

DKH  
 7/25/90 P. 115  
 115 167

SUBJECT: AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. DC-2836 REVISION 6

J.O. NO. \_\_\_\_\_ MADE BY R.A. [Signature] DATE 3/22/90 CHK. BY [Signature] DATE 5/9/90

8.4.2 CASE 2 G10W or G10S FLOW TO 2 UNPRESS. SCS + 1 FW BREAK

By inspection of Figs 1 & 3, G10S is a smaller pump than G10W.  
 ∴ ANALYZE FOR G10S ONLY, AS IT BOUNDS G10W.  
 USING EQUATION (10) AND THE FLOW COEFFICIENTS FOR EACH FLOW,  
 CALCULATE VENTURI (CAVITATING) CURVES FOR EACH SIZE VENTURI IN THE REGION OF INTERSECTION WITH THE G10S ACTUAL PUMP CURVE AND PLOT TO FIND INTERSECTION ON FIG. 2.

RESULTS ARE SHOWN IN TABLE 4-5, BELOW.

TABLE 4-5

VENTURI SIZE (GPM)	C	Q (CURVE) <sup>①</sup>		P = Q <sup>2</sup> /C <sup>②</sup>	Q CALC'D <sup>③</sup>			P CALC <sup>③</sup>
		15G	35G		15G	25G	35G	
150	19.41	115	345	681	113	227	340	@ 665
		110	330	623				
145	18.02	110	330	671	111	223	335	@ 680
		115	345	734				
140	16.70	110	330	725	108	217	325	@ 705
		105	315	660				
135	15.39	105	315	716	106	212	318	@ 730
		110	330	786				

- ① USED TO CALCULATE VENTURE CURVE FROM EQ. (10)
- ② CALC'D FROM ① AND EQ. (10) TO DEVELOP VENTURE CURVE
- ③ CALC'D FROM INTERSECTION OF VENTURE CURVES (POINTS ① AND ②) AND G10S ACTUAL PUMP CURVE (FIG. 2)

DWG. NO. \_\_\_\_\_

ENGINEERING DEPARTMENT  
CALCULATION SHEETDKH  
7/25/90 P. 1098/159  
116/167  
SUPPL B  
DC-2836 REVISION 0

SUBJECT: AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO.

MADE BY

R.G. Hoff

DATE 3/22/90

CHK. BY

0

DATE

5/1/90

8.4.3 CASE 3 G10W or (G10+G10S) FLOW  
TO 3 SG AT 1015 PSIG

INSPECTION OF FIGURE 3 SHOWS THAT IN THE AREA OF INTEREST ( $\approx 185$  GPM), THE PUMP CURVES FOR G10W AND (G10+G10S) INTERSECT EACH OTHER. THEREFORE, EVALUATION WILL CONSIDER BOTH PUMP CURVES, AS APPROPRIATE.

FLOW TO THE STEAM GENERATORS IS CONTROLLED BY FRICTION AND ELEVATION LOSSES, <sup>(RATHER THAN VENTURE CAVITATION, 4/15/90)</sup> BECAUSE OF THE HIGH STEAM GENERATOR PRESSURE. THESE LOSSES HAVE BEEN DEFINED BY REF. 6, p. R4-26 IN A SYSTEM CURVE FOR THE EXISTING DESIGN. BECAUSE REDUCING THE SIZE OF THE VENTURIS WILL INCREASE SYSTEM LOSSES, THE SYSTEM CURVE MUST BE RECALCULATED FOR EACH SIZE VENTURI. LOSS COEFFICIENTS FOR EACH VENTURI SIZE WERE CALCULATED IN SECTION 8.3. A NEW SYSTEM LOSS COEFFICIENT WILL BE CALCULATED FOR EACH VENTURI, BY ADDING THE INCREASE IN LOSS COEFFICIENT FOR EACH VENTURI TO THE EXISTING SYSTEM LOSS COEFFICIENT.

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEETDKR  
7/25/90 P. Hod +59  
SUPPL. B 117 167  
DC-2836 REVISION 0SUBJECT: AFW FLOW VENTURE SIZING

DESIGN CALCULATION NO. \_\_\_\_\_ REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY R. A. Wolf DATE 3/22/90 CHK. BY 0 DATE 5/9/90

## DATA TO PLOT FIGURE 3

PLOT  $G_{10W}$  AND  $(G_{10} + G_{10S})$  ON THE SAME PLOT. USE AN EXPANDED SCALE THAT ENCOMPASSES AREA OF INTEREST (100 GPM TO 300 GPM)

$G_{10W}$  (FROM  $G_{10W}$  ADJUSTED CURVE, SHEET R4-57 OF REF. 6):

Q	P
100	1290
150	1260
200	1200
250	1130
300	1045

$(G_{10} + G_{10S})$  (FROM  $G_{10} + G_{10S}$  ACTUAL CURVE, SHEET R4-59)\* OF REF. 6, (FIGURE 2 OF THIS CALCULATION):

Q	P	* $(G_{10} + G_{10S})$ ACTUAL AND $(G_{10} + G_{10S})$ ACTUAL MERGE AT 300 GPM.
132	1225	
150	1220	
200	1210	
250	1195	
300	1175	

AT THIS TIME, ALSO PLOT  $G_{10}$  ACTUAL CURVE FOR FUTURE USE.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

DKH  
7/25/90 P.H. ~~118~~ 167  
SUPPL. B 118  
DC-2836 REVISION 0

SUBJECT: AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. \_\_\_\_\_ REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY P.A. W.P. DATE 3/22/90 CHK. BY 0 DATE 5/9/90

G-10 FROM G10 ACTUAL CURVE OF REF. 6  
(FIG. 2 THIS CALCULATION)

Q	P	
150	1210	}
200	1170	
250	1125	
275	1100	
300	1070	

EXTRAPOLATED



ENGINEERING DEPARTMENT  
CALCULATION SHEETDKH  
7/25/90 P. 42 of 49  
SUPPL. 3 119 0/167  
DC 2836 REVISION 0

SUBJECT: AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. DC 2836 REVISION 0

J.O. NO.

MADE BY

R. E. Hoff

DATE 3/22/90

CHK. BY

P

DATE

5/9/90

FROM REFERENCE 6, SHEET R4-26, THE PRESSURE LOSS DUE TO ELEVATION = 10.6 PSID

FROM REFERENCE 6, SHEET R4-27

$Q_{TOTAL} = 604 \text{ GPM @ } 300 \text{ PSID on } 201.3 \text{ GPM/SG @ } 300 \text{ PSI}$

FRUCTION LOSS =  $300 - 10.6 = 289 \text{ PSI}$

$$\text{SYSTEM } K \equiv \Delta P / Q^2 = \frac{289}{201.3^2} = 7.13 \text{E-}3$$

FROM B.3, CURRENT VENTURI  $K = 3.8 \text{E-}3$

$\therefore K \text{ OF SYSTEM WITHOUT VENTURI} =$

$$(7.13 - 3.8) \text{E-}3 = 3.33 \text{E-}3$$

CALCULATE A SYSTEM K FOR EACH SIZE VENTURI. THEN, CALCULATE LIMITED SYSTEM CURVES FOR EACH SIZE VENTURI NEAR INTERSECTIONS WITH PUMP CURVES.

$$\Delta P = KQ^2 + \text{ELEV. LOSS} = KQ^2 + 11.$$

FOR AN SG AT 1015 PSIG,  $P = 1015 + \Delta P = 1026.7 + KQ^2$

TABLE 8-6, BELOW SHOWS: THE <sup>ESTIMATED</sup>  $\Delta P$  FOR EACH VENTURI AT THE MINIMUM FLOW OF  $185/3 = 61.7 \text{ GPM/VENTURE}$ , NEW SYSTEM K'S FOR EACH VENTURI AND THE TOTAL FLOW TO THE THREE STEAM GENERATORS

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET 25-28 OF 62 SHEETS

DKH  
7/25/90 P-H3  
120 167

SUBJECT: AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. DC2836 REVISION C

J.O. NO.

MADE BY

PAW

DATE 3/22/90

CHK. BY

□

DATE 5/9/90

TABLE 8-6

VENTURI SIZE	KV (1)	$\Delta P_{VENT.}$ (2)	K <sub>sys</sub> (3)	Q <sub>curve</sub> (4)	P (5)	Q <sub>calc.</sub> (6)
150	6.07E-3	23.1	9.41E-3	270	1102	268
				240	1086	
145	6.55	24.9	9.88	270	1106	266
				240	1089	
140	7.07	26.9	10.40	270	1110	265
				240	1093	
135	7.67	29.2	11.00	270	1115	263
				240	1096	

(1) FROM TABLE 8.4

(2)  $\Delta P = K * 61.7^2$  (61.7 = 185/3)

(3)  $K_{sys} = 3.33E-3 + K_v$

(4) INPUT VALUE FOR SYS. CURVE

(5) CALC'D FROM  $P = 1026 + K_{sys} Q^2$

(6) FROM INTERSECTION OF SYS. CURVE WITH GLOW PUMP CURVE (Fig 3)

ALL VENTURIS. HAVE LARGE MARGIN

CALCULATE MAXIMUM K &  $\Delta P$  VENTURI AT 61.79 PM / SC  
= 185 GPM TOTAL

AT 185 GPM  $P = 1214$  (G10 + G10s PUMP CURVE)

$\Delta P_{sys} = 1214 - (1015 + 11) = 188$  PSID

$K = 188 / (185/3)^2 = 49.4 E-3$

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEETS 29 OF 62 SHEETS

DEH  
7/25/90 P.H.H. 159  
SUPPL B 121 167

SUBJECT: AFW FLOW VENTURI SIZING DESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY R. A. WJ DATE 3/22/90 CHK. BY Q DATE 5/9/90

$$K_{\text{ALLOWABLE VENTURI}} = 49.4 \text{ E-3} - 3.33 \text{ E-3}$$
$$= 46.3 \text{ E-3}$$

$$\Delta P_{\text{ALLOWABLE}} = 46.3 \text{ E-3} + \left(\frac{185}{3}\right)^2 = 175 \text{ PSI}$$

WHICH IS MUCH LARGER THAN ESTIMATED  
 $\Delta P$ 'S OF 23.4 TO 29.2 PSI.  $\therefore$  THIS CASE  
WILL NOT CONTROL THE DESIGN, BUT MAY  
BE THE LIMITING CASE WITH RESPECT  
TO PRESSURE DROP.

DWG. NO. \_\_\_\_\_

ENGINEERING DEPARTMENT  
CALCULATION SHEET

DK 4  
7/25/90 P: HSE/139  
SUPPL B 122 167  
DC-2836 REVISION 0

SUBJECT: AFW VENTURI SIZING

DESIGN CALCULATION NO. 0

J.O. NO. \_\_\_\_\_ MADE BY R.G. Jff DATE 3/22/90 CHK. BY 0 DATE 5/9/90

8.4.4 CASE 4 G10 TO 3SGS AT 1015 psia

ANALYSIS IS SIMILAR TO CASE 3, EXCEPT THAT FLOWS ARE DETERMINED BY INTERSECTION OF NEW SYSTEM CURVES, CALCULATED IN 8.4.3, WITH G10 PUMP CURVE.

IN THIS FLOW RANGE G10 CURVE IS VERY CLOSE TO G10W CURVE (SEE FIG. 3). ∴ USE SYSTEM CURVES CALCULATED IN 8.4.3 TO DETERMINE FLOWS. FROM FIG. 3 :

TABLE 8. - 7

VENTURI SIZE	G10 FLOW GPM
150	272
145	270
140	268
135	265

AT 165 GPM  $P_0$  of G10  $\approx$  1198 psia

$\Delta P = 1198 - 1026 = 172 \text{ psi}$

$K = 172 / \left(\frac{165}{3}\right)^2 = 56.9 E-3$

LARGER THAN FOR CASE 3

∴ CASE 3 K BOUNDS CASE 4

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET RS-31 OF 62 SHEETS

DKIT  
7/25/90  
SUPPL. B  
123  
P-HH  
167  
0

SUBJECT AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY R.A. [Signature] DATE 3/22/90 CHK. BY [Signature] DATE 5/9/90

8.4.5 CASE 5 GLOW OR (G10+G105) TO 25G  
AT 1015 PSIG AND 1 BRKAK

FROM FIGURE 3, GLOW AND (G10+G105) PUMP CURVES INTERSECT NEAR AREA OF INTEREST. BOUNDING CASE WILL BE DETERMINED DURING ANALYSIS. BOUNDING CASE IS PUMP THAT PROVIDES THE LEAST FLOW TO THE BRKAK.

THE SYSTEM CURVE WILL CHANGE WHEN THERE IS A BROKEN LINE, BECAUSE

$$Q_T = Q_1 + Q_2 + Q_3 \quad (16)$$

WHERE:

$Q_T$  = TOTAL FLOW

$Q_1 = Q_2$  = FLOW TO PRESSURIZED STEAM GENERATOR

$Q_3$  = FLOW THROUGH BRKAK

$$Q_1 = Q_2 = K_{1,2} \sqrt{(P_0 - P_{SG} - P_{GL})} \quad (17)$$

$P_0$  = PUMP DISCH. PRESS

$P_{SG}$  = ST. GEN. PRESS.

$P_{GL}$  = ELEV. PRESS. LOSS

$$Q_3 = C_3 \sqrt{(P_0 - P_V)} \quad (18)$$

$C_3$  = VENTURE COEFFICIENT

$P_V$  = VAPOR PRESSURE

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SUBJECT: AFW FLOW VENTURI SIZINGDESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO. \_\_\_\_\_

MADE BY R. A. WiffDATE 3/22/90CHK. BY PDATE 5/9/90

COMBINING (16), (17) AND (18) YIELDS

$$Q_T = 2K_{1,2} \sqrt{P_0 - P_{s2} - \Delta P_{EL}} + C_3 \sqrt{P_0 + (14.7 - P_v)} \quad (19)$$

FOR SC PRESSURE OF 1015 PSIA,  $\Delta P_{EL} = 11$  PSIA (SEE 8.4.3)

AND  $P_v = 0.4$  PSIA (SEE 8.1); YIELDING:

$$Q_T = 2K_{1,2} \sqrt{P_0 - 1026} + C_3 \sqrt{P_0 + 14.3}$$

$K_{sys}$  VALUES WERE CALCULATED IN SECTION 8.2

FOR USE IN EQUATION (9),  $\Delta P = K_{sys} Q^2$

OR  $K_{sys} = \Delta P / Q^2$  (NOTE:  $K_{sys}$  IS FOR 1 LOOP TO SA)

BUT IN EQ. (9)  $K_{1,2} = Q / \sqrt{\Delta P}$

$$\therefore K_{1,2} = 1 / \sqrt{K_{sys}} \quad (20)$$

C VALUES WERE DEVELOPED IN SECTION 8.3 FOR USE IN

EQ. (10),  $\Delta P = Q^2 / C$  OR  $C = Q^2 / \Delta P$

BUT IN EQ. (19)  $C_3 = Q / \sqrt{\Delta P}$

$$\therefore C_3 = \sqrt{C} \quad (21)$$

CALCULATE  $K_{1,2}$  &  $C_3$  FOR EACH VENTURI SIZE.

RESULTS ARE SUMMARIZED IN TABLE 8-8

ENGINEERING DEPARTMENT  
CALCULATION SHEET

DATE 7/25/90 P. 110 of 159  
SUPPL. B 125 167  
DESIGN CALCULATION NO. DC-2876 REVISION 0

SUBJECT: AFW FLOW VENTURI SIZING

J.O. NO. \_\_\_\_\_ MADE BY R.A. Wff DATE 3/22/90 CHK. BY Ø DATE 5/9/90

TABLE 8-8

VENTURI SIZE	$K_{sys} \times E^3$	$K_{1,2}$	C	$C_3$
150	9.40	10.31	19.47	4.41
145	9.88	10.06	18.02	4.24
140	10.40	9.81	16.70	4.09
135	11.00	9.53	15.39	3.92

o USING THE ABOVE VALUES, DEVELOP SYSTEM CURVES FOR EACH VENTURI SIZE IN AREA THAT WILL INTERSECT  $G_{10W}$  OR  $(G_{10} + G_{10S})$  PUMP CURVES, USING EQUATION (19).

o CALCULATE  $Q_T$  AND  $P_0$  FROM INTERSECTION WITH PUMP CURVE (SEE FIGURE 2)

o CALCULATE  $Q_1$ ,  $Q_2$  &  $Q_3$  FROM EQUATIONS (17) AND (18).

LIST ALL VALUES IN TABLE 8-9, BELOW

ENGINEERING DEPARTMENT  
CALCULATION SHEET

DKH  
7/25/90  
SUPPL. B  
DC2836  
P.H. 126  
159  
167  
REVISION 0

SUBJECT: AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. DC2836 REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY R. J. [Signature] DATE 3/22/90 CHK. BY [Signature] DATE 5/9/90

TABLE 89

VENTURI SIZE	$K_{1,2}$	$C_3$	$P_0$ CURVE	$Q_T$ CURVE	$Q_T$ CALC	$P_0$ CALC	$Q_{1+Q_2}$	$Q_3$
150	10.31	4.41	1080	297	285	1072	140	145
145	10.06	4.24	1070	282	284	1076	142	140
140	9.81	4.09	1080	288	281	1081	146	135
135	9.53	3.92	1080	270	278	1086	148	130

- ① FROM TABLE
  - ② INPUT FOR SYSTEM CURVE
  - ③ CALCULATED FROM EQ. (19)
  - ④ FROM INTERSECTION OF SYS. CURVE & PUMP CURVE FIG 3
  - ⑤ FROM EQ. (17) AND  $P_0$  CALC
  - ⑥ FROM EQ. (18) AND  $P_0$  CALC.
- NOTE - ALL FLOWS GREATER THAN 100 GPM REQUIRE MCLT



ENGINEERING DEPARTMENT  
CALCULATION SHEETDKH  
7125190 P. 1200-159  
127 167SUBJECT: AFW FLOW VENTURI SIZING DESIGN CALCULATION NO. DC 2836 REVISION 0J.O. NO. \_\_\_\_\_ MADE BY P. L. W. DATE 3/22/91 CHK. BY Ø DATE 5/9/90

ALL VENTURI SIZES IN TABLE 8-9 PROVIDE SUFFICIENT MARGIN, AS  $(Q_1 + Q_2)$  RANGES FROM 139 GPM TO 148 GPM. THE REQUIRED VALUE IS 100 GPM BECAUSE REDUCING VENTURI SIZE HAS A GREATER EFFECT ON FLOW LOST THROUGH THE LEAK, THAN ON SYSTEM FLOWS, THE SMALLER VENTURIS PERMIT MORE FLOW TO THE STEAM GENERATORS.

CHECK MARGIN ON  $\Delta P$ 

$$\text{AT } 100 \text{ GPM } P_0 (G_{10} + G_{105}) = 1250$$

$$\Delta P = 1250 - 1026 = 224$$

$$K = 224 / \left(\frac{100}{2}\right)^2 = 89.6 E-3$$

$$89.6 E-3 > 50.5 E-3 \text{ CALCULATED IN 8.4.3}$$

$\therefore$  THE LOSSES ARE BOUNDED BY CASE 3.

8.4.6 CASE 6 G105 FLOW LIMIT

SECTION 8.4.2 CALCULATED FLOW TO EACH STEAM GENERATOR USING THE ACTUAL G105 CURVE. EXTRAPOLATING THE VENTURI CURVES TO THE G105 DESIGN CURVE YIELDS

THE RESULTS PRESENTED BELOW, IN TABLE 8-10

ENGINEERING DEPARTMENT  
CALCULATION SHEETDKH  
7/25/90 P. 121 of 179  
SUPPL B 128 167  
DC-2836 REVISION 0

SUBJECT: AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO.

MADE BY

R. A. Hoff

DATE 3/22/96

CHK. BY

D

DATE

5/9/90

TABLE 8.10

VENTURI SIZE	GDS FLOW GPM
150	350
145	342
140	335
135	325

THUS, ALL VENTURIS PROVIDE LARGE MARGINS  
WITH RESPECT TO 420 GPM LIMIT.

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

DRAWN 7/25/90 P. +200 of 159  
SUPPL B 129 167  
DL-2836 REVISION 0

SUBJECT: AFW FLOW VENTURI SIZING DESIGN CALCULATION NO. DL-2836 REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY R.A. [signature] DATE 3/22/90 CHK. BY [initials] DATE 5/4/90

8.5 DESIGN MARGINS

8.5.1 CASE 1 150 GPM MAX. / SG

REVIEW OF PREVIOUS CALCULATIONS SHOW ALL SIZES (135 - 150) PROVIDE LARGE MARGIN FOR ALL CASES.

IF 140 GPM +0, -10 GPM IS SELECTED  
MARGIN FOR CASE 1 IS  $\frac{150 - 140}{150} = 6.7\%$

AT 130 GPM MARGIN =  $\frac{150 - 130}{150} = 13.3\%$

8.5.2 CASE 2 175 MIN. TO TWO DSG. SG + BREAK FROM SECTION 8.4.

FOR 135 GPM VENTURI 212 GPM PROVIDED  
MARGIN =  $\frac{212 - 175}{175} = 21\%$

REVIEW OF ALL CASES INDICATES CASE 2 WILL CONTROL DESIGN FOR CASE 1. PLOT CASE 1 FLOW VS. CASE 2 FLOW (FIGURE 4).

EXTRAPOLATING FLOW TO 130 GPM SHOWS 206 GPM TO 2 SCS  
MARGIN =  $(206 - 175) / 175 = 18\%$

ENGINEERING DEPARTMENT  
CALCULATION SHEET

DKH  
7/25/90 P. 123 of 187  
SUPPL. B 130 167  
DESIGN CALCULATION NO. DC-2836 REVISION 0

SUBJECT: AFW FLOW VENTURE SIZING

J.O. NO.

MADE BY

R. A. W. /

DATE

3/22/90

CHK. BY

D

DATE

5/9/90

8.5.3 CASE 3 185 GPM TO 3 PRESS. SG (G10W) OR (G10+G10S)

140 GPM DESIGN PROVIDES 265 GPM TO 3 SCS  
(8.4.3) TABLE 8-6

$$\text{MARGIN} = \frac{265 - 185}{185} = 43\% \quad (80 \text{ GPM})$$

EXTRAPOLATING TO 130 GPM SHOWS:

260 GPM TO 3 SCS

$$\text{MARGIN} = \frac{260 - 185}{185} = 41\% \quad (7.5 \text{ GPM})$$

8.5.4 CASE 4 165 GPM TO 3 PRESS. SG (G10)

FROM 8.4.4 TABLE 8-7

140 GPM DESIGN PROVIDES 265 GPM

$$\text{MARGIN} = \frac{268 - 165}{165} = 62\% \quad (103 \text{ GPM})$$

EXTRAPOLATING TO 130 GPM YIELDS 262 gpm

$$\text{MARGIN} = \frac{263 - 165}{165} = 59\% \quad (98 \text{ GPM})$$

8.5.5 CASE 5 100 GPM TO 2 PRESS. SG + BREAK (G10W) OR (G10+G10S)

FROM 8.4.5

A 140 DESIGN YIELDS 146 GPM.

$$\text{MARGIN} = \frac{146 - 100}{100} = 46\% \quad (46 \text{ GPM})$$

REDUCING ORIFICE SIZE, INCREASES FLOW.

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

PKH  
7/25/90 P. 129 of 131  
SUPPL. B 131 162

SUBJECT AFW FLOW VENTURE SIZING

DESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY R. A. Uff DATE 3/22/90 CHK. BY Ø DATE 5/4/90

8.5.6 CASE 6 MAXIMUM GIOS FLOW  
FROM 8.4.6

140 DESIGN YIELDS 335 GPM

MARGIN =  $\frac{420 - 335}{420} = 20\%$  (85 GPM)

EXTRAPOLATING TO 130 GPM YIELDS 320

MARGIN =  $\frac{420 - 320}{420} = 24\%$

ENGINEERING DEPARTMENT  
CALCULATION SHEETDKIT  
7/25/90 P. 125  
SUPPL. B 132 167  
DC 2836 REVISION 0SUBJECT: AFW FLOW VENTURI SIZINGDESIGN  
CALCULATION NO.

J.O. NO.

MADE BY

C. A. W.

DATE 3/22/90

CHK. BY

D

DATE 5/9/90

8.6 DESIGN PARAMETERS

THIS SECTION PROVIDES THE PARAMETERS FOR SPECIFYING ORIFICE PERFORMANCE.

BASED ON CALCULATED MARGINS, A DESIGN OF 140 GPM  $\pm 0$ , -10 GPM APPEARS REASONABLE FROM (G10 + G10S + G10W) CURVE & SECTION 8.3 140 GPM OCCURS AT 1160 PSIG.

$\therefore$  SPECIFY VENTURIS FOR 140  $\pm 0$ , -10 GPM AT 1160 PSIG. TO SATISFY CASE 1.

TO SATISFY CASE 2, EACH VENTURI MUST PASS 87.5 GPM. SPECIFY 100 GPM TO PROVIDE A MARGIN. 100 GPM INTERSECTS G10S ACTUAL CURVE (FIGURE 2) AT 775 PSIG.

$\therefore$  SPECIFY THAT EACH VENTURI SHALL PASS AT LEAST 100 GPM AT 775 PSIG.

CASE 3 IS THE LIMITING CASE FOR NON-CAVITATION PRESSURE LOSS.

THE MAXIMUM ALLOWABLE PRESSURE DROP IS 175 PSID AT 61.7 GPM / VENTURE  
HOWEVER, TABLE 8-6 SHOWS THAT THE 140 GPM VENTURE SHOULD HAVE A 27 PSI PRESSURE DROP

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEETDEK  
7/25/90 P. 125 of 159  
SUPPL B 133 167  
DC-2836 REVISION 0SUBJECT: AF W FLOW VENTURI SIZINGDESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO. \_\_\_\_\_

MADE BY R-G. WJDATE 3-22-90CHK. BY ØDATE 5/5/90

EXTRAPOLATING TO A 130 GPM VENTURI YIELDS A  
32 PSID PRESSURE DROP.

∴ SPECIFY PRESSURE DROP NOT TO  
EXCEED 40 PSID AT 62 GPM. THIS SHOULD  
BE EASILY ATTAINABLE, PROVIDING AN EFFICIENT  
VENTURI, AND STILL PROVIDING CONSIDERABLE  
MARGIN  $\left( \frac{175 - 40}{40} \right) = 338\%$

THE VENTURI DIAMETER SHOULD BE APPROXIMATELY  
0.377" FROM TABLE B.3 TO PASS 140 GPM  
AT 130 GPM AND THE SAME PRESSURE, THE  
DIAMETER IS  $\approx 0.377 \left( \frac{130}{140} \right)^{1/4} = 0.370$

THIS APPEARS TO BE READILY ATTAINABLE  
BECAUSE, IT REQUIRES A TOLERANCE OF  
 $+0, -0.0075$  INCH. OLD VENTURI TOLERANCE  
IS  $+0, -0.005$  INCH (REF. 7)

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEETDKH  
7/25/90 P 127 of 159  
SUPPL. B 134 167  
DESIGN CALCULATION NO. DC-2836 REVISION 6

SUBJECT: AFW FLOW VENTURI SIZING

J.O. NO.

MADE BY

R. A. W.

DATE 5-21-96

CHK. BY

DATE

B.7 SUMMARY FIGURES

THE FOLLOWING SUMMARY FIGURES WILL BE PREPARED FOR THE RESULTS SECTION:

FIGURE 2-1 " SUMMARY PLOT - BEST ESTIMATE LOSSES FOR FLOW VENTURIS "

FIGURE 2-2 " SUMMARY PLOT MAXIMUM VENTURE PRESSURE LOSSES,

FIGURE 2-3 " CASE 5 CONDITIONS BASED ON MAXIMUM VENTURE  $\Delta P$ .

PUMP CURVES OBTAINED FROM FIGURES 1, 2, 3 AND ATTACHMENT H WILL BE PLOTTED ON FIGURES 2-1 AND 2-2. SYSTEM AND VENTURE CURVES, BASED ON THE BEST ESTIMATE OF VENTURE  $\Delta P$  WILL BE CALCULATED IN 8.7.1 AND PLOTTED ON FIGURE 2-1. SIMILAR CURVES BASED ON THE MAXIMUM ALLOWABLE VENTURE  $\Delta P$ S WILL BE CALCULATED IN 8.7-2 AND PLOTTED ON FIGURE 2-2. FIGURE 2-2 AND SECTION 8.4 RESULTS WILL BE SHOWN ON FIGURE 2-3, WHICH DEPICTS THE SYSTEM UNDER CASE 5 POSTULATED CONDITIONS



ENGINEERING DEPARTMENT  
**CALCULATION SHEET**

DKH  
 7/25/90 P 128 of 159  
 SUPPL. 13  
 135 167

SUBJECT: AFW FLOW VENTURE SIZING

DESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY R.A. W DATE 5-21-90 CHK. BY \_\_\_\_\_ DATE \_\_\_\_\_

8.2.1 CALCULATE SYSTEM CURVES AND CAVITATION CURVES AND SUPERIMPOSE ON PLOT OF PUMP CURVES

DO FOR 135 AND 140 GPM VENTURES  
 SYSTEM CURVE:

$$\Delta P = KQ^2 + \Delta P_{EUL} = KQ^2 + 11.$$

FROM TABLE 8-6  $K(140) = 10.4E-3$  &  $K(135) = 11.00E-3$

FOR 15G FOR 3 SG'S DIVIDE KS BY  $3^2 =$   
 $1.16E-3 (140)$  AND  $1.22E-3 (135)$

CAVITATING FLOW CURVE:

$$\Delta P = Q^2 / c \text{ OR } P = Q^2 / c - 14.$$

$c(140) = 16.70$  &  $c(135) = 15.39$  FOR 15G

FOR 3 SG  $c(140) = 16.70 \times 9 = 150.3$   $c(135) = 15.39 \times 9 = 138.5$

Q	140 SYS + 1015 SG.	135 SYS + 1015 SG	CAV (140)	CAV (135)
100	1038	1038		
150	1052			
200	1072	1075	1077	
300	1130	1136	1142	585
325				689
350	1168			801
380				946
400	1212	1221	1232	1050
410				1104
425	1236			1188
435				1245
450	1261	1273		1333
				636
				870
				1029
				1141
				1200
				1290
				1352
				1448

ENGINEERING DEPARTMENT  
CALCULATION SHEET

DLW  
7/25/90 P-1278-159  
136 167  
SUPPL. 3  
DC-2836 REVISION 0

SUBJECT: AFN FLOW VENTURI SIZING

DESIGN CALCULATION NO. 0

J.O. NO. MADE BY R. G. W. DATE 5-21-98 CHK. BY DATE

8.7.2 EFFECT OF HIGHER VENTURI PRESSURE LOSSES

THE PREVIOUS CALCULATIONS USED  $K_s$  FOR NON-CAVITATING VENTURI PRESSURE LOSSES BASED ON TEST DATA FOR THE EXISTING VENTURIS MODIFIED TO ACCOUNT FOR THE CHANGED SIZES, AS CALCULATED IN SECTIONS 8.2 AND 8.3. LARGER VENTURI  $K_s$  WERE SPECIFIED AT THE VENTURI VENDOR'S REQUEST. THIS SECTION CALCULATES SYSTEM CURVES BASED ON THE SPECIFIED VENTURI LOSSES.

IF  $\Delta P_{MAX} @ 55 \text{ gpm} = 35 \text{ psid}$ :

$$K_v = \Delta P / Q^2 \text{ (Eq. 8)} = \frac{35}{55^2} = 1.157E-2$$

$$K_{sys} = 3.33E-3 + 1.157E-2 = 1.49E-2$$

IF  $\Delta P_{MAX} @ 62.5 \text{ gpm} = 45 \text{ psid}$ :

$$K_v = 45 / 62.5^2 = 1.152E-2 < 1.157E-2$$

$\therefore 55 \text{ GPM GMSG GOVERNS}$

$$P_{sys} = P_{sc} + \Delta P_{CL} + \Delta P_{sys}$$

@ 1015 psic + 11 psi  $\Delta P_{CL}$

$$P_{sys} = 1026 + 1.49E-2 \left(\frac{Q}{13}\right)^2$$
$$= 1026 + 1.656E-3 Q^2$$

DWG. NO.

ENGINEERING DEPARTMENT  
**CALCULATION SHEET**

DKH P-1308-57  
 7125190 137 167  
 SUPPL. B  
 DESIGN CALCULATION NO. DC-2836 REVISION 0

SUBJECT: AFW FLOW VENTURIZ SIZING

J.O. NO. \_\_\_\_\_ MADE BY R. A. W. J. DATE 5.21.90 CHK. BY \_\_\_\_\_ DATE \_\_\_\_\_

SYSTEM CURVE

TOTAL FLOW (GPM)	PUMP DISC PRESS (PSIG)
100	1044
200	1094
300	1176
350	1230
400	1292
450	1363

FOR CASE 5 (FROM 8.4.5)

$$Q_T = 2K_{1,2} \sqrt{P_0 - P_{sa} - \Delta P_{CL}} + C_3 \sqrt{P_0 + (14.7 - P_{P_v})} \quad \text{Eq. 11}$$

$$= 2K_{1,2} \sqrt{P_0 - 1026} + C_3 \sqrt{P_0 + 14}$$

$$K_{1,2} = 1/\sqrt{K_{SYS}} \text{ (Eq. 20)} = 1/\sqrt{1.496-2} = 8.19$$

$$Q_T = 2 * 8.19 \sqrt{P_0 - 1026} + 4.09 \sqrt{P_0 + 14}$$

PUMP DISCH. PRESS (PD) (PSIG)	TOTAL FLOW (Q <sub>T</sub> ) (GPM)
1050	212
1100	277
1150	322
1200	359
1250	390
1300	419

ENGINEERING DEPARTMENT  
**CALCULATION SHEET**

DKH  
 7/25/90 P-1318-159  
 SUPPL B 138 167  
 DC-2836 REVISION 0

SUBJECT: AFW FLOW VENTURI SIZINGDESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY R.L.W. DATE 5/21/90 CHK. BY \_\_\_\_\_ DATE \_\_\_\_\_

$$\text{For CASE 5; } Q_T = 2k_{1,2} \sqrt{P_0 - 1026} + C_3 \sqrt{P_0 + 14.3}$$

$$\text{FOR 140 GPM VENTURI } 2k_{1,2} = 19.62, C_3 = 4.09$$

$$\text{135 GPM VENTURI } 2k_{1,2} = 19.06, C_3 = 3.92$$

P	Q <sub>T</sub> 140	Q <sub>T</sub> 135'
1026	132.	126.
1050	230	
1100	305	295
1150	358	
1200	401	388
1250	439.	
1300	473	458

DUE TO THE CLOSENESS OF THE VALUES FOR THE 135 GPM AND 140 GPM SYSTEM CURVES, PLOT VALUES FOR 140 GPM VENTURI SYSTEM CURVES ONLY.


$$\Delta P \text{ VENTURI AT CALCULATED FLOW OF 68 GPM / SG}$$

$$= 1.157E-2 (68)^2 = 53.5 \text{ psia}$$

DWG. NO.

MADE BY RLL DATE 3/22/90 CHECKED BY  $\phi$  DATE 5/9/90

# FIGURE 1 CAVITATING FLOW LIMIT



NOTE: BASED ON DESIGN PUMP CURVES

FIGURE 10


TOTAL FLOW TO S/G'S

DE 4  
7/25/10 P. 137  
1/18/9

30 Squares to the Inch

MADE BY R.W.J. DATE 3/22/90 CHECKED BY [Signature] DATE 5/4/90

### FIGURE 2 CAVITATING VENTURI FLOW LIMIT CURVES



CAVITATING FLOW  
LIMIT CURVES  
FOR 135, 140, 145, &  
150 GPM VENTURIES

FIGURE 1

7/25/90  
133 of 159  
167


Made By R.A.W.P. Date 5/7/90

Calc No. DC2836 Rev. 0

Ckd By Ø Date 5/9/90

Sh RS-44 of 62

**FIGURE 3**




SUPPL. B. DC-2036 REGNO

SH 25-45 DE 7/25/90 R. 145-110

MADE BY R. A. H. DATE 3/16/90 CHEMISTRY DATE 5/9/91

FIGURE 4  
COMPARISON OF  
CASE 1 AND CASE 2  
FLOWS WITH LIMITS





SUPPL. B DC-2836 REV. 0  
 ATTACHMENT A  
 PFI ID  
 FROM REF. 2


DE. BY R. H. M. 3/22/90  
 CHECKED BY S. DATE 5/2/93

SHR. OF 62

NUCLEAR GENERATION SITE  
 UNIT 1

# AUXILIARY FEEDWATER SYSTEM

SYSTEM DESCRIPTION SD-S01-620  
 REVISION 2 PAGE 25 OF 37



P. 143  
 1508 of 157  
 DKH 7/25/80

FIGURE 1 - Ref. 6  
 SUPPL. A DC-2836 REV. 5

FIGURE 1  
 SD-S01-620-01-5

DATE \_\_\_\_\_  
 MADE BY \_\_\_\_\_

**SCE** Southern California Edison Company  
 Songs ① 2 & 3

INTERIM DCN NO.  
 \_\_\_\_\_

MADE BY E. A. Uff 3/23/90  
 CHECKED BY [Signature] DATE 5/9/90

INTERIM DESIGN CHANGE  
 NOTICE (IDCN)/DESIGN  
 CHANGE NOTICE (DCN)  
 SUPPLEMENTAL PAGE

IDCN NUMBER S-1						
DRAWING NO.	SHEET NO.	REV. NO.	DCN CONV.		QUALITY CLASS	
			DATE			
			DWG. REV.	DCN NO.		
1810-AA319-M0007	-	0			SR.	


MSAPH 1-3587.01SM REV A SHT \_\_\_\_\_  
 DESCRIPTION OF CHANGE

Date 3-8-90 Page 2 of 3

By A. REYES

**BEFORE**

CUSTOMER TAG NUMBER	PERMIT SERIAL NO	PIPE SIZE	BETA RATIO	DESIGN		OPERATING		DESIGN FLOW RATE (CAVITATING MODE)	FLUID
				PRESSURE	TEMP	PRESSURE	TEMP		
PE-1076	N-5413	3" - SCH 80	.1517	600 PSIG	850 °F	524 PSIG	40°F	131 GPM @ 40 °F	WATER
PE-1076	N-5414	3" - SCH 80	.1517	600 PSIG	850 °F	524 PSIG	40°F	131 GPM @ 40 °F	WATER
PE-1077	N-5415	3" - SCH 80	.1517	600 PSIG	850 °F	524 PSIG	40°F	131 GPM @ 40 °F	WATER



ATTACHMENT C  
SYSTEM DESCRIPTION (REF. 3)DKH 7/25/90  
P. 138/189  
145 167NUCLEAR GENERATION SITE  
UNIT 1SYSTEM DESCRIPTION SD-S01-620  
REVISION 2 PAGE 2 OF 37AUXILIARY FEEDWATER SYSTEM1.0 FUNCTIONS/DESIGN BASES

1.1 The Auxiliary Feedwater System has the following main functions:

- 1.1.1 To provide feedwater to the steam generators during abnormal or emergency conditions which result in a loss of Main Feedwater.
- 1.1.2 To provide feedwater to the steam generators during normal start-up, normal shutdown and hot stand-by conditions.

1.2 The Auxiliary Feedwater System has the following additional functions:

- 1.2.1 To provide a means of filling and venting the Main Feedwater System in Modes 4, 5, or 6.
- 1.2.2 To provide a means of filling and/or feeding the steam generators via the Main Feedwater System in Modes 4, 5 or 6.

1.3 The Auxiliary Feedwater System has the following design bases:

- 1.3.1 The Auxiliary Feedwater System is designed to provide sufficient steam generator feedwater flow and volume to achieve and maintain the Reactor Coolant System in 'HOT STANDBY' (Mode 3) for at least 32 hours, with no offsite power available, following a reactor trip from full power. The Steam Dump System is used in conjunction with the Auxiliary Feedwater System to meet this design basis.
- 1.3.2 The Auxiliary Feedwater System is designed such that the Reactor Coolant System can be cooled down to less than 350°F from normal operating conditions with no offsite power available.

1.4 The Auxiliary Feedwater System has the following additional design bases:

- 1.4.1 The total minimum delivered flow to the steam generators from either AFW pumps G-10 and G-10S (operating concurrently) or AFW pump G-10W (operating alone) for loss of feedwater events shall be 195 gpm (plus margin) at a steam generator pressure of 1015 psig.
- 1.4.2 The total minimum delivered flow to the steam generators from AFW pump G-10 for station blackout events shall be 165 gpm (plus margin [1]) at a steam generator pressure of 1015 psig.

[1] This requirement anticipates the future application of generic Station Blackout requirements.

SUPPL. B 06-2836 REV 0  
ATTACHMENT C  
(CONT)

MADE BY RAH 3/23/91 SH 25-449 of 62  
CHECK 6081 @ DATE 5/9/90 DKH 1/25/90  
P. 139 of 159  
146 0 167

NUCLEAR GENERATION SITE  
UNIT 1

SYSTEM DESCRIPTION SD-S01-620  
REVISION 2 PAGE 3 OF 37

AUXILIARY FEEDWATER SYSTEM

1.0 FUNCTIONS/DESIGN BASES (Continued)

- 1.4.3 The total minimum delivered flow to the unaffected steam generators from AFW pump G-10W for feedwater line break events (upstream of the in-containment check valves) shall be 125 gpm (plus margin) at a steam generator pressure of 1015 psig with operator action to equalize flow in each AFW line.
- 1.4.4 The total minimum delivered flow to the unaffected steam generators from AFW pump pumps G-10 and G-10S, operating concurrently, for feedwater line break events (upstream of the in-containment check valves) shall be 125 gpm (plus margin) at a steam generator pressure of 1015 psig without operator action to equalize flow in each AFW line.
- 1.4.5 The total minimum delivered flow to the unaffected steam generators from AFW pump G-10W or G-10S for feedwater line break events (downstream of the in-containment check valves) shall be 250 gpm (plus margin) at depressurized steam generator conditions.
- 1.4.6 The maximum flow from AFW pump G-10S shall be limited to 420 gpm (pump runout limit) at depressurized steam generator conditions, considering the most limiting single active failure and using only passive mechanical means.
- 1.4.7 The maximum automatically delivered flow from AFW pump G-10W or G-10S shall be limited to 150 gpm per steam generator (water hammer limit) at depressurized conditions considering the most limiting single active failure and using only passive mechanical means.

CASE 4 Main Feedwater Line Break Downstream of In-Containment Check Valves at 50% Power

- 4a. The plant is initially operating at 53% of rated power.
- 4b. Initial reactor coolant average temperature is 4°F above the nominal value (551.5°F) corresponding to 50% power level on the nominal average temperature program (575.15°F at full power).
- 4c. Initial pressurizer water level is 30.0% narrow range span (NRS).
- 4d. Main feedwater to all steam generators is assumed to stop at the time of the feedline break.
- 4e. Pressurizer power-operated relief valves are available, but no credit is taken for the pressurizer sprays.
- 4f. AFW is assumed to be manually actuated and the system manually aligned to deliver flow of 225 gpm to two steam generators 15 minutes after the initiation of the event (feedline break).
- 4g. The steam flow/feed flow mismatch reactor trip is assumed not available.
- 4h. The feedline break size is assumed to be 0.7854 ft<sup>2</sup>. All three steam generators depressurize since SONGS-1 does not have main steamline isolation valves.

RESULTS

CASE 1 Main Feedwater Line Break Upstream of In-Containment Check Valves at 100% Power

The results of the feedline break at full power located upstream of inside containment check valve transient are shown in Figures 1 through 4. The time sequence of events is presented in Table 2. Reactor trip is provided by the steam flow/feed flow mismatch signal. The results show that an AFW flow of 100 gpm initiated 30 minutes after the break is sufficient to remove core decay heat. Calculations of this case show that the core remained in a coolable geometry during this FLB scenario. The detailed calculations involved showing that the mass relieved through the pressurizer PORVs (between the time of initial relief through the PORVs and the time the PORVs reseal due to the heat removal capability of the AFW exceeding the core decay heat) was not sufficient to uncover the core. As such, the acceptance criterion for a FLB event that the core remains in a coolable geometry during the transient was shown to be met.

MADE BY R.A. [Signature] 3/23/90 CHECKED BY [Signature] DATE 5/9/95

SH. RS-500E 62  
DKH  
7/25/90  
P. HHT/199  
148 167

CASE 2 Main Feedwater Line Break Upstream of In-Containment Check Valves at 50% Power

The results of the feedline break at 50% power located upstream of inside containment check valve transient are shown in Figures 5 through 8. The time sequence of events is presented in Table 3. Reactor trip is provided by the high pressurizer water level (50% NRS) signal. The results show that an AFW flow of 100 gpm initiated 15 minutes after the break is sufficient to remove core decay heat. The reactor coolant system (RCS) remains subcooled and the pressurizer does not fill. Thus, the core remains covered with water. As such, the acceptance criterion for a FLB event that the core remains in a coolable geometry during the transient was shown to be met.

CASE 3 Main Feedwater Line Break Downstream of In-Containment Check Valves at 100% Power

The results of the feedline break at full power located downstream of inside containment check valve transient are shown in Figures 9 through 12. The time sequence of events is presented in Table 4. Reactor trip is provided by the steam flow/feed flow mismatch signal. The results show that an AFW flow of 225 gpm initiated 20 minutes after the break is sufficient to remove core decay heat. Calculations of this case show that the core remained in a coolable geometry during this FLB scenario. The detailed calculations involved showing that the mass relieved through the pressurizer PORVs (between the time of initial relief through the PORVs and the time the PORVs reseal due to the heat removal capability of the AFW exceeding the core decay heat) was not sufficient to uncover the core. As such, the acceptance criterion for a FLB event that the core remains in a coolable geometry during the transient was shown to be met.

CASE 4 Main Feedwater Line Break Downstream of In-Containment Check Valves at 50% Power

The results of the feedline break at full power located downstream of inside containment check valve transient are shown in Figures 13 through 16. The time sequence of events is presented in Table 5. Reactor trip is provided by the high pressurizer pressure signal. The results show that an AFW flow of 225 gpm initiated 15 minutes after the break is sufficient to remove core decay heat. Calculations of this case show that the core remained in a coolable geometry during this FLB scenario. The detailed calculations involved showing that the mass relieved through the pressurizer PORVs (between the time of initial relief through the PORVs and the time the PORVs reseal due to the heat removal capability of the AFW exceeding the core decay heat) was not sufficient to uncover the core. As such, the acceptance criterion for a FLB event that the core remains in a coolable geometry during the transient was shown to be met.

CONCLUSIONS

The reanalysis of the Rupture of a Main Feedwater Pipe supports SONGS 1 operation with the reduced AFW flows presented in Table 1. The reanalysis is applicable for SONGS 1 operation on both the Nominal Tavg Program and Reduced Tavg Program. The radiological consequences following a feedline break were not addressed in this safety evaluation.

MADE BY R.A. [Signature] 3/23/90  
CHECKED BY [Signature] DATE 5/9/90

Made By Ro-ff Date 5/8/90

SUPPL. B  
Calc No. DC2836 Rev: 0

Ckd By EP Date 5/9/90 Final Transmittal  
Preliminary

PA ; Sh R5-52 of 62

DKH  
7/25/90 P. 142-159  
149 167

SAN ONOFRE UNIT 1  
FEEDLINE BREAK REANALYSIS WITH REDUCED AUXILIARY FEED FLOW

BACKGROUND

Due to waterhammer concerns, Southern California Edison (SCE) is investigating possible modifications to the auxiliary feedwater (AFW) system. The potential modifications will reduce their (AFW) flow rates. SCE has requested Westinghouse to reanalyze the feedline break event to support the reduced AFW flows. The feedline break event is the only accident that was reanalyzed.

The previous analyses, documented in Reference 1, contains four cases. Breaks are assumed both upstream and downstream of the in-containment check valves initiated when operating at 100% and 50% of Rated Thermal Power. The analyses documented in this report model only breaks downstream of the in-containment check valves. The specific cases that are modeled for this analysis are as follows:

- Case 1 - Downstream FLB initiated at 103% power with 200 gpm AFW initiated 20 minutes after the break.
- Case 2 - Downstream FLB initiated at 53% power with 200 gpm AFW initiated 15 minutes after the break.
- Case 3 - Downstream FLB initiated at 103% power with 175 gpm AFW initiated 20 minutes after the break.
- Case 4 - Downstream FLB initiated at 53% power with 175 gpm AFW initiated 15 minutes after the break.
- Case 5 - Downstream FLB initiated at 53% power with 30 gpm AFW initiated 1 minute after the break and increased to 125 gpm 20 minutes after the break.

ATTACHMENT E  
(REF. 4)

Made By R.L.W.F. Date 5/8/90

Ckd By [Signature] Date 5/9/90

Document Transmittal

SUPL B  
Calc No. 022836 Rev. 0

Sh RS-53 of 62

DKH P. 438-159  
7/2/90 150/167

Westinghouse Proprietary Class 2  
Preliminary

**CASE 3 Main Feedwater Line Break Downstream of the In-Containment Check Valves at 100% Power with 175 gpm AFW**

The Case 3 FLB results are shown in Figures 9 through 12. The time sequence of events is presented in Table 4. Reactor trip is provided by the steam flow/feed flow mismatch signal. The results show that an AFW flow of 175 gpm initiated 20 minutes after the break is sufficient to remove core decay heat. Calculations show that the mass relieved through the pressurizer PORVs was not sufficient to uncover the core and thus, the core remained in a coolable geometry during this FLB scenario. As such, the acceptance criterion for a FLB event that the core remains in a coolable geometry during the transient was shown to be met.

**CASE 4 Main Feedwater Line Break Downstream of the In-Containment Check Valves at 50% Power with 175 gpm AFW**

The results of the Case 4 FLB are shown in Figures 13 through 16. The time sequence of events is presented in Table 5. Reactor trip is provided by the high pressurizer water level (50% NRS) signal. The results show that an AFW flow of 175 gpm initiated 15 minutes after the break is sufficient to remove core decay heat. Calculations show that the mass relieved through the pressurizer PORVs was not sufficient to uncover the core and thus, the core remained in a coolable geometry during this FLB scenario. As such, the acceptance criterion for a FLB event that the core remains in a coolable geometry during the transient was shown to be met.

ATTACHMENT E  
(REF. 4)









ATTACHMENT G  
(FROM REF. 2)

SUPPL. B TO  
DC 2836 REV. 0

SH 125-570 F 61

MADE BY R. A. [Signature] 3/23/90 CHECKED BY [Signature] DATE [Signature]

CASE 1-P.3

28	.00	15.00	41	42	43
29	.00	15.00	42	43	44
30	.00	21.70	44	45	46
31	.00	21.70	45	46	47
32	.00	31.50	47	48	
33	.00	18.10	34	35	49
34	.00	17.00	35	49	50
35	.00	23.15	50	51	
36	.00	23.15	51	52	

af613-88  
CALC NO. M-DC-2836  
P. 80 OF P. 125  
BY Mlocasio DATE 1-6-88  
CHK BY FA DATE 11/2/88

DKK  
7/25/90 P. 147/159  
157  
197

OUTPUT SELECTION: ALL RESULTS ARE OUTPUT EACH PERIOD

THIS SYSTEM HAS 52 PIPES WITH 33 JUNCTIONS , 11 LOOPS AND 9 FGNS

THE RESULTS ARE OBTAINED AFTER 4 TRIALS WITH AN ACCURACY = .00027

Pipe Network Test System  
AFW-G-10S IN OPERATION

CONTRACT NO. 468000

PIPE NO.	NODE NOS.	FLOWRATE	HEAD LOSS	PUMP HEAD	MINOR LOSS	VELOCITY	HL/1000
LINE 1	IS CLOSED						
2	2 11	.00	.00	.00	.00	.00	.00
3	11 0	.00	.00	.00	.00	.00	.00
4	2 3	.00	.00	.00	.00	.00	.00
5	3 4	.00	.00	.00	.00	.00	.00
THE CHECK VALVE IN LINE NUMBER 6 IS CLOSED							
THE CHECK VALVE IN LINE NUMBER 7 IS CLOSED							
THE CHECK VALVE IN LINE NUMBER 8 IS CLOSED							
9	5 6	131.13	3.70	.00	.00	5.68	39.38
10	6 7	65.56	13.75	.00	.00	2.84	10.72
11	6 7	65.56	13.75	.00	.00	2.84	10.72
12	7 8	131.13	3.07	.00	.00	5.68	39.38
13	8 9	131.13	.32	.00	1178.42	5.68	39.38
LINE 14	IS CLOSED						
15	9 10	131.13	4.02	.00	.00	5.68	39.38
16	10 0	131.13	.02	.00	.00	.56	.13
THE PUMP IN LINE 17 IS OPERATING OUT OF RANGE $Q_{max} = 405 \text{ gpm}$ (OK for 405.45)							
17	0 13	405.45	2.18	1296.30	.00	17.57	345.81
18	13 22	12.00	1248.93	.00	.00	4.44	94.95
19	22 0	12.00	4.48	.00	.00	1.89	11.38
20	13 14	393.45	47.62	.00	.00	17.05	326.15
21	14 15	393.45	18.15	.00	.00	9.90	81.38
22	15 16	131.14	.87	.00	.00	5.68	39.39
23	15 5	131.13	.52	.00	.00	3.65	13.02
24	15 27	131.19	.55	.00	.00	3.65	13.03
25	16 17	131.14	2.32	.00	.00	5.68	39.39
26	17 18	65.56	13.77	.00	.00	2.84	10.72
27	17 18	65.58	13.77	.00	.00	2.84	10.73
28	18 19	131.14	3.27	.00	.00	5.68	39.39
29	19 20	131.14	.32	.00	1178.61	5.68	39.39
LINE 30	IS CLOSED						
31	20 21	131.14	4.65	.00	.00	5.68	39.39
32	21 0	131.14	.02	.00	.00	.56	.13

ATTACHMENT G  
(FROM 126F2)

SUPPL. B TO  
DC2836 REV0

SH 125-58 F 62

MADE BY *W. A. ...* 3/23/90 CHECKED *Q* DATE *5/1/93*

CASE 1-P4

CALC NO. *10-DC-2836*

P. 21 OF P. 125

LINE	IS	CLOSED							
33	IS	CLOSED							
34	24	33	.00	.00	.00	.00	.00	.00	.00
35	IS	CLOSED							
36	24	25	.00	.00	.00	.00	.00	.00	.00
37	25	26	.00	.00	.00	.00	.00	.00	.00
THE CHECK VALVE IN LINE NUMBER			38	IS	CLOSED				
THE CHECK VALVE IN LINE NUMBER			39	IS	CLOSED				
THE CHECK VALVE IN LINE NUMBER			40	IS	CLOSED				
41	27	28	131.19	2.36	.00	.00	5.69	39.42	
42	28	29	65.59	13.76	.00	.00	2.84	10.73	
43	28	29	65.59	13.76	.00	.00	2.84	10.73	
44	29	30	131.19	3.19	.00	.00	5.69	39.42	
45	30	31	131.19	.32	.00	1179.43	5.69	39.42	
46	IS	CLOSED							
47	31	32	131.19	4.18	.00	.00	5.69	39.42	
48	32	0	131.19	.03	.00	.00	.56	.13	
49	33	34	.00	.00	.00	.00	.00	.00	
50	34	35	.00	.00	.00	.00	.00	.00	
51	35	36	.00	.00	.00	.00	.00	.00	
52	36	0	.00	.00	.00	.00	.00	.00	

BY *M...* DATE *1-6-88*  
CHK BY *FA* DATE *1/1/88*

JUNCTION NUMBER	DEMAND	GRADE LINE	ELEVATION	PRESSURE
2	.00	57.92	17.00	17.73
3	.00	57.92	16.00	18.17
4	.00	57.92	16.70	17.86
5	.00	1244.66	18.30	531.42
6	.00	1240.96	15.75	530.93
7	.00	1227.22	15.75	524.97
8	.00	1224.14	23.20	520.41
9	.00	45.40	23.20	9.62
10	.00	41.39	31.50	4.28
11	.00	57.92	21.80	15.65
13	.00	1310.95	16.80	560.80
14	.00	1263.33	16.80	540.16
15	.00	1245.18	16.70	532.34
16	.00	1244.32	15.00	532.70
17	.00	1241.99	15.00	531.70
18	.00	1228.23	15.00	525.73
19	.00	1224.96	22.40	521.11
20	.00	46.04	22.40	10.24
21	.00	41.39	31.50	4.28
22	.00	62.40	20.50	18.16
24	.00	57.92	18.80	16.95
25	.00	57.92	21.70	15.70
26	.00	57.92	22.70	15.26
27	.00	1244.64	16.70	532.11
28	.00	1242.27	15.00	531.82
29	.00	1228.52	15.00	525.86
30	.00	1225.32	21.70	521.57
31	.00	45.58	21.70	10.35
32	.00	41.40	31.50	4.29
33	.00	57.92	18.10	17.26
34	.00	57.92	17.00	17.73
35	.00	57.92	23.15	15.07
36	.00	57.92	23.15	15.07

*P. 118/159*  
*154/167*  
*155*  
*DKH 7/15/90*

THE NET SYSTEM DEMAND = .00

SUMMARY OF INFLOWS (+) AND OUTFLOWS (-) FROM FIXED GRADE NODES


ATTACHMENT G  
(FROM RGE. 2)

SUPPLY DC-2836 REV 0

SH 25-50 63

MADE BY BA. H 3/23/90 CHECKED BY [Signature] DATE 9/9/90

CASE 1-R6



02613-88  
 CALC NO. ~~MP-DC-2836 Rev~~  
 P. 83 OF P. 125  
 BY M.W. [Signature] DATE 1-6-88  
 CHK BY PAH DATE 1/12/88

DC4 7/25/90  
 P. [Signature]  
 156 167

ATTACHMENT H  
 G IOW CURVES  
 (FROM REF. 6)

- SUPPL. B DC-2836 REV 0

SH RS-60

MADE BY L.A. [Signature] 3/23/90 CHECKED BY [Signature]

DATE 5/9/90

20 Squares to the Inch

NOTE: BASED ON DESIGN PUMP CURVES




FIGURE 9

SUPPLEMENT A DC-2836 Rev. 0

RA [Signature] 3/23/90

REV 4  
 7/25/90 P. [Signature]  
 6/21/90 [Signature]

ATTACHMENT I SUPPL. B DC 2836  
(REF 6 CALC.)

SHRS-61 SE 62  
DKH  
7/25/90 P. 158  
159/167

MADE BY R.O. Luff 3/23/90

CHECKED BY [Signature] DATE 5/9/90

SHEET [Redacted] SHEETS

ENGINEERING DEPARTMENT

**CALCULATION SHEET**

ref 3/23/90

SUBJECT: SONGS 1 Hydraulic Calculation For AFW Lines - Flow Requirements

Supplement A  
CALC NO. 2836 RIV. 3

J.O. NO. [Redacted] MADE BY [Redacted]

$$Q_1 = \sqrt{\frac{Q_2^2 (\Delta P_1 - \Delta P_E)}{\Delta P_2 - \Delta P_E}}$$

From G10+G10S test data:

$Q_2 = \text{Total G10+G10S flow to S/G's} \div 3 \text{ S/G's}$

$Q_2 = 526 \text{ gpm} \div 3$

$Q_2 = 175.3 \text{ gpm}$

$\Delta P_2 = P_{\text{DISCHARGE}} - P_{\text{S/G}}$

$\Delta P_2 = 1030 \text{ psig} - 800 \text{ psig}$

$\Delta P_2 = 230 \text{ psig}$

$$Q_1 = \sqrt{\frac{(175.3)^2 (\Delta P_1 - \Delta P_E)}{230 - \Delta P_E}}$$

Loss due to elevation:

From Ref. 14, 17, 18, 19:  $Z_{\text{S/G}} = 41' - 4 \frac{7}{16}" = 41.37 \text{ ft}$

$Z_{\text{PUMP G10}} = 17' - 0" = 17.0 \text{ ft}$

$Z_{\text{PUMP G10S}} = 16' - 10" = 16.83 \text{ ft}$

For the largest difference in height, use elevation of Pump G10S.

$h_L = Z_{\text{S/G}} - Z_{\text{PUMP G10S}}$

$h_L = 41.37 \text{ ft} - 16.83 \text{ ft}$

$h_L = 24.54 \text{ ft}$

Eq. 7, 3-5:  $\Delta P_E = \frac{h_L \rho}{1.44}$

$\Delta P_E = \frac{24.54 \times 62.4}{1.44} = 10.62 \text{ psid}$



ATTACHMENT I  
(FROM REF. 6)

SUPPL. B DC 2836

SH. 25-62 AF 69

DKH

7/25/90 P.

158  
159  
159/167

MADE BY L.C. JH 3/23/90

CHECKED BY

DATE 5/9/90

ENGINEERING DEPARTMENT  
**CALCULATION SHEET**

Supplement A

SUBJECT: SONGS 1 Hydraulic Calculation For AFW Lines - Flow Requirements

J.O. NO. MAD

$$Q_1 = \sqrt{\frac{(175.3)^2 (\Delta P_1 - 10.62)}{230 - 10.62}}$$

Sample calculation:

$$Q_1 = \sqrt{\frac{(175.3)^2 (200 - 10.62)}{(230 - 10.62)}} = 162.87 \text{ GPM}$$

$$Q_T = 162.87 \times 3 = 488.6 \text{ TOTAL FLOW TO 3/G'S.}$$

Data to plot System Loss Curve - Refer to Figure 6:

<u>P<sub>1</sub> (psig)</u>	<u>Q<sub>1</sub> (gpm)</u>	<u>Q<sub>T</sub> (gpm)</u>
300	201.3	604.0
250	183.1	549.4
200	162.9	488.6
180	154.0	462.1
160	144.7	433.9
140	134.6	403.9
100	111.9	335.7
60	83.2	249.5
20	36.2	108.6
10.62	0	0

System curve can be validated with the G10 test data for FCV's fully open with S/G pressure at 800 psig. Refer to Figure 6 for test data points.