

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8207300359 DOC. DATE: 82/07/23 NOTARIZED: NO DOCKET #
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern California 05000361
 AUTH. NAME AUTHOR AFFILIATION
 DIETCH, R. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Forwards application for amend to License NPF-10, changing
 Tech Specs to extend surveillance interval for ESF actuation
 subgroup relays from 6-month to 18-month interval.

DISTRIBUTION CODE: 800IS COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1 + 16
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES: J Hanchett 1cy PDR Documents, ELD Chandler 1cy. 05000361
 NRR Scaletti 1cy. *w/check: \$1,200.00*

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL		RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	
	A/D LICENSNG	1	0	LIC BR #3 BC	1	0
	LIC BR #3 LA	1	0	ROOD, H. 01	1	1
INTERNAL:	ELD/HDS2	1	0	IE FILE	1	1
	IE/DEP EPDS 35	1	1	IE/DEP/EPLB 36	3	3
	NRR/DE/CEB 11	1	1	NRR/DE/EQB 13	3	3
	NRR/DE/GB 28	2	2	NRR/DE/HGEB 30	2	2
	NRR/DE/MEB 18	1	1	NRR/DE/MTEB 17	1	1
	NRR/DE/QAB 21	1	1	NRR/DE/SAB 24	1	1
	NRR/DE/SEB 25	1	1	NRR/DHFS/HFEB40	1	1
	NRR/DHFS/LQB 32	1	1	NRR/DHFS/OLB 34	1	1
	NRR/DHFS/PTRB20	1	1	NRR/DSI/AEB 26	1	1
	NRR/DSI/ASB 27	1	1	NRR/DSI/CPB 10	1	1
	NRR/DSI/CSB 09	1	1	NRR/DSI/ETSB 12	1	1
	NRR/DSI/ICSB 16	1	1	NRR/DSI/PSB 19	1	1
	NRR/DSI/RAB 22	1	1	NRR/DSI/RSB 23	1	1
	NRR/DST/LGB 33	1	1	REG FIL 04	1	1
	RGNS	2	2	RM/DDAMI/MIB	1	0
EXTERNAL:	ACRS 41	10	10	BNL (AMDTS ONLY)	1	1
	DMB/DSS (AMDTS)	1	1	FEMA-REP DIV 39	1	1
	LPDR 03	1	1	NRC PDR 02	1	1
	NSIC 05	1	1	NTIS	1	1
NOTES:		3	13			

TOTAL NUMBER OF COPIES REQUIRED: LTTR 61 ENCL 56

Southern California Edison Company



P. O. BOX 800

2244 WALNUT GROVE AVENUE

ROSEMEAD, CALIFORNIA 91770

ROBERT DIETCH
VICE PRESIDENT

July 23, 1982

TELEPHONE
213-572-4144

Mr. H. R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Gentlemen:

Subject: Docket No. 50-361
Amendment Application No. 8
San Onofre Nuclear Generating Station
Unit 2

Enclosed are three executed and thirty-seven conformed copies of Amendment Application No. 8 to Operating License NPF-10 for San Onofre Nuclear Generating Station, Unit 2. Amendment Application No. 8 consists of Proposed Change NPF-10-4 to Facility Operating License No. NPF-10, Technical Specifications incorporated as Appendix A.

Proposed Change NPF-10-4 is a request to extend the surveillance interval for the Engineered Safety Feature Actuation System subgroup relays from the present six month interval, as shown in Table 4.3-2 of the Technical Specifications, to an 18 month (refueling) interval.

It is respectfully requested that Amendment Application No. 8 be reviewed promptly and appropriate action taken. Direct distribution of Application No. 8 to Facility Operating License No. NPF-10 will be made in accordance with the service list provided by SCE's letter of March 30, 1982 to the Commission. An affidavit attesting to the fact that distribution has been completed will be submitted within ten days of amendment docketing.

The proposed change contained in Amendment Application No. 8 is considered to constitute a Class II amendment based on the determination that this change has no safety or environmental significance. Accordingly, enclosed is Southern California Edison Company's check in the amount of \$1,200.00 as required by 10 CFR 170.22.

Very truly yours,

Robert Dietch

Boo!

w/ check:

\$1200.00

Enclosure

8207300359 820723
PDR ADOCK 05000361
P PDR