REGULATOR NEORMATION DISTRIBUTION STEM (RIDS)

ACCESSION NBR:8209020297 DUC.DATE: 82/08/31 NOTARIZED: NO DOCKET # FACIL:50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361

AUTHOR AFFILIATION

DIETCH, H.R. Southern California Edison Co.

RECIP.NAME RECIPIENT AFFILIATION
DENTON,H.R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Forwards application to amend License NPF=10, Changing Tech Spec Table 3,3=13 to permit limited containment purging w/purge sys activity monitor 2RT=7804=1 inoperable.Class II amend fee encl.

DISTRIBUTION CODE: A034S COPIES RECEIVED:LTR _/ ENCL _/ SIZE: 2+//_TITLE: Containment Purging

NOTES: J Hanchett 1cy PDR Documents. ELD Chandler 1cy.
NRR Scaletti 1cy.

05000361

w/check \$1,200

	RECIPIENT ID CODE/NAME		COPIES		RECIPIENT		COPIES	
			LTTR ENCL		ID CODE/NAME		LTTR ENCL	
	LIC BR #3 BC	01	7	.7				
INTERNAL:	NRR FIELDS, M	15	1	1	NRR REEVES	E 14	1	1
	NRR/DE/EQB	09	1	1	NRR/DL/ORAI	3 10	1	1
	NRR/DSI/ADRS		1	.0	NRR/DSI/AEI	3	1	i
	NRR/DSI/CSB	12	1	1	NRR/DSI/ET	SB 08	1	1
	NRR/DSI/RAB	11	1	1	REG FIRE	04	1	1
	RGN5		1	1		•		
EXTERNAL:	ACRS	13	10	10	LPDR	03	1	1
	NRC PDR	02	1	1	NSIC	05	1	1
	NTIS		1	1				
NOTES:			3	3				

20

Southern California Edison Company



P. O. BOX 800

2244 WALNUT GROVE AVENUE ROSEMEAD, CALIFORNIA 91770 August 31, 1982

TELEPHONE 213-572-4144

Mr. H. R. Denton, Director Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, D. C. 20555

Gentlemen:

ROBERT DIETCH

VICE PRESIDENT

Subject: Docket No. 50-361

Amendment Application No. 10

San Onofre Nuclear Generating Station

Unit 2

Enclosed are three executed and thirty-seven conformed copies of Amendment Application No. 10 to Operating License NPF-10 for San Onofre Nuclear Generating Station, Unit 2. Amendment Application No. 10 consists of Proposed Change NPF-10-28 to Facility Operating License No. NPF-10, Technical Specifications incorporated as Appendix A.

Proposed Change NPF-10-28 is a request to revise Technical Specification 3.3.3.9, Table 3.3-13, RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION. The proposed change permits limited containment purging with the purge system activity monitor 2RT-7804-1 inoperable by providing alternate means of monitoring containment purge gaseous effluent activity.

By letter of August 5, 1982, SCE requested early approval of Proposed Change NPF-10-28 to allow containment purging to avoid a forced shutdown due to high containment pressure. On August 6, 1982 the NRC modified and approved a version of Proposed Change NPF-10-28 for 30 days. In accordance with SCE's August 5, 1982 letter, Proposed Change NPF-10-28 is hereby formally submitted as Amendment Application No. 10 to Operating License NPF-10.

It is respectfully requested that Amendment Application No. 10 be reviewed promptly and appropriate action taken. Direct distribution of Amendment Application No. 10 to Facility Operating License NPF-10 will be made in accordance with the service list provided in SCE's letter of August 2, 1982 to the Commission. An affidavit attesting to the fact that distribution has been completed will be submitted within ten days of amendment docketing.

Mr. H. R. Denton

-2- August 31, 1982

The proposed change contained in Amendment Application No. 10 is considered to constitute a Class II amendment based on the determination that this change has no safety or environmental significance. Accordingly, enclosed is Southern California Edison Company's check in the amount of \$1,200.00 as required by 10 CFR 170.22.

Very truly yours,

Label Label

Enclosure