

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8209090007. DOC. DATE: 82/09/07. NOTARIZED: NO DOCKET #: 05000361  
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern California  
 AUTH. NAME: BASKIN, K.P. AUTHOR AFFILIATION: Southern California Edison Co.  
 RECIP. NAME: MIRAGLIA, F. RECIPIENT AFFILIATION: Licensing Branch 3

SUBJECT: Forwards Proposed Change NPF-10-34 to License NPF-10 previously submitted as part of 820903 Amend Application 11. Change alters Tech Spec Table 2.2-1 & Pages 2-3 & 2-4, deleting ref to full differential pressure.

DISTRIBUTION CODE: 80015 COPIES RECEIVED: LITR 1 ENCL 1 SIZE: 1  
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: J Hanchett 1cv PDR Documents. ELD Chandler 1cv. 05000361  
 NRR Scaletti 1cv.

	RECIPIENT ID CODE/NAME	COPIES LITR ENCL	RECIPIENT ID CODE/NAME	COPIES LITR ENCL
	NRR/DL/ADL	1 0	NRR LB3 BC	1 0
	NRR LB3 LA	1 0	ROOD, H. 01	1 1
INTERNAL:	ELD/HDS2	1 0	IE FILE	1 1
	IE/DEP/EPDS 35	1 1	IE/DEP/EPLB 36	3 3
	NRR/DEVAEAB	1 0	NRR/DE/CEB 11	1 1
	NRR/DEVEQB 13	3 3	NRR/DE/VGB 28	2 2
	NRR/DEVHGB 30	2 2	NRR/DE/MEB 18	1 1
	NRR/DEVMTEB 17	1 1	NRR/DE/QAB 21	1 1
	NRR/DEVSAB 24	1 1	NRR/DE/SEB 25	1 1
	NRR/DHFS/HFEB 40	1 1	NRR/DHFS/LQB 32	1 1
	NRR/DHFS/OLB 34	1 1	NRR/DHFS/PTRB 20	1 1
	NRR/DSI/AEB 26	1 1	NRR/DSI/ASB 27	1 1
	NRR/DSI/CPB 10	1 1	NRR/DSI/CSB 09	1 1
	NRR/DSI/EISB 12	1 1	NRR/DSI/ICSB 16	1 1
	NRR/DSI/PSB 19	1 1	NRR/DSI/RAB 22	1 1
	NRR/DSI/RSB 23	1 1	NRR/DST/LGB 33	1 1
	<b>REG FILE</b> 04	1 1	RGNS	2 2
	RM/DDA/MI/MIB	1 0		
EXTERNAL:	ACRS 41	10 10	BNL (AMDTS ONLY)	1 1
	DMB/DSS (AMDTS)	1 1	FEMA-REP DIV 39	1 1
	LPDR 03	1 1	NRC PDR 02	1 1
	NSIC 05	1 1	NTIS	1 1
NOTES:		3 3		

RR

*Southern California Edison Company*



P. O. BOX 800  
2244 WALNUT GROVE AVENUE  
ROSEMEAD, CALIFORNIA 91770

September 7, 1982

TELEPHONE  
(213) 572-1401

K. P. BASKIN  
MANAGER OF NUCLEAR ENGINEERING,  
SAFETY, AND LICENSING

Director, Office of Nuclear Reactor Regulation  
Attention: Mr. Frank Miraglia, Branch Chief  
Licensing Branch No. 3  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Gentlemen:

Subject: Docket No. 50-361  
San Onofre Nuclear Generating Station  
Unit 2

Amendment Application No. 11 to Facility Operating License NPF-10 for San Onofre Nuclear Generating Station, Unit 2, was formally submitted to the NRC on September 3, 1982. Amendment Application No. 11 consisted of eight (8) proposed changes to Technical Specifications incorporated in Facility Operating License NPF-10 as Appendix A.

Enclosed you will find proposed change NPF-10-34, which was formally submitted as part of Amendment Application No. 11. NPF-10-34 is a change to Technical Specification 2.2.1, Table 2.2-1. It is requested that you please consider this change to be of emergency status and direct your attention to it as soon as possible. Proposed change to Technical Specification 2.2.1, Table 2.2-1, pages 2-3 and 2-4, deletes reference to percent of full differential pressure and inserts the actual instrument trip setpoints in psid.

If you have any questions or if I can be of any assistance to you concerning the enclosed information, please contact me.

Very truly yours,

*KP Baskin*

Enclosure

cc: Mr. H. Rood, Project Manager  
License Branch No. 3

Boo!

8209090007 820907  
PDR ADOCK 05000361  
PDR  
P

DESCRIPTION OF PROPOSED CHANGE NPF-10-34 AND SAFETY ANALYSIS  
AMENDMENT APPLICATION NO. 11 TO OPERATING LICENSE NPF-10

This is a request to revise Table 2.2-1 of Specification 2.2.1.

This Proposed Change, (1) deletes reference to percent of full differential pressure and inserts the actual instrument calibration values, and (2) reflects a recalculation of the instrument setpoints.

Existing Specification:

<u>Page</u>	<u>Functional Unit</u>	<u>Trip Setpoint</u>	<u>Allowable Value</u>
2-3	11. Reactor Coolant Flow-Low		
	a) DN Rate	< 0.3%/sec (6)(8)	< 0.315%/sec (6)(8)
	b) Floor	> 60% (6)(8)	> 55% (6)(8)
	c) Step	< 10% (6)(8)	< 13% (6)(8)

Page 2-4 (6) DN RATE, % of reference value, is the maximum decrease rate of the trip setpoint.

FLOOR, % of reference value, is the minimum value of the trip setpoint.

STEP, % of reference value, is the amount by which the trip setpoint is below the input signal unless limited by DN Rate or Floor. The reference value is that of the input signal at operating flow and coolant temperature.

Proposed Specifications:

11. Reactor Coolant Flow-Low

<u>Functional Unit</u>	<u>Trip Setpoint</u>	<u>Allowable Value</u>
a. DN Rate	< 0.22 psid/sec (6)(8)	< 0.231 psid/sec (6)(8)
b. Floor	> 13.2 psid (6)(8)	> 12.1 psid (6)(8)
c. Step	< 6.82 psid (6)(8)	< 7.231 psid (6)(8)

*PDR Dups #  
8209080546*

To be consistent with this change, Table Notation (6) for Table 2.2.1 and is to read as follows:

- (6) DN RATE, is the maximum decrease rate of the trip setpoint.
- FLOOR, is the minimum value of the trip setpoint.
- STEP, is the amount by which the trip setpoint is below the input signal unless limited by DN Rate or Floor.

Reason for Proposed Change:

This proposed change:

- (1) Allows easier setpoint verification as the instruments are set to the values actually shown in the Technical Specifications.
- (2) Modifies the setpoint values as the result of calculations performed during the startup program.

Safety Analysis:

These changes reflect a change from preliminary data to final data. The calculations have been verified in accordance with the procedures of the qualified and approved Q.A. Program.

Accordingly, it is concluded that: (1) Proposed Change NPF-10-34 does not present significant hazard considerations not described or implicit in the Final Safety Analysis; (2) there is reasonable assurance that the health and safety of the public will not be endangered by the proposed change; and (3) this action will not result in a condition which significantly alters the impact of the station on the environment as described in the NRC Final Environmental Statement.