

REGULATORY INFORMATION DISTRIBUTION SYSTEM (DS)

ACCESSION NBR: 8212030157 DOC. DATE: 82/12/01 NOTARIZED: NO DOCKET #  
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern California 05000361  
 AUTH. NAME AUTHOR AFFILIATION  
 DIETCH, R. Southern California Edison Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Forwards Amend Application 15 to License NPF-10, consisting of Proposed Changes 10 & 21. Changes would increase ESF response time limits for auxiliary feedwater delivery & minimize Tech Spec differences between units.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 40 SIZE: 1+103  
 TITLE: OR Submittal: General Distribution

NOTES: J Hanchett 1cy PDR Documents, ELD Chandler 1cy. 05000361  
 NRR Scaletti 1cy.

*W/ check \$1200.00*

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
	NRR LB3 BC 01	7	7			
INTERNAL:	ELD/HDS2	1	0	NRR/DL DIR	1	1
	NRR/DL/ORAB	1	0	NRR/DSI/RAB	1	1
	<u>REG FILE</u> 04	1	1	RGNS	1	1
EXTERNAL:	ACRS 09	6	6	LPDR 03	1	1
	NRC PDR 02	1	1	NSIC 05	1	1
	NTIS	1	1			
NOTES:		3	3			

*All Extras to NRR LB #3 BC*

Southern California Edison Company



P. O. BOX 800

2244 WALNUT GROVE AVENUE

ROSEMEAD, CALIFORNIA 91770

ROBERT DIETCH  
VICE PRESIDENT

December 1, 1982

TELEPHONE  
213-572-4144

Mr. H. R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Gentlemen:

Subject: Docket No. 50-361  
Amendment Application No. 15  
San Onofre Nuclear Generating Station  
Unit 2

Enclosed are three executed and forty conformed copies of Amendment Application No. 15 to Operating License NPF-10 for the San Onofre Nuclear Generating Station. Amendment Application No. 15 consists of Proposed Changes NPF-10-36 and NPF-10-51 to Facility Operating License No. NPF-10, Appendix A, Technical Specifications.

Proposed Change NPF-10-36 is a request to revise Technical Specifications 3.3.2 (Table 3.3-5) and 4.7.1.2.1.a. The proposed change increases the engineered safety feature response time limits for auxiliary feedwater delivery and identifies other identical response time requirements.

Proposed Change NPF-10-51 contains various changes to minimize differences between the Unit 2 and Unit 3 Technical Specifications.

It is respectfully requested that Amendment Application No. 15 be reviewed promptly and appropriate action taken. Direct distribution of Amendment Application No. 15 to the Facility Operating License No. NPF-10 will be made in accordance with the service list provided by SCE's letter of August 2, 1982 to the Commission. An affidavit attesting to the fact that distribution has been completed will be submitted within ten days of amendment docketing.

The proposed changes contained in Amendment Application No. 15 are considered to constitute a Class II amendment based on the determination that these changes have no safety or environmental significance. Accordingly, enclosed is Southern California Edison Company's check in the amount of \$1,200.00 as required by 10 CFR 170.22.

Very truly yours,

*Robert Dietch*

A001  
s  
1/40  
w/ck: \$1200.00

8212030157 821201  
PDR ADOCK 05000361  
P PDR

Enclosures

cc: H. Rood, Project Manager  
Licensing Branch No. 3, NRC