

NPF-10-55

ATTACHMENT A

8212070193 821203  
PDR ADOCK 05000361  
P PDR

## INSTRUMENTATION

### 3/4.3.4 TURBINE OVERSPEED PROTECTION

#### LIMITING CONDITION FOR OPERATION

---

3.3.4 At least one turbine overspeed protection system shall be OPERABLE.

APPLICABILITY: MODES 1, 2\* and 3.\*

#### ACTION:

- a. With one stop valve or one control valve per high pressure turbine steam lead inoperable and/or with one reheat stop valve or one reheat intercept valve per low pressure turbine steam lead inoperable, restore the inoperable valve(s) to OPERABLE status within 72 hours, or close at least one valve in the affected steam lead or isolate the turbine from the steam supply within the next 6 hours.
- b. With the above required turbine overspeed protection system otherwise inoperable, within 6 hours isolate the turbine from the steam supply.

#### SURVEILLANCE REQUIREMENTS

---

4.3.4.1 The provisions of Specification 4.0.4 are not applicable.

4.3.4.2 The above required turbine overspeed protection system shall be demonstrated OPERABLE:

- a. At least once per 7 days by cycling each of the following valves through at least one complete cycle from the running position.
  1. Four high pressure turbine stop valves.
  2. Four high pressure turbine control valves.
  3. Six low pressure turbine reheat stop valves.
  4. Six low pressure turbine reheat intercept valves.
- b. At least once per 31 days by direct observation of the movement of each of the above valves through one complete cycle from the running position.
- c. At least once per 18 months by performance of a CHANNEL CALIBRATION on the turbine overspeed protection systems.
- d. At least once per 40 months by disassembling at least one of each of the above valves and performing a visual and surface inspection of valve seats, disks and stems and verifying no unacceptable flaws or corrosion.

---

\*With any main steam line isolation valve and/or any main steam line isolation valve bypass valve not fully closed.

NPF-10-55

ATTACHMENT B

## INSTRUMENTATION

### 3/4.3.4 TURBINE OVERSPEED PROTECTION

#### LIMITING CONDITION FOR OPERATION

---

3.3.4 At least one turbine overspeed protection system shall be OPERABLE.

APPLICABILITY: MODES 1, 2\* and 3.\*

#### ACTION:

- a. With one stop valve or one control valve per high pressure turbine steam lead inoperable and/or with one reheat stop valve or one reheat intercept valve per low pressure turbine steam lead inoperable, restore the inoperable valve(s) to OPERABLE status within 72 hours, or close at least one valve in the affected steam lead\* or isolate the turbine from the steam supply within the next 6 hours.
- b. With the above required turbine overspeed protection system otherwise inoperable, within 6 hours isolate the turbine from the steam supply.
- c. The provisions of specification 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.3.4.1 The provisions of Specification 4.0.4 are not applicable.

4.3.4.2 The above required turbine overspeed protection system shall be demonstrated OPERABLE:

- a. At least once per 7 days by cycling each of the following valves through at least one complete cycle from the running position.
  1. Four high pressure turbine stop valves.
  2. Four high pressure turbine control valves.
  3. Six low pressure turbine reheat stop valves.
  4. Six low pressure turbine reheat intercept valves.
- b. At least once per 31 days by direct observation of the movement of each of the above valves through one complete cycle from the running position.
- c. At least once per 18 months by performance of a CHANNEL CALIBRATION on the turbine overspeed protection systems.
- d. At least once per 40 months by disassembling at least one of each of the above valves and performing a visual and surface inspection of valve seats, disks and stems and verifying no unacceptable flaws or corrosion.

---

\*With any main steam line isolation valve and/or any main steam line isolation valve bypass valve not fully closed.

\*\* For performance of surveillance testing of the valves in the unaffected low pressure turbine steam lead the valve or valves closed in an affected low pressure turbine steam lead may be re-opened following successful completion of surveillance testing of that valve in accordance with 4.3.4.2a. for a period not to exceed one hour.