## REGULATORY TORMATION DISTRIBUTION SYSTEM (RIDS

ACCESSION NBR:8212230325 DOC.DATE: 82/12/21 NOTARIZED: NO DOCKET # FACIL:50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361

AUTHOR AFFILIATION

BASKIN, K.P. Southern California Edison Co.

RECIP.NAME RECIPIENT AFFILIATION KNIGHTON, G.W. Licensing Branch 3

SUBJECT: Supple 821220 ltr re proposed change to License NPF=10. Component coaling water sys adequate simultaneously serve all essential & nonessential loads except shutdown coaling HX.Safety analyses not affected by change.

DISTRIBUTION CODE: BOOIS COPIES RECEIVED:LTR ENCL SIZE: \_\_\_\_\_\_\_
TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: J Hanchett 1cy PDR Documents. ELD Chandler 1cy.
NRR Scaletti 1cy.

05000361

	RECIPIENT COPIES		ES	RECIPIENT	COPIES
	ID CODE/NAME	LTTR	ENCL	ID CODE/NAME	LTTR ENCL
	NRR/DL/ADL	1	. 0	NRR LB3 BC	1 0
	NRR LB3 LA	1	0	ROOD, H. 01	1 1
INTERNAL:	ELD/HDS2	1	. 0	IE FILE	1 1
	IE/DEP EPDS 35	1	1	IE/DEP/EPLB 36	3 3
	NRR/DE/AEAB	1	0	NRR/DE/CEB - 11	1 1
	NRR/DE/EQB 13	2	2	NRR/DE/GB 28	5 2
	NRR/DE/HGEB 30	1	1,	NRR/DE/MEB 18	1 1
	NRR/DE/MTEB 17	1	1	NRR/DE/QAB 21	1 1
	NRR/DE/SAB 24	i	1	NRR/DE/SEB 25	1 1
	NRR/DHFS/HFEB40	1	1	NRR/DHFS/LQB 32	1 1
	NRR/DHFS/OLB 34	1	1	NRR/DL/SSPB	1 0
	NRR/DSI/AEB 26	1	1	NRR/DSI/CPB 10	1 1
	NRR/DSI/CSB 09	1	1	NRR/DSI/ICSB 16	1 1
	NRR/DSI/METB 12	1	1	NRR/DSI/PSB 19	1 1
	NRRADSIARAB 22	1	1	NRR/DSI/RSB 23	1 1
	REG FILE 04	i	1	RGN5	3 3
	RM/DDAMI/MIB	1	0	, "	·
EXTERNAL:	ACRS 41	6	6	BNL (AMDTS ONLY)	1 1
	DMB/DSS (AMDTS)	1	1	FEMA-REP DIV 39	1 1
	LPDR 03	1	1	NRC PDR 02	1 1
	NSIC 05	1	1	NTIS	1 1
NOTES:		3	-3		

## Southern California Edison Company



P. O. BOX 800 2244 WALNUT GROVE AVENUE ROSEMEAD. CALIFORNIA 91770

K. P. BASKIN

MANAGER OF NUCLEAR ENGINEERING,

SAFETY, AND LICENSING

December 21, 1982

TELEPHONE (213) 572-1401

Director, Office of Nuclear Reactor Regulation Attention: Mr. George W. Knighton, Branch Chief Licensing Branch No. 3 U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Gentlemen:

Subject: Docket No. 50-361

San Onofre Nuclear Generating Station

Unit 2

The purpose of this letter is to supplement SCE's letter to the NRC of December 20, 1982 concerning proposed change NPF-10-60 to Operating License NPF-10. The supplementary information covers two areas: (1) review of the FSAR Chapter 15 Safety Analyses and (2) Analyses of Component Cooling Water(CCW) System Heat Loads.

The Chapter 15 Safety Analyses have been reviewed to assess the impact of the subject design change. The result of this assessment is that the safety analyses are not impacted by the proposed change. A more detailed discussion of this review will be provided during the week of January 17, 1983.

The CCW System design has been reviewed and has been verified that flow and heat capacity are adequate to simultaneously serve all essential and non-essential loads with the exception of the Shutdown Cooling Heat Exchanger(SDCHX). The SDCHX are isolated until they receive Containment Spray Actuation Signal at approximately 16 psig containment pressure

Because the proposed signal to isolate the essential from the non-essential loads occurs at approximately 3 psig containment pressure (on Containment Isolation Actuation Signal), the CCW system capacity will not be exceeded.

If you have any questions concerning the above information, please call me.

Very truly yours,

WP Basken

Bool

cc: Harry Rood, NRC(to be opened by addressee only)

8212230325 821221 PDR ADDCK 05000361 P PDR