

ArevaEPRDCPEm Resource

From: Miernicki, Michael
Sent: Wednesday, November 06, 2013 9:35 AM
To: 'usepr@areva.com' (usepr@areva.com)
Cc: Le, Hien; McKenna, Eileen; Segala, John; Hearn, Peter; Gleaves, Bill; ArevaEPRDCPEm Resource
Subject: US EPR DC FINAL RAI 607, Chapter 16, Technical Specifications
Attachments: Final RAI 607_BPTS_7246.docx

Attached please find subject request for additional information (RAI). A draft RAI was provided to you on October 22, 2013. On November 1, 2013, AREVA informed us that, the RAI is clear and does not contain proprietary information and that no further clarification is needed.

The schedule we have established for review of your application assumes technically correct and complete responses within 30 days of receipt of RAIs,. For any RAIs that cannot be answered **within 30 days or December 6, 2013**, it is expected that a date for receipt of this information will be provided to the staff within the 30-day period so that the staff can assess how this information will impact the published schedule.

Thank you,

Mike

Michael J. Miernicki
Sr. Project Manager
NRC/NRO/DNRL/LB1
301-415-2304

Hearing Identifier: AREVA_EPR_DC_RAIs
Email Number: 4717

Mail Envelope Properties (9C2386A0C0BC584684916F7A0482B6CAF320C139A0)

Subject: US EPR DC FINAL RAI 607, Chapter 16, Technical Specifications
Sent Date: 11/6/2013 9:35:06 AM
Received Date: 11/6/2013 9:35:12 AM
From: Miernicki, Michael

Created By: Michael.Miernicki@nrc.gov

Recipients:

"Le, Hien" <Hien.Le@nrc.gov>
Tracking Status: None
"McKenna, Eileen" <Eileen.McKenna@nrc.gov>
Tracking Status: None
"Segala, John" <John.Segala@nrc.gov>
Tracking Status: None
"Hearn, Peter" <Peter.Hearn@nrc.gov>
Tracking Status: None
"Gleaves, Bill" <Bill.Gleaves@nrc.gov>
Tracking Status: None
"ArevaEPRDCPEm Resource" <ArevaEPRDCPEm.Resource@nrc.gov>
Tracking Status: None
"usepr@areva.com" (usepr@areva.com) <usepr@areva.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	838	11/6/2013 9:35:12 AM
Final RAI 607_BPTS_7246.docx		30238

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information 607

Issue Date: 11/06/2013

Application Title: U. S. EPR Standard Design Certification - Docket Number 52-020

Operating Company: AREVA NP Inc.

Docket No. 52-020

Review Section: 16 - Technical Specifications

Application Section:

QUESTIONS

16-325

Upon review of Revision 5 of the U.S. EPR Tier 2, FSAR, Chapter 16, "Technical Specifications (TS)," the following item was developed to address proposed changes to the EPR TS and Bases without citing a source document which can be used to support these changes:

- Page 3.5.5-1: A new Required Action D.2.2 is added to LCO 3.5.5, "Extra Borating System," without a discussion being added in the associated bases. Also this item is not listed in the Table of "Summary of Changes for Rev. 5," so the staff cannot tell what initiates the changes. The applicant is requested to provide a justification for these changes and revise the associated bases to include a discussion of Action D.2.2 accordingly.