

Southern California Edison Company



P. O. BOX 800  
2244 WALNUT GROVE AVENUE  
ROSEMEAD, CALIFORNIA 91770

K. P. BASKIN  
MANAGER OF NUCLEAR ENGINEERING,  
SAFETY, AND LICENSING

July 22, 1983

TELEPHONE  
(213) 572-1401

Director, Office of Nuclear Reactor Regulation  
Attention: Mr. D. G. Eisenhut, Director  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Gentlemen:

Subject: EOF Ventilation System  
Docket Nos. 50-206, 50-361 and 50-362  
San Onofre Nuclear Generating Station  
Units 1, 2 and 3

In response to recent statements by the staff of the Nuclear Regulatory Commission (NRC) requiring the capability to isolate the ventilation system for the Emergency Operations Facility (EOF) at San Onofre Nuclear Generating Station (SONGS), Southern California Edison Company (SCE) has reviewed the EOF ventilation system design. As a result of the review, SCE has concluded that certain modifications are necessary to assure that the EOF ventilation system can be isolated. The modifications involve the installation of isolation dampers on all HVAC penetrations into the EOF. SCE is proceeding with the modifications and these modifications will be completed and associated procedures issued by January 1, 1984.

As a result of SCE's review of the EOF ventilation system design, SCE has identified a potential problem with air leakage from EOF equipment rooms, such as the diesel generator room. The significance of these leaks is unknown at this time. If it is determined necessary, SCE will correct the problem in an expeditious manner.

If you have any questions, please call me.

Very truly yours,

cc: D. M. Crutchfield - NRC  
G. W. Knighton - NRC  
H. Rood - NRC (to be opened by addressee only)  
A. E. Chaffee - Resident Inspector - SONGS 2&3

8307260135 830722  
PDR ADDCK 05000206  
F PDR

B021  
1/0