REGULATORY STAFORMATION DISTRIBUTION SYSTEM (RIDS)

				1						
ACCESSIO	N NBR: 840904	0121	DOC.	DATE:	84/08/29	NOTARIZE	D: NO		DOCKET #	,
FACIL:5	0=206 San On	ofre h	iuclear	Stati	on, Unit	1, Southe	rn≕Cali	forn	05000206	
AUTH N	AME A	UTHOR	AFFILI	ATION						、 ·
MEDFORD	,M.O. So	utherr	n-Calif	ornia.	Edison C	0.				
	VAME R									
PAULSON,W.A. Operating Reactors Branch						5				
SUBJECT	: Forwards a SEP Topic of safe sh of vent st	III=6, utdowr	Sample Pipin	calcu g & re	lations sults of	reseismic seismic e	evalua aualuati	itjon -		;
			· ·		De	R repi		21	0.11	· 15'
DISTRIB	UTION CODE:	DBSOA	COPIE	S RECE	IVED LTR	_ ENCL	SIZE	<u>.9</u> 2	0+11	Ì
TITLE:	OR Submittal	: SEP	Seismi	c Revi	ew					
					١				an a	
	Hanchett 1c L:03/27/67	y PDR	Docume	nts. N	IRR/DL/SE	P 1cy.			05000206	
	RECIPIENT ID CODE/NAME		COPIES		RECIPIENT		COPIES			
			LTTR				LTTR ENCL			
	NRR ORBS BC	Por la construction de la constr	3	2.14 C La		DET MARIE				
	NNN ORDS UC	V 🛉	.	, ,						
INTERNAL:	ADMZI EMB		4 .	4	ELD/HD	82	1	ħ		
714 MIX1016 1	NRR ADL ASEPB	14	1	:1-		/TAPMG	1	6		
	REG FILE	04	1	1.	RGNS		1.	Ţ		
			•	i •			*	1		
EXTERNAL:	ACRS	20	. 6	i b	LPDR	03	1	1.		
······	NRC PDR	02	1	1.	NTIS	11	1	í.		
		* **	•	فيهنا		* *	•			
NOTES:			2	* k	_]					
,				-						

ENCL

Limited Dist.

1.

TOTAL NUMBER OF COPIES REQUIRED: LTTR 20

50° [8408230178] 8/21/84 49 5091 -1 49.5090 - 1 -2 495088 - 1 -2

Southern California Edison Company

P. O. BOX 800 2244 WALNUT GROVE AVENUE ROSEMEAD, CALIFORNIA 91770

M.O. MEDFORD MANAGER, NUCLEAR LICENSING

August 29, 1984

TELEPHONE

(213) 572-1749

Director, Office of Nuclear Reactor Regulation Attention: Mr. W. A. Paulson, Acting Chief Operating Reactors Branch No. 5 Division of Licensing U. S. Nuclear Regulatory Commission Washington, D.C. 20555

Gentlemen:

Subject: Docket No. 50-206 SEP Topic III-6 Seismic Design Considerations San Onofre Nuclear Generating Station Unit 1

The purpose of this letter is to provide additional information requested by the NRC relating to the seismic reevaluation program for San Onofre Unit 1. Two reports are provided and include: (1) sample calculations relating to seismic evaluation of safe shutdown piping and (2) results of the seismic evaluation of the vent stack.

Enclosure 1 provides three sample calculations performed on the main feedwater piping. These sample calculations are FW-04, "Safe Shutdown Piping Functionality Assessment," SUP-FW-04-01, "Pipe Support Evaluation for Pipe Functionality" and SUP-FW-04-02, "Pipe Support Capacity Calculations." These calculations were performed to demonstrate the functionality of the main feedwater piping system as part of the San Onofre Unit 1 seismic return to service program. As shown in SUP-FW-04-01, an iterative quasi-linear analysis procedure was used to demonstrate the functionality of the piping considering variation in the support stiffnesses due to yielding of structural steel members. This is equivalent to performing a non-linear analysis, accounting for the non-linear load-deflection behavior of the structural steel loaded beyond elastic limits. The calculation iterations are provided as the appendices of SUP-FW-04-01.

Enclosure 2 provides a report entitled "Vent Stack Seismic Evaluation, San Onofre Nuclear Generating Station, Unit 1," dated August 14, 1984. This report provides an evaluation of the San Onofre Unit 1 vent stack and demonstrates that the vent stack will retain its design function following the occurrence of a 0.67g Design Basis Earthquake using the SONGS 1 Balance of Plant Structures Seismic Reevaluation Criteria.

If you have any questions regarding this information, please call me.

Very truly yours,

manedfin

Enclosures

7040121_8408 AD0CK_05000

. .

. .

. .

·

ENCLOSURE 1

.

.