## Southern California Edison Company

P. O. BOX 800 2244 WALNUT GROVE AVENUE ROSEMEAD, CALIFORNIA 91770

JACK B. MOORE

## August 6, 1979

Mr. R. H. Engelken, Director Office of Inspection and Enforcement U. S. Nuclear Regulatory Commission Region V Suite 202, Walnut Creek Plaza 1990 North California Boulevard Walnut Creek, California 94596

Dear Mr. Engelken:

Subject: Docket Nos. 50-361 and 50-362 San Onofre Nuclear Generating Station, Units 2 and 3

In a letter to your office dated April 9, 1979, we submitted a final report dealing with staking of Limitorque valve operators. The conditions described in the report were considered reportable in accordance with 10CFR50.55(e).

We would like to clarify one area of our initial In that report, we indicated that ninety-six (96) report. valves procured for use at San Onofre Units 2 and 3 with Limitorque operators were being inspected for proper staking of lock nuts. This quantity of valves included only valves which had been delivered at the time the report was submitted. A further review of valves in manufacturing or in transit indicated that an additional quantity of valves was involved in the investigation. Accordingly, we hereby amend our previous report to indicate that two hundred and forty-eight (248) valves will require inspection for proper staking of lock nuts. Inspection is being performed as valves become available for inspection at the jobsite. All valves which have been identified as requiring inspection will be inspected and reworked. if necessary, before turnover from Construction to Startup.

TELEPHONE 213-572-2292

79091002-33

79-114



Mr. R. H. Engelken

-2-

August 6, 1979

If you have any questions regarding our initial report or the supplemental information provided above, we would be pleased to discuss this matter with you at your convenience.

Very truly yours, Amour

cc: Victor Stello (NRC, Director I&E)
R. J. Pate (NRC, San Onofre)