GULATORY INFORMATION DISTRACTION SYSTEM (RIDS)

DOC. DATE: 87/08/18 NOTARIZED: NO ACCESSION NBR: 8709030168

FACIL: 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ

AUTH, NAME

AUTHOR AFFILIATION

MORGAN, H. E.

Southern California Edison Co.

RECIPIENT AFFILIATION RECIP. NAME

Document Control Branch (Document Control Desk)

SUBJECT: Special rept: on 870804, condenser evacuation sys wide range noble gas monitor out of svc greater than 72 h. Caused by failure of low/mid range sample timer, readout display & low

range indication recorder Recorder & timer repaired.

DISTRIBUTION CODE: 1E22D COPIES RECEIVED: LTR _ ENCL (TITLE: 50.73 Licensee Event Report (LER), Incident Rpt, etc.

NOTES: ELD Chandler 1cy.

05000362

DOCKET #

05000362

	RECIPIENT		COPIES	RECIPIENT	COPIES	
	ID CODE/NAME		LTTR ENCL	ID CODE/NAME	LTTR	ENCL
	PD5 LA		1 1	PD5 PD	i	1
	ROOD, H		i			
INTERNAL:	ACRS MICHELSON		1 1	ACRS MOELLER	2	4
	AEOD/DOA		· i 🖠	AEOD/DSP/NAS	1	1
	AEOD/DSP/ROAB		2 2	AEOD/DSP/TPAB	1	1
•	DEDRO		1	NRR/DEST/ADS	1	ď
	NRR/DEST/CEB		1 d	NRR/DEST/ELB	1	- 1
	NRR/DEST/ICSB		1	NRR/DEST/MEB	i	L
	NRR/DEST/MTB		1	NRR/DEST/PSB	1	1
	NRR/DEST/RSB		1	NRR/DEST/SGB	1	1
	NRR/DLPG/HFB		1	NRR/DLPQ/QAB	i	i
	NRR/DOEA/EAB		i	NRR/DREP/RAB	1	1
	NRR/DREE/RPB		5 5	NRR/PMAS/ILRB	1	1
	REG PILE 02	,	1 1	RES DEPY GI	. 1	i
	RES TELFORD; U		1 1	RES/DE/EIB	1	<u>l</u>
	RGN5 FILE 01		1			
						1
EXTERNAL:	EG&G GROH, M		5 3	H ST LOBBY WARD	1	- 1
	LPDR		1 1	NRC PDR	: 1	- 1
	NSIC HARRIS, J		1 1	NSIC MAYS, G	1	ł
NOTES:	•		1 \		•	,,

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P. O. BOX 1:28

SAN CLEMENTE, CALIFORNIA 92672

H. E. MORGAN STATION MANAGER TELEPHONE (714) 368-6241

August 18, 1987

U. S. Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555

Subject:

Docket No. 50-362

Special Report

San Onofre Nuclear Generating Station, Unit 3

In accordance with Technical Specification 3.3.3.1, Table 3.3-6, Action Statement 19, of Facility Operating License No. NPF-15 for San Onofre Nuclear Generating Station, Unit 3, this letter provides the required Special Report for a Condenser Evacuation System Wide Range Noble Gas Monitor being out of service greater than 72 hours.

On 8/04/87, at 1345, with Unit 3 at 100% power, the Condenser Evacuation System Wide Range Noble Gas Monitor 3RI-7870 was removed from service for the performance of the quarterly functional test required by Technical Specification Table 4.4-3. Since redundant monitor 3RI-7818 was inoperable, Action Statements 36, 37 & 40 of Limiting Condition for Operation (LCO) 3.3.3.9 were implemented upon removal of 3RI-7870 from service. These action requirements constitute the preplanned alternate method of monitoring required by LCO 3.3.3.1 Action Statement 19.

During the performance of the quarterly functional test it was identified that the low\mid range grab sample timer, the readout display and the low range indication recorder had failed to operate satisfactorily. Following repair of both the recorder and the grab sample timer, and replacement of the readout display power supply, the monitor was properly aligned at 0810 on 8/10/87 and the quarterly functional test was satisfactorily completed.

Since the preplanned alternate method of monitoring noble gas at the condenser evacuation system discharge was implemented during the period the monitor was not performing its function, the health and safety of the plant personnel or the public was not affected by this equipment failure.

Please contact us if we can be of further assistance.

Sincerely,

115 Mas

- cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)
 - J. B. Martin (Regional Administrator, USNRC Region V)
 Institute of Nuclear Power Operations (INPO)