

UNITED STATES NUCLEAR REGULATORY COMMISSION
SOUTHERN CALIFORNIA EDISON COMPANY, ET AL.

DOCKET NO. 50-206

NOTICE OF ISSUANCE OF AMENDMENT TO
PROVISIONAL OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (Commission) has issued Amendment No. 122 to Provisional Operating License No. DPR-13, issued to Southern California Edison Company and San Diego Gas and Electric Company (the Licensee), which revised the Technical Specifications for operation of the San Onofre Nuclear Generating Station, Unit No. 1, located in San Diego County, California. The amendment was effective as of the date of issuance.

The amendment approves the revised safety analysis for (1) an increase in steam generator tube plugging from 15% to 20%, including reanalysis of a Loss-of-Coolant-Accident, (2) the reactor coolant pump locked rotor and shaft break, and (3) an additional time delay and revised boron concentration in the safety injection lines.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations. The Commission has made appropriate findings as required by the Act and the Commission's regulations in 10 CFR Chapter 1, which are set forth in the license amendment.

Notice of Consideration of Issuance of Amendment and Opportunity for Hearing in connection with this action was published in the FEDERAL REGISTER on January 23, 1989 (54 FR 319). No request for a hearing or petition for leave to intervene was filed following this notice.

8904280293 890414
PDR ADOCK 05000206
P PDC

50-206 SANONOFRE, UNIT I SCE
CONSTRUCTION PERMIT & LICENSE
JAN 1989 thru 7/3/89

The Commission has prepared an Environmental Assessment related to this action and has concluded that an environmental impact statement need not be prepared because operation of the facility in accordance with this amendment will have no significant adverse effect on the quality of the human environment.

For further details with respect to the action see (1) the application for amendment dated January 11, 1989, as supplemented January 27, March 4 and 11, and April 1, 1989, (2) Amendment No. 122 to License No. DPR-13, (3) the Commission's related Safety Evaluation and (4) the Commission's Environmental Assessment. All of these items are available for public inspection at the Commission's Public Document Room, 2120 L Street, NW., Washington, DC 20555, and at the General Library, University of California, P.O. Box 19557, Irvine, California 92713. A copy of items (2), (3) and (4) may be obtained upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Director: Director, Division of Reactor Projects - III, IV, V and Special Projects.

Dated at Rockville, Maryland this 14th day of April, 1989.

FOR THE NUCLEAR REGULATORY COMMISSION

Charles M. Trammell

Charles M. Trammell, Senior Project Manager
Project Directorate V
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation