

May 10, 1989

Docket No.: 50-206

DISTRIBUTION

Docket File
NRC & LPDRs
CTrammell (2)
MVirgilio
JLee
OGC-White Flint
PD5 Plant File
EJordan
BGrimes
THuang
TCollins
WHodges

Mr. Kenneth P. Baskin
Vice President
Southern California Edison Company
2244 Walnut Grove Avenue
Post Office Box 800
Rosemead, California 91770

Dear Mr. Baskin:

SUBJECT: ORDER FOR MODIFICATION OF LICENSE - INADEQUATE CORE COOLING
INSTRUMENTATION SYSTEM (TAC NO. 45171)

Re: San Onofre Nuclear Generating Station, Unit No. 1

The Commission has issued the enclosed Order for Modification of License for San Onofre Nuclear Generating Station, Unit No. 1, which requires full compliance with Generic Letter 82-28, "Inadequate Core Cooling Instrumentation System," including the addition of a reactor water level monitor.

A copy of this Order is being filed with the Office of the Federal Register for publication.

Sincerely,

s/

George W. Knighton, Director
Project Directorate V
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosure:
Order

cc: w/enclosure:
See next page

*See previous concurrence

*C/P-3
ent*

FC	:DRSP/PD5*	:DRSP/PD5*	:NRR/SRXB*	:OGC*	:NRR/ADS*	:NRR/ADT*	:DRSP/D:PD5*:
AME	:JLee	:CTrammell	:dr:WHodges	:LChandler	:ATHadani	:FMiraglia	:GKnighton
ATE	:10/17/88	:10/18/88	:10/18/88	:4/26/89	:2/13/89	:2/21/89	:2/22/89

FC	:NRR/AD:DRSP*	:NRR/AD:DRP	:NRR/ADP	:DDONRR	:DONRR:
AME	:MVirgilio	:GHolahan	:JParton	:JSniezek:	:Murley
ATE	:4/28/89	:5/15/89	:5/18/89	:1/89	:5/10/89

5/4#1

OFFICIAL RECORD COPY

8905190121	890510
FDR	ADOCK 05000206
F	FDC

DF01
1/1



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

May 10, 1989

Docket No.: 50-206

Mr. Kenneth P. Baskin
Vice President
Southern California Edison Company
2244 Walnut Grove Avenue
Post Office Box 800
Rosemead, California 91770

Dear Mr. Baskin:

SUBJECT: ORDER FOR MODIFICATION OF LICENSE - INADEQUATE CORE COOLING
INSTRUMENTATION SYSTEM (TAC NO. 45171)

Re: San Onofre Nuclear Generating Station, Unit No. 1

The Commission has issued the enclosed Order for Modification of License for San Onofre Nuclear Generating Station, Unit No. 1, which requires full compliance with Generic Letter 82-28, "Inadequate Core Cooling Instrumentation System," including the addition of a reactor water level monitor.

A copy of this Order is being filed with the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in cursive script, reading "George W. Knighton".

George W. Knighton, Director
Project Directorate V
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosure:
Order

cc: w/enclosure:
See next page

Mr. Kenneth P. Baskin
Southern California Edison Company

San Onofre Nuclear Generating
Station, Unit No. 1

cc
Charles R. Kocher, Assistant
General Counsel
James Beoletto, Esquire
Southern California Edison Company
Post Office Box 800
Rosemead, California 91770

Mr. Jack McGurk, Acting Chief
Radiological Health Branch
State Department of Health
Services
714 P Street, Office Bldg. 8
Sacramento, California 95814

David R. Pigott
Orrick, Herrington & Sutcliffe
600 Montgomery Street
San Francisco, California 94111

Mr. Hans Kaspar, Executive Director
Marine Review Committee, Inc.
531 Encinitas Boulevard, Suite 105
Encinitas, California 92024

Mr. Robert G. Lacy
Manager, Nuclear
San Diego Gas & Electric Company
P. O. Box 1831
San Diego, California 92112

Resident Inspector/San Onofre NPS
U.S. NRC
P. O. Box 4329
San Clemente, California 92672

Mayor
City of San Clemente
San Clemente, California 92672

Chairman
Board of Supervisors
County of San Diego
1600 Pacific Highway Room 335
San Diego, California 92101

Director
Energy Facilities Siting Division
Energy Resources Conservation &
Development Commission
1516 - 9th Street
Sacramento, California 95814

Regional Administrator, Region V
U.S. Nuclear Regulatory Commission
1450 Maria Lane, Suite 210
Walnut Creek, California 94596