



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SOUTHERN CALIFORNIA EDISON COMPANY

SAN DIEGO GAS AND ELECTRIC COMPANY

DOCKET NO. 50-206

SAN ONOFRE NUCLEAR GENERATING STATION, UNIT NO. 1

AMENDMENT TO PROVISIONAL OPERATING LICENSE

Amendment No. 126  
License No. DPR-13

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Southern California Edison Company and San Diego Gas and Electric Company (the licensee) dated February 14, 1989 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8905190129 890509  
PDR ADOCK 05000206  
P PDC


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B. of Provisional Operating License No. DPR-13 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 126, are hereby incorporated in the license. Southern California Edison Company shall operate the facility in accordance with the Technical Specifications, except where otherwise stated in specific license conditions.

3. This license amendment is effective as of the date of its issuance and must be fully implemented no later than 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
George W. Knighton, Director  
Project Directorate V  
Division of Reactor Projects - III,  
IV, V and Special Projects

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: May 9, 1989

ATTACHMENT TO LICENSE AMENDMENT NO. 126

PROVISIONAL OPERATING LICENSE NO. DPR-13

DOCKET NO. 50-206

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

REMOVE  
6-4

INSERT  
6-4

overtime which exceeds 25%(ii) of normal time is required due to unforeseen problems(iii) or during extended outages(iv), on a temporary basis, the following guidelines shall be followed:

- 1) An individual should not be permitted to work more than 16 hours straight (shift turnover and meal time are not included when calculating hours worked).
- 2) An individual should not be permitted to work more than 16 hours in any 24-hour period, nor more than 24 hours in any 48-hour period, nor more than 72 hours in any 7-day period (shift turnover and meal time are not included when calculating hours worked).
- 3) A break (the time an individual leaves the work location to the time an individual returns to the work location) of at least 8 hours should be allowed between work periods (shift turnover time is not included when calculating the break; meal time is not included when calculating the break, unless it represents an administrative entry on the timesheet and not extra hours spent at the work location).
- 4) Except during extended shutdown periods, overtime should be considered on an individual basis and not for the entire staff on a shift.

Any deviation from the above guidelines shall be authorized by the Station Manager, or by the Responsible Station Division Manager, or higher levels of management, in accordance with established procedures and with documentation of the basis for granting the deviation. Controls shall be included in the procedures such that individual overtime shall be reviewed monthly by the Station Manager or his designee to assure that excessive hours have not been assigned. Routine deviation from the above guidelines is not authorized.

- g. The Plant Superintendent (at time of appointment), the Assistant Plant Superintendent, Shift Superintendents and Control Room Supervisors shall hold a senior reactor operator license. The Control Operators and Assistant Control Operators shall hold a reactor operator license.

- 
- (ii) 25% is established as a level of overtime which will not significantly reduce the effectiveness of personnel, but which requires additional management approval prior to exceeding this level.
  - (iii) Unforeseen problems are forced shutdowns or power reductions of any unit, equipment failure or unscheduled repair, surveillance, calibration or maintenance, entry into a Technical Specification CTION Statement or the absence of personnel required to provide normal shift coverage.
  - (iv) Extended outages are periods in Modes 5 and/or 6.