



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SOUTHERN CALIFORNIA EDISON COMPANY

SAN DIEGO GAS AND ELECTRIC COMPANY

DOCKET NO. 50-206

SAN ONOFRE NUCLEAR GENERATING STATION, UNIT NO. 1  
AMENDMENT TO PROVISIONAL OPERATING LICENSE

Amendment No. 135  
License No. DPR-13

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Southern California Edison Company and San Diego Gas and Electric Company (the licensee) dated June 11, 1990, as supplemented by letter dated October 12, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9011070247 901026  
PDR ADOCK 05000206  
P PIC


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B. of Provisional Operating License No. DPR-13 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 135, are hereby incorporated in the license. Southern California Edison Company shall operate the facility in accordance with the Technical Specifications, except where otherwise stated in specific license conditions.

3. This license amendment is effective as of the date of its issuance and must be fully implemented no later than 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in black ink, appearing to read "J. E. Dyer", followed by the word "FOR" in a smaller, spaced-out font.

James E. Dyer, Acting Director  
Project Directorate V  
Division of Reactor Projects III,  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: October 26, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 135

PROVISIONAL OPERATING LICENSE NO. DPR-13

DOCKET NO. 50-206

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

REMOVE

i  
ii  
iii  
3.0-2  
  
4.0-1  
4.0-2

INSERT

i  
ii  
iii  
3.0-2  
3.0-3  
3.0-4  
4.0-1  
4.0-2  
4.0-3  
4.0-4

APPENDIX A

TECHNICAL SPECIFICATIONS

LIST OF EFFECTIVE PAGES

<u>Page</u>	<u>Amendment No.</u>	<u>Page</u>	<u>Amendment No.</u>	<u>Page</u>	<u>Amendment No.</u>
i	135	3.0-1	43, 56, 64, 83	3.3-3	25, 38, 86, 124, 130
ii	135		130	3.3-4	25, 37, 124, 130
iii	135	3.0-2	56, 64, 83, 130,	3.3-5	25, 130
iv	131		135	3.3-6	25, 102, 120, 130
v	90, 130, 131	3.0-3	135	3.3-7	25, 102, 130
vi	90, 130, 131	3.0-4	135	3.3-8	25, 38, 122, 130
vii	90, 102, 130, 131	3.1-1	29, 38, 70, 83,	3.3-9	25, 38, 122, 130
viii	90, 130		91, 96, 130	3.3-10	25, 130
ix	90, 91, 102, 130	3.1-2	29, 83, 96, 130	3.3-11	NRC Order 4/20/81, 130
	131	3.1-3	43, 77, 103, 130	3.3-12	NRC Order 4/20/81, 130
x	90, 91, 130, 131	3.1-4	77, 130	3.4-1	29, 82, 125, 130
xi	55, 92, 102, 110,	3.1-5	77, 125, 130	3.4-2	29, 130
	111, 130, 131	3.1-6	77, 102, 130	3.4-3	82, 125, 130
xii	56, 58, 71, 79,	3.1-7	77, 102, 103, 130	3.4-4	82, 125, 130
	83, 104, 117, 130,	3.1-8	43, 102, 103, 130	3.5-1	83, 117, 130
	131	3.1-9	77, 102, 130	3.5-2	43, 56, 58, 83,
xiii	31, 56, 58, 79,	3.1-10	Change No. 14, 38,		117, 128, 130
	83, 84, 91, 117,	3.1-11	102, 130	3.5-3	43, 56, 58, 83,
	130, 131		Change No. 14, 38,		117, 121, 122, 130
xiv	131	3.1-12	Change No. 14, 92,	3.5-4	55, 58, 83, 117,
1.0-1	31, 56, 59, 83,		130		118, 121, 128, 130
	117, 130	3.1-13	Change No. 14, 92,	3.5-5	83, 117, 130
1.0-2	31, 56, 59, 83,		130	3.5-6	7, 11, 25, 35, 55,
	104, 117, 130	3.1-14	Change No. 14,	3.5-7	56, 111, 130
1.0-3	31, 56, 59, 79,		102, 130		7, 11, 25, 35, 49,
	83, 104, 117, 130	3.1-15	Change No. 14,		55, 56, 111, 122,
1.0-4	31, 56, 59, 79,		102, 130		130
	83, 117, 130	3.1-16	Change No. 14,	3.5-8	11, 49, 111, 122,
1.0-5	77, 79, 83, 117,		102, 130		130
	130	3.1-17	Change No. 14,	3.5-9	11, 25, 56, 111,
1.0-6	79, 83, 96, 117,		102, 130		130
	130	3.1-18	Change No. 7, 37,	3.5-10	56, 130
1.0-7	58, 83, 117, 130		55, 91, 119, 130	3.5-11	56, 130
1.0-8	56, 83, 117, 130	3.1-19	Change No. 7, 55,	3.5-12	56, 130
2.1-1	43, 55, 97, 117,		119, 130	3.5-13	56, 130
	130	3.1-20	37, 55, 119, 130		
2.1-2	43, 97, 117, 121,		58, 59, 83, 130		
	130	3.1-21	58, 130		
2.1-3	43, 117, 121, 122,		83, 130		
	130	3.1-22	102, 130		
2.1-4	43, 117, 121, 122,		25, 102, 130		
	130	3.2-1	25, 37, 86, 124		
2.1-5	43, 97, 117, 121,		130		
	122, 130	3.2-2	25, 130		
2.1-6	55, 130	3.3-1			
		3.3-2			

LIST OF EFFECTIVE PAGES  
(Cont.)

<u>Page</u>	<u>Amendment No.</u>	<u>Page</u>	<u>Amendment No.</u>	<u>Page</u>	<u>Amendment No.</u>
3.5-14	56, 130	3.8-2	36, 77, 130	3.15-2	79, 90, 91, 105, 130
3.5-15	58, 83, 130	3.8-3	25, 36, 73, 77, 130	3.15-3	79, 90, 91, 105, 130
3.5-16	58, 83, 130	3.8-4	36, 73, 77, 130	3.16-1	79, 130
3.5-17	58, 83, 130	3.8-5	36, 73, 77, 130	3.16-2	79, 90, 91, 105, 130
3.5-18	58, 72, 130	3.9-1	3, 10, 112, 130	3.16-3	79, 90, 91, 105, 130
3.5-19	58, 83, 125, 130	3.9-2	3, 10, 112, 130	3.16-4	79, 90, 91, 105, 130
3.5-20	125, 130	3.10-1	7, 8, 112, 122, 130	3.16-5	79, 130
3.5-21	58, 83, 117, 124, 125, 130	3.10-2	7, 112, 122, 130	3.16-6	79, 90, 130
3.5-22	64, 82, 125, 130	3.11-1	7, 8, 11, 35, 55, 112, 117, 122, 130	3.16-7	79, 90, 130
3.5-23	58, 82, 125, 130	3.11-2	7, 11, 112, 117, 122, 130	3.17-1	79, 90, 91, 105, 130
3.5-24	58, 82, 125, 130	3.12-1	14, 130	3.17-2	79, 90, 130
3.5-25	58, 82, 125, 129, 130	3.13-1	21, 63, 81, 130	3.18-1	79, 91, 105, 130
3.5-26	79, 90, 105, 130	3.13-2	21, 63, 81, 130	3.18-2	79, 90, 130
3.5-27	79, 90, 130	3.14-1	31, 44, 93, 130, 131	3.18-3	79, 130
3.5-28	79, 130	3.14-2	31, 130, 131	3.18-4	79, 130
3.5-29	79, 90, 105, 130	3.14-3	31, 130, 131	3.18-5	79, 130
3.5-30	79, 90, 130	3.14-4	31, 93, 130, 131	3.18-6	79, 130
3.5-31	79, 90, 130	3.14-5	31, 130, 131	3.18-7	79, 91, 105, 130
3.5-32	83, 130	3.14-6	130, 131, 134	3.18-8	79, 90, 130
3.5-33	83, 130	3.14-7	130, 131	3.18-9	79, 90, 105, 130
3.5-34	83, 91, 130	3.14-8	130, 131	3.19-1	79, 90, 105, 130
3.6-1	25, 56, 58, 73, 130	3.14-9	130, 131	3.20-1	102, 130
3.6-2	Change No. 7, 56, 130	3.14-10	130, 131	3.20-2	102, 130
3.6-3	58, 99, 130	3.14-11	31, 93, 130, 131	4.0-1	83, 130, <u>135</u>
3.6-4	58, 71, 99, 130	3.14-12	31, 130, 131	4.0-2	83, 130, <u>135</u>
3.6-5	58, 59, 71, 99, 130	3.14-13	31, 130, 131	4.0-3	<u>135</u>
3.6-6	58, 59, 83, 130	3.14-14	31, 130, 131	4.0-4	<u>135</u>
3.7-1	25, 52, 68, 84, 130, 134	3.14-15	31, 93, 130, 131	4.1-1	<u>29</u> , 56, 83, 117, 130
3.7-2	25, 84, 106, 130, 134	3.14-16	31, 130, 131	4.1-2	7, 22, 83, 117, 122, 130
3.7-3	25, 84, 130, 134	3.14-17	31, 130, 131, 134	4.1-3	117, 130
3.7-4	25, 52, 68, 84, 106, 130, 134	3.14-18	31, 130, 131	4.1-4	25, 29, 70, 96, 117, 130
3.7-5	25, 52, 68, 84, 106, 120, 130, 134	3.14-19	130, 131	4.1-5	25, 29, 70, 96, 130
3.7-6	134	3.14-20	130, 131	4.1-6	25, 29, 56, 70, 100, 122, 130, 134
3.7-7	134	3.14-21	130, 131		
3.8-1	25, 36, 37, 73, 77, 130	3.14-22	130, 131		
		3.14-23	130, 131		
		3.14-24	130, 131		
		3.14-25	130, 131		
		3.14-26	130, 131		
		3.15-1	79, 130		

LIST OF EFFECTIVE PAGES  
(Cont.)

<u>Page</u>	<u>Amendment No.</u>	<u>Page</u>	<u>Amendment No.</u>	<u>Page</u>	<u>Amendment No.</u>
4.1-7	25, 29, 36, 77, 103, 130	4.3-3	24, 58, 87, 118, 130	4.12-1	91, 130
4.1-8	77, 125, 130	4.3-4	24, 87, 130	4.13-1	18, 113, 130
4.1-9	77, 122, 125, 130	4.3-5	24, 75, 87, 130	4.14-1	21, 33, 63, 81, 130
4.1-10	117, 130	4.3-6	75, 87, 130	4.14-2	21, 63, 81, 130
4.1-11	25, 130	4.3-7	58, 130	4.14-3	21, 63, 81, 130
4.1-12	Change No. 5, 25, 130	4.3-8	58, 59, 83, 130	4.14-4	21, 63, 81, 105, 130
4.1-13	79, 130	4.3-9	58, 83, 130	4.15-1	31, 37, 38, 44, 130, 131
4.1-14	79, 90, 130	4.4-1	Change No. 12, 25, 56, 82, 84, 95, 104, 123, 130	4.15-2	31, 44, 130, 131
4.1-15	79, 130	4.4-2	25, 84, 130	4.15-3	31, 130, 131
4.1-16	79, 130	4.4-3	25, 56, 82, 84, 117, 130, 134	4.15-4	130, 131
4.1-17	79, 90, 130	4.4-4	25, 82, 84, 95, 104, 123, 124, 130, 134	4.15-5	130, 131
4.1-18	79, 130	4.4-5	84, 130	4.15-6	31, 130, 131
4.1-19	58, 130	4.4-6	25, 56, 84, 104, 123, 130	4.15-7	31, 130, 131
4.1-20	58, 130	4.4-7	25, 56, 84, 130, 134	4.15-8	130, 131
4.1-21	58, 130	4.5-1	Change No. 10, 38, 79, 130	4.15-9	130, 131
4.1-22	58, 83, 130	4.5-2	79, 90, 130	4.15-10	130, 131
4.1-23	58, 83, 117, 125, 130	4.5-3	79, 130	4.15-11	130, 131
4.1-24	58, 109, 130	4.5-4	79, 130	4.15-12	130, 131
4.1-25	58, 130	4.5-5	79, 130	4.16-1	31, 101, 115, 130, 133
4.1-26	58, 82, 125, 130	4.5-6	79, 130	4.16-2	37, 101, 115, 130, 133
4.1-27	58, 82, 125, 130	4.6-1	38, 79, 130	4.16-3	37, 101, 115, 130, 133
4.1-28	65, 82, 125, 130	4.6-2	79, 90, 130	4.16-4	37, 55, 101, 115, 130, 133
4.1-29	65, 125, 130	4.6-3	79, 130	4.16-5	37, 91, 101, 105, 115, 130, 133
4.1-30	82, 130	4.6-4	79, 130	4.17-1	79, 130
4.1-31	83, 130	4.6-5	79, 130	4.18-1	79, 130
4.1-32	83, 130	4.6-6	79, 130	4.18-2	79, 130
4.1-33	83, 130	4.6-7	79, 130	4.18-3	79, 130
4.1-34	119, 130	4.6-8	79, 130	4.18-4	79, 130
4.1-35	119, 130	4.6-9	79, 130	4.18-5	79, 130
4.2-1	25, 37, 54, 114, 130	4.7-1	Change No. 14, 46, 130	4.18-6	79, 130
4.2-2	25, 37, 114, 130	4.8-1	91, 130	4.19-1	79, 105, 130
4.2-3	25, 37, 114, 130	4.9-1	Change No. 14, 130		
4.2-4	25, 37, 114, 124, 130	4.9-2	130		
4.2-5	25, 37, 114, 124, 130	4.10-1	13, 94, 130		
4.2-6	37, 114, 130	4.10-2	13, 94, 130		
4.2-7	NRC Order 4/20/81, 54, 130	4.11-1	14, 109, 130		
4.3-1	24, 58, 75, 130	4.11-2	14, 109, 130		
4.3-2	5, 24, 58, 75, 87, 118, 130				

BASIS:

Specification 3.0.1 through 3.0.4 establish the general requirements applicable to Limiting Conditions for Operation. These requirements are based on the requirements for Limiting Conditions for Operation stated in the Code of Federal Regulations, 10 CFR 50.36(c)(2):

"Limiting conditions for operation are the lowest functional capability or performance levels of equipment required for safe operation of the facility. When a limiting condition for operation of a nuclear reactor is not met, the licensee shall shut down the reactor or follow any remedial action permitted by the technical specification until the condition can be met."

Specification 3.0.1 establishes the Applicability statement within each individual specification as the requirement for when (i.e., in which OPERATIONAL MODES or other specified conditions) conformance to the Limiting Conditions for Operation is required for safe operation of the facility. The ACTION requirements establish those remedial measures that must be taken within specified time limits when the requirements of a Limiting Condition for Operation are not met.

There are two basic types of ACTION requirements. The first specifies the remedial measures that permit continued operation of the facility which is not further restricted by the time limits of the ACTION requirements. In this case, conformance to the ACTION requirements provides an acceptable level of safety for unlimited continued operation as long as the ACTION requirements continue to be met. The second type of ACTION requirement specifies a time limit in which conformance to the conditions of the Limiting Condition for Operation must be met. This time limit is the allowable outage time to restore an inoperable system or component to OPERABLE status or for restoring parameters within specified limits. If these actions are not completed within the allowable outage time limits, a shutdown is required to place the facility in a MODE or condition in which the specification no longer applies. It is not intended that the shutdown ACTION requirements be used as an operational convenience which permits (routine) voluntary removal of a system(s) or component(s) from service in lieu of other alternatives that would not result in redundant systems or components being inoperable.

The specified time limits of the ACTION requirements are applicable from the point in time it is identified that a Limiting Condition for Operation is not met. The time limits of the ACTION requirements are also applicable when a system or component is removed from service for surveillance testing or investigation of operational problems. Individual specifications may include a specified time limit for the completion of a Surveillance Requirement when equipment is removed from service. In this case, the allowable outage time limits of the ACTION requirements are applicable when this limit expires if the surveillance has not been completed. When a shutdown is required to comply with ACTION requirements, the plant may have entered a MODE in which a new specification becomes applicable. In this case, the time limits of the ACTION requirements would apply from the point in time that the new specification becomes applicable if the requirements of the Limiting Condition for Operation are not met.

Specification 3.0.2 establishes that noncompliance with a specification exists when the requirements of the Limiting Condition for Operation are not met and

the associated ACTION requirements have not been implemented within the specified time interval. The purpose of this specification is to clarify that (1) implementation of the ACTION requirements within the specified time interval constitutes compliance with a specification and (2) completion of the remedial measures of the ACTION requirements is not required when compliance with a Limiting Condition for Operation is restored within the time interval specified in the associated ACTION requirements.

Specification 3.0.3 establishes the shutdown ACTION requirements that must be implemented when a Limiting Condition for Operation is not met and the condition is not specifically addressed by the associated ACTION requirements. The purpose of this specification is to delineate the time limits for placing the unit in a safe shutdown MODE when plant operation cannot be maintained within the limits for safe operation defined by the Limiting Conditions for Operation and its ACTION requirements. It is not intended to be used as an operational convenience which permits (routine) voluntary removal of redundant systems or components from service in lieu of other alternatives that would not result in redundant systems or components being inoperable. One hour is allowed to prepare for an orderly shutdown before initiating a change in plant operation. This time permits the operator to coordinate the reduction in electrical generation with the load dispatcher to ensure the stability and availability of the electrical grid. The time limits specified to reach lower MODES of operation permit the shutdown to proceed in a controlled and orderly manner that is well within the specified maximum cooldown rate and within the cooldown capabilities of the facility assuming only the minimum required equipment is OPERABLE. This reduces thermal stresses on components of the primary coolant system and the potential for a plant upset that could challenge safety systems under conditions for which this specification applies.

If remedial measures permitting limited continued operation of the facility under the provisions of the ACTION requirements are completed, the shutdown may be terminated. The time limits of the ACTION requirements are applicable from the point in time there was a failure to meet a Limiting Condition for Operation. Therefore, the shutdown may be terminated if the ACTION requirements have been met or the time limits of the ACTION requirements have not expired, thus providing an allowance for the completion of the required actions.

The time limits of Specification 3.0.3 allow 37 hours for the plant to be in the COLD SHUTDOWN MODE when a shutdown is required during the POWER MODE of operation. If the plant is in a lower MODE of operation when a shutdown is required, the time limit for reaching the next lower MODE of operation applies. However, if a lower MODE of operation is reached in less time than allowed, the total allowable time to reach COLD SHUTDOWN, or other applicable MODE, is not reduced. For example, if HOT STANDBY is reached in 2 hours, the time allowed to reach HOT SHUTDOWN is the next 11 hours because the total time to reach HOT SHUTDOWN is not reduced from the allowable limit of 13 hours. Therefore, if remedial measures are completed that would permit a return to POWER OPERATION, a penalty is not incurred by having to reach a lower MODE of operation in less than the total time allowed.

The same principle applies with regard to the allowable outage time limits of the ACTION requirements, if compliance with the ACTION requirements for one specification results in entry into a MODE or condition of operation for another



specification in which the requirements of the Limiting Condition for Operation are not met. If the new specification becomes applicable in less time than specified, the difference may be added to the allowable outage time limits of the second specification. However, the allowable outage time limits of ACTION requirements for a higher MODE of operation may not be used to extend the allowable outage time that is applicable when a Limiting Condition for Operation is not met in a lower MODE of operation.

The shutdown requirements of Specification 3.0.3 do not apply in MODES 5 and 6, because the ACTION requirements of individual specifications define the remedial measures to be taken.

Specification 3.0.4 establishes limitations on MODE changes when a Limiting Condition for Operation is not met. The purpose of this specification is to ensure that facility operation is not initiated or that higher MODES of operation are not entered when corrective action is being taken to obtain compliance with a specification by restoring equipment to OPERABLE status or parameters to specified limits.

When a shutdown is required to comply with ACTION requirements, the provisions of Specification 3.0.4 do not apply because they would delay placing the facility in a lower MODE of operation.

Exceptions to this specification have been provided for a limited number of specifications when startup with inoperable equipment would not affect plant safety. These exceptions are stated in the ACTION statements of the appropriate specifications.

REFERENCE:

NRC Generic Letter No. 87-09 dated 6/4/87

## 4.0 SURVEILLANCE REQUIREMENTS (GENERAL)

---

---

APPLICABILITY: Applies to the surveillance requirements to be implemented in these specifications.

OBJECTIVE: To define the conditions under which the surveillance requirements of Section 4 Specifications are applicable.

### SPECIFICATION:

4.0.1 Surveillance Requirements shall be met during OPERATIONAL MODES or other conditions specified for individual Limiting Conditions for Operation unless otherwise stated in an individual Surveillance Requirement.

4.0.2 Each Surveillance Requirement shall be performed within the specified surveillance interval with a maximum allowable extension not to exceed 25% of the specified surveillance interval.

- a. A maximum allowable extension not to exceed 25% of the surveillance interval, but
- b. The combined time interval for any 3 consecutive surveillance-intervals shall not exceed 3.25 times the specified surveillance interval.

4.0.3 Failure to perform a Surveillance Requirement within the allowed surveillance interval, defined by Specification 4.0.2, shall constitute noncompliance with the OPERABILITY requirements for a Limiting Condition for Operation. The time limits of the ACTION requirements are applicable at the time it is identified that a Surveillance Requirement has not been performed. The ACTION requirements may be delayed for up to 24 hours to permit the completion of the surveillance when the allowable outage time limits of the ACTION requirements are less than 24 hours. Surveillance Requirements do not have to be performed on inoperable equipment.

4.0.4 Entry into an OPERATIONAL MODE or other specified condition shall not be made unless the Surveillance Requirement(s) associated with the Limiting Condition for Operation have been performed within the stated surveillance interval or as otherwise specified. This provision shall not prevent passage through or to OPERATIONAL MODES as required to comply with ACTION requirements.

### BASIS:

Specifications 4.0.1 through 4.0.4 establish the general requirements applicable to Surveillance Requirements. These requirements are based on the Surveillance Requirements stated in the Code of Federal Regulations, 10 CFR 50.36(c)(3):

"Surveillance requirements are requirements relating to test, calibration, or inspection to ensure that the necessary quality of systems and components is maintained, that facility operation will be within safety limits, and that the limiting conditions of operation will be met."

#### 4.0 SURVEILLANCE REQUIREMENT (GENERAL)

---

---

Specification 4.0.1 establishes the requirement that surveillances must be performed during the OPERATIONAL MODES or other conditions for which the requirements of the Limiting Conditions for Operation apply unless otherwise stated in an individual Surveillance Requirement. The purpose of this specification is to ensure that surveillances are performed to verify the operational status of systems and components and that parameters are within specified limits to ensure safe operation of the facility when the plant is in a MODE or other specified condition for which the associated Limiting Conditions for Operation are applicable. Surveillance Requirements do not have to be performed when the facility is in an OPERATIONAL MODE for which the requirements of the associated Limiting Condition for Operation do not apply unless otherwise specified. The Surveillance Requirements associated with a Special Test Exception are only applicable when the Special Test Exception is used as an allowable exception to the requirements of a specification.

Specification 4.0.2 establishes the conditions under which the specified time interval for Surveillance Requirements may be extended. Item a. permits an allowable extension for the normal surveillance interval to facilitate surveillance scheduling and consideration of plant operating conditions that may not be suitable for conducting the surveillance; e.g., transient conditions or other ongoing surveillance or maintenance activities. Item b. limits the use of the provisions of Item a. to ensure that it is not used repeatedly to extend the surveillance interval beyond that specified. The limits of Specification 4.0.2 are based on engineering judgment and the recognition that the most probable result of any particular surveillance being performed is the verification of conformance with the Surveillance Requirements. These provisions are sufficient to ensure that the reliability ensured through surveillance activities is not significantly degraded beyond that obtained from the specified surveillance interval.

Specification 4.0.3 establishes the failure to perform a Surveillance Requirement within the allowed surveillance interval, defined by the provisions of Specification 4.0.2, as a condition that constitutes a failure to meet the OPERABILITY requirements for a Limiting Condition for Operation. Under the provisions of this specification, systems and components are assumed to be OPERABLE when Surveillance Requirements have been satisfactorily performed within the specified time interval. However, nothing in this provision is to be construed as implying that systems or components are OPERABLE when they are found or known to be inoperable although still meeting the Surveillance Requirements. This specification also clarifies that the ACTION requirements are applicable when Surveillance Requirements have not been completed within the allowed surveillance interval and that the time limits of the ACTION requirements apply from the point in time it is identified that a surveillance has not been performed and not at the time that the allowed surveillance interval was exceeded. Completion of the Surveillance Requirement within the allowable outage time limits of the ACTION requirements restores compliance with the requirements of Specification 4.0.3. However, this does not negate the fact that the failure to have performed the surveillance within the allowed surveillance interval, defined by

#### 4.0 SURVEILLANCE REQUIREMENT (GENERAL)

---

---

the provisions of Specification 4.0.2, was a violation of the OPERABILITY requirements of a Limiting Condition for Operation that is subject to enforcement action. Further, the failure to perform a surveillance within the provisions of Specification 4.0.2 is a violation of a Technical Specification requirement and is, therefore, a reportable event under the requirements of 10 CFR 50.73(a)(2)(i)(B) because it is a condition prohibited by the plant's Technical Specifications.

If the allowable outage time limits of the ACTION requirements are less than 24 hours or a shutdown is required to comply with ACTION requirements, e.g., Specification 3.0.3, a 24-hour allowance is provided to permit a delay in implementing the ACTION requirements. This provides an adequate time limit to complete Surveillance Requirements that have not been performed. The purpose of this allowance is to permit the completion of a surveillance before a shutdown is required to comply with ACTION requirements or before other remedial measures would be required that may preclude completion of a surveillance. The basis for this allowance includes consideration for plant conditions, adequate planning, availability of personnel, the time required to perform the surveillance, and the safety significance of the delay in completing the required surveillance. This provision also provides a time limit for the completion of Surveillance Requirements that become applicable as a consequence of MODE changes imposed by ACTION requirements and for completing Surveillance Requirements that are applicable when an exception to the requirements of Specification 4.0.4 is allowed. If a surveillance is not completed within the 24-hour allowance, the time limits of the ACTION requirements are applicable at that time. When a surveillance is performed within the 24-hour allowance and the Surveillance Requirements are not met, the time limits of the ACTION requirements are applicable at the time that the surveillance is terminated.

Surveillance Requirements do not have to be performed on inoperable equipment because the ACTION requirements define the remedial measures that apply. However, the Surveillance Requirements have to be met to demonstrate that inoperable equipment has been restored to OPERABLE status.

Specification 4.0.4 establishes the requirement that all applicable surveillances must be met before entry into an OPERATIONAL MODE or other condition of operation specified in the Applicability statement. The purpose of this specification is to ensure that system and component OPERABILITY requirements or parameter limits are met before entry into a MODE or condition for which these systems and components ensure safe operation of the facility. This provision applies to changes in OPERATIONAL MODES or other specified conditions associated with plant shutdown as well as startup.

Under the provisions of this specification, the applicable Surveillance Requirements must be performed within the specified surveillance interval to ensure that the Limiting Conditions for Operation are met during initial plant startup or following a plant outage.

#### 4.0 SURVEILLANCE REQUIREMENT (GENERAL)

---

---

When a shutdown is required to comply with ACTION requirements, the provisions of Specification 4.0.4 do not apply because this would delay placing the facility in a lower MODE of operation.

#### REFERENCE:

NRC Generic Letter No. 87-09 dated 6/4/87