

APR 15 1988

Docket Nos. 50-206, 50-361, 50-362

Southern California Edison Company
P. O. Box 800
2244 Walnut Grove Avenue
Rosemead, California 92770

Attention: Mr. Kenneth P. Baskin, Vice President
Nuclear Engineering Safety and Licensing

Gentlemen:

This refers to the routine inspection conducted by Messrs. F. R. Huey, J. E. Tatum, and A. L. Hon of this office during the period of January 17 through February 27, 1988 of activities authorized by NRC License Nos. DPR-13, NPF-10 and NPF-15 and to the discussion of our findings held by the inspectors with Mr. C. B. McCarthy and other members of the Southern California Edison staff at the conclusion of the inspection.

Areas examined during this inspection are described in the enclosed inspection report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspectors.

Based on the results of this inspection, it appears that certain of your activities were not conducted in full compliance with NRC requirements, as set forth in the Notice of Violation, enclosed herewith as Appendix A.

Your response to this Notice is to be submitted in accordance with the provisions of 10 CFR 2.201 as stated in Appendix A, Notice of Violation.

In addition to the apparent violations that have been cited in this inspection report, the circumstances which resulted in a number of steam generator code safety valves being inoperable on Units 2 and 3 (discussed in paragraph 9 of this report) are of concern to the NRC. Poor engineering work and inadequate review apparently culminated in this condition, and it was fortuitous that a significant safety issue did not develop. Your attention is warranted to ensure that all aspects of engineering work are being properly conducted.

In accordance with 10 CFR 2.790(a), a copy of this letter, the enclosure, and your response will be placed in the NRC Public Document Room.

The responses directed by this letter and the accompanying Notice are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

8804290299 880415
PDR ADDCK 05000206
Q DCD

Should you have any questions concerning this inspection, we will be glad to discuss them with you.

Sincerely,
original signed
R. P. Zimmerman, Chief
Reactor Projects Branch

Enclosures:

- 1. Notice of Violation
- 2. Inspection Reports
 - Nos. 50-206/88-03
 - 50-361/88-03
 - 50-362/88-03

cc w/Enclosures:

- D. J. Fogarty, Executive Vice President
- C. B. McCarthy, Jr., Vice President - Site Manager (San Clemente)
- H. E. Morgan, Station Manager (San Clemente)
- State of California

bcc w/enclosure:

- Project Inspector
- Resident Inspector
- docket file
- G. Cook
- A. Johnson
- B. Faulkenberry
- J. Martin
- D. Persinko, NRR

bcc w/o enclosure 2:

- LFMB
- M. Smith

Allegation File (ATS RV-87-A-084) (Report cover page and Paragraph 10.d only)
 Edward Baker, NRR (Report cover page and Paragraph 11)
 James Conway, NRR (Report cover page and Paragraph 11)

REGION V/dot

AHon *AH*
4/12/88

JTatum
JTatum
4/12/88

RHuey
RHuey
4/16/88

PJohnson
PJohnson
4/12/88

AJohnson
AJohnson
4/12/88

REQUEST COPY]	REQUEST COPY]	REQUEST COPY]	REQUEST COPY]	REQUEST COPY]
YES / NO]	YES / NO]	YES / NO]	YES / NO]	YES / NO]

RPZ
RZimmerman 4/15/88

REQUEST COPY]
YES / NO]

SEND TO PDR]
YES / NO]