

PDR

JUN 22 1988

Docket Nos. 50-206, 50-361, 50-362

Southern California Edison Company
P. O. Box 800
2244 Walnut Grove Avenue
Rosemead, California 92770

Attention: Mr. Kenneth P. Baskin, Vice President
Nuclear Engineering, Safety, and Licensing

Gentlemen:

This refers to the routine inspection conducted by Messrs. F. R. Huey, J. E. Tatum, and A. L. Hon of this office during the period of April 10 through May 21, 1988 of activities authorized by NRC License Nos. DPR-13, NPF-10 and NPF-15 and to the discussion of our findings held by the inspectors with Mr. C. B. McCarthy and other members of the Southern California Edison staff at the conclusion of the inspection.

Areas examined during this inspection are described in the enclosed inspection report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspectors.

No violations of NRC requirements were identified within the scope of this inspection.

Your staff's failure to monitor fundamental parameters and to establish appropriate operability criteria for the emergency chillers (discussed in paragraph 2b of this report) is of concern to the NRC. The lack of a timely assessment of chiller operability on April 2, 1988, when refrigerant level was found to be low, is also of concern. Your attention is warranted to ensure that these concerns are adequately addressed. In this regard, please provide a written response to discuss the actions that you are taking to resolve these concerns.

We understand that four fire suppression system actuations have occurred in Unit 3 cable riser rooms since April, 1988. We are interested in the actions you are taking to evaluate and determine the root cause of these occurrences, including the communications, technical support, and possible long-term degradation aspects involved. We will evaluate these as part of our ongoing inspection program.

In accordance with 10 CFR 2.790(a), a copy of this letter, the enclosure, and your response will be placed in the NRC Public Document Room.

8807140220 880622
PDR ADOCK 05000206
Q PDC

IE01
41

JUN 22 1988

-2-

The response requested by this letter is not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

Should you have any questions concerning this inspection, we will be glad to discuss them with you.

Sincerely,

R P Zimmerman

R. P. Zimmerman, Chief
Reactor Projects Branch

Enclosure:

Inspection Reports:

Nos. 50-206/88-13
50-361/88-11
and 50-362/88-11

cc w/Enclosure:

D. J. Fogarty, Executive Vice President
C. B. McCarthy, Vice President (San Clemente)
H. E. Morgan, Station Manager (San Clemente)
State of California

bcc w/Enclosure:

Docket File
Project Inspector
Resident Inspector
G. Cook, RV
B. Faulkenberry, RV
J. Martin, RV
T. Foley, NRR

bcc w/o Enclosure:

M. Smith
J. Zollicoffer

REGION V/Joan

for FRHuey
6/22/88

for JETatum
6/22/88

for ALHon
6/22/88

for PHJohnson
6/22/88

R/PZ
RZimmerman
6/22/88

REQUEST COPY] REQUEST COPY] REQUEST COPY] REQUEST COPY] REQUEST COPY]
YES / NO] YES / NO] YES / NO] YES / NO] YES / NO]

SEND TO PDR]
YES / NO]