

November 5, 1990

Docket No. 50-206

Mr. Harold B. Ray  
Senior Vice President  
Southern California Edison Company  
Irvine Operations Center  
23 Parker Street  
Irvine, California 92718

Dear Mr. Ray:

SUBJECT: VERIFICATION OF PRESSURIZER INTEGRITY - SAN ONOFRE NUCLEAR  
GENERATING STATION, UNIT NO. 1

We have received your letter dated October 19, 1990, which provides the results of your visual inspection of the pressurizer for San Onofre Nuclear Generating Station, Unit No. 1 (SONGS-1). Your inspection was performed in response to concerns that we expressed to you in a letter dated July 30, 1990, regarding pressurizer clad cracking. Based on your inspection results, you have concluded that clad cracking has not occurred in the SONGS-1 pressurizer and that the integrity of the pressurizer remains intact.

The purpose of this letter is to acknowledge your responsiveness in addressing our concerns, as we recognize that your inspection of the SONGS-1 pressurizer was not a trivial matter. We are satisfied by the results of your inspection and have no further questions in this regard.

Sincerely,

Original Signed By:

James E. Tatum, Project Manager  
Project Directorate V  
Division of Reactor Projects - III,  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION

Docket File	NRC & LPDRs
JTatum (2)	MVirgilio
DFoster	OGC
PD5 Plant File	EJordan
BGrimes	ACRS (10)
RHermann	MHum

OFC	:DRSP/LA/PD5	:DRSP/PM/PD5	:DRSP/(A)D:PD5	:DET:EMeB	:
NAME	:DFoster	:JTatum:sg	:JDyer	:CYCheng	:
DATE	:11/2/90	:11/2/90	:11/5/90	:11/2/90	:

OFFICIAL RECORD COPY

Document Name: S01 LTR

9011070299 901105  
PDR ADOCK 05000206  
Q PDC

DFol  
11/0

m H 4  
wch

Mr. Harold B. Ray  
Southern California Edison Company

San Onofre Nuclear Generating  
Station, Unit No. 1

CC:  
David R. Pigott, Esq.  
Orrick, Herrington & Sutcliffe  
600 Montgomery Street  
San Francisco, California 94111

Mr. Richard J. Kosiba, Project Manager  
Bechtel Power Corporation  
12440 E. Imperial Highway  
Norwalk, California 90650

Mr. Robert G. Lacy  
Manager, Nuclear Department  
San Diego Gas & Electric Company  
P. O. Box 1831  
San Diego, California 92112

Mr. Phil Johnson  
U.S. Nuclear Regulatory Commission  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596

Resident Inspector, San Onofre NPS  
c/o U.S. Nuclear Regulatory Commission  
P. O. Box 4329  
San Clemente, California 92672

Mayor  
City of San Clemente  
San Clemente, California 92672

Chairman, Board of Supervisors  
County of San Diego  
1600 Pacific Highway, Room 335  
San Diego, California 92101

Regional Administrator, Region V  
U.S. Nuclear Regulatory Commission  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596

Mr. John Hickman  
Senior Health Physicist  
Environmental Radioactive Mgmt. Unit  
Environmental Management Branch  
State Department of Health Services  
714 P Street, Room 616  
Sacramento, California 95814

Mr. Don J. Womeldorf  
Chief, Environmental Management Branch  
California Department of Health Services  
714 P Street, Room 616  
Sacramento, California 95814