



Docket # 50-206
 Control # 8807140139
 Date 8/7/88 of Document
 REGULATORY DOCKET FILE

- NOTES:
1. ALL OUTPUTS ARE DRY CONTACT ACTUATION. REFERENCE WIRING DIAGRAM DRAWING NO. 1875E50.
 2. ALL SAFETY LOGIC IS ENERGIZED NORMAL AND DE-ENERGIZED TO TRIP. NON SAFETY OUTPUTS ARE ENERGIZED TO TRIP.
 3. THESE SIGNALS ARE BYPASSED AND PREVENTED FROM TRIP WHEN THE ASSOCIATED CHANNEL IS IN BYPASS.

SO. SIVP-38	REV	3
D. 727A14	REV	3
SIVP-3	REV	3
ECN-3	REV	3
REVISED	3-12-88	
D.C. FUNNY	7-7-88	

TOLERANCE & MACHINE NOTES
 UNLESS OTHERWISE SPECIFIED
 DRAWING PRACTICES, GEOMETRIC SYMBOLS.

RADIUS R CHAMFER ALL EDGES... .005-.030
 FILLET RADIUS... .031.01
 ANGULARITY: CHAMFERS... .2°
 MAXIMUM SURFACE ROUGHNESS-250µ IN. MAA
 DWG. REF. THIRD ANGLE PROJECTION
 NEXT ASSY

B. SMOODY 2-24-88

Westinghouse Electric Corporation
 WATER OF LIGHTS DIVISIONS - WASHINGTON, PA U.S.A.

COINCIDENTOR UNIT I
 FUNCTIONAL BLOCK DIAGRAM

DIMENSIONS IN INCHES

SIZE / PCHW NO.	DWG NO.	REV.
D	2D333798	3

SCALE: 1" = 1" (AS SHOWN)

8807140167
 APERTURE CARD