

MEETING SUMMARY DISTRIBUTION

Docket  
NRC FDR  
Local PDR  
ORB Reading  
NRR Reading  
HRDenton  
EGCase  
DEisenhut  
RPurple  
RTEdesco  
TNovak  
GLianas  
Jolshinski  
GZech  
JHeltemes, AEOd  
CThayer  
SVarga  
BClark  
Tippolito  
RReid  
Crutchfield  
SNowicki  
OELD  
OI&E (3)  
OSD  
NRC Participants  
NSIC  
TERA  
ACRS (16)

REGULATORY DOCKET FILE COPY

8010300156

P





Docket No. 50-206

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

September 22, 1980

LICENSEE: Southern California Edison Company

FACILITY: San Onofre Unit No. 1

SUBJECT: SUMMARY OF JULY 31, 1980 MEETING TO DISCUSS SLEEVING OF THE  
SAN ONOFRE UNIT NO. 1 STEAM GENERATOR TUBES

NRC and Southern California Edison (SCE) representatives met in Bethesda, Maryland, on July 31, 1980, to discuss the sleeving design concept for steam generator tube repair and plans to decontaminate the steam generator bowl prior to sleeving. The meeting attendees are listed in Attachment 1.

SCE requested the meeting to present details of the design concept of sleeving steam generator tubes with leak-tight sleeves as a repair mechanism for tubes that had undergone intergranular attack. In addition, SCE representatives presented data and a description of their proposed method of decontaminating the steam generator bowl with a hydro grit stream composed of water and magnetite.

A copy of the material presented at the meeting (minus Westinghouse proprietary data) is enclosed in Attachment 2.

The major items discussed during the meetings are summarized below:

1. The NRC staff indicated some of their concerns related to the sleeving process that need to be addressed. These concerns included: inspectability of sleeved tubes; leak tightness of the sleeves; mechanical strength of sleeved tubes; radiological exposure to workers during the repair program; pluggability of sleeved tubes; and effects of stagnation of secondary water between the sleeve and tube.
2. The sleeves installed at Palisades were of a different design than proposed for San Onofre Unit 1. The Palisades sleeves were not designed as leak tight.
3. Cold leg inspections had been performed and four (4) tubes had indications of Phosphate thinning. Approximately 1400 tubes were inspected previously and 107 tubes examined during this inspection.
4. Pressure testing was performed on 25 tubes in the hot leg up to 3000 psig and no tubes leaked. The tubes are designed for a differential pressure of 2200 psig following an accident.

A handwritten mark or signature, possibly a stylized 'J' or 'L', located at the bottom right of the page.

5. SCE preposes to sleeve approximately 2500 tubes per steam generator or approximately 7500 tubes out of the 11,382.
6. SCE has performed an evaluation and has concluded that the sleeving does not constitute an unreviewed safety question.
7. SCE has estimated that worker exposures will be 250 man rem for inspection plus tube pulling and approximately 1000 man rem for steam operator repair. ALARA aspects will be covered in the August 15, 1980 meeting.
8. The NRC staff wants design details on the mechanical plugs in time to include this aspect in our review.
9. SCE requested NRC approval to install sleeves and any remaining concerns by September 10, 1980. SCE plans to return San Onofre Unit 1 to power about November 1, 1980.

Stanley J. Nowicki, Project Manager  
Operating Reactors Branch #5  
Division of Licensing

Attachments:  
As stated.

|           |             |              |  |  |  |  |
|-----------|-------------|--------------|--|--|--|--|
| OFFICE ▶  | DL: ORE #5  | DL: ORB #5   |  |  |  |  |
| SURNAME ▶ | SNowicki:cc | DCrutchfield |  |  |  |  |
| DATE ▶    | 9/19/80     | 9/22/80      |  |  |  |  |

5. SCE preposes to sleeve approximately 2500 tubes per steam generator or approximately 7500 tubes out of the 11,382.
6. SCE has performed an evaluation and has concluded that the sleeving does not constitute an unreviewed safety question.
7. SCE has estimated that worker exposures will be 250 man rem for inspection plus tube pulling and approximately 1000 man rem for steam operator repair. ALARA aspects will be covered in the August 15, 1980 meeting.
8. The NRC staff wants design details on the mechanical plugs in time to include this aspect in our review.
9. SCE requested NRC approval to install sleeves and any remaining concerns by September 10, 1980. SCE plans to return San Onofre Unit 1 to power about November 1, 1980.

*Stanley J. Nowicki*

Stanley J. Nowicki, Project Manager  
Operating Reactors Branch #5  
Division of Licensing

Attachments:  
As stated.

cc  
Charles R. Kocher, Assistant  
General Counsel  
Southern California Edison Company  
Post Office Box 800  
Rosemead, California 91770

David R. Pigott  
SSamuel B. Casey  
Chickering & Gregory  
Three Embarcadero Center  
Twenty-Third Floor  
San Francisco, California 94111

Jack E. Thomas  
Harry B. Stoehr  
San Diego Gas & Electric Company  
P. O. Box 1831  
San Diego, California 92112

Resident Inspector  
c/o U. S. NRC  
P. O. Box AA  
Oceanside, California 92054

Mission Viejo Branch Library  
24851 Chrisanta Drive  
Mission Viejo, California 92676

Mayor  
City of San Clemente  
San Clemente, California 92672

Chairman  
Board of Supervisors  
County of San Diego  
San Diego, California 92101

California Department of Health  
ATTN: Chief, Environmental  
Radiation Control Unit  
Radiological Health Section  
714 P Street, Room 498  
Sacramento, California 95814

Director, Technical Assessment  
Division  
Office of Radiation Programs  
(AW-459)  
U. S. Environmental Protection  
Agency  
Crystal Mall #2  
Arlington, Virginia 20460

U. S. Environmental Protection  
Agency  
Region IX Office  
ATTN: EIS COORDINATOR  
215 Fremont Street  
San Francisco, California 94111

## ATTENDANCE

|                    |              |
|--------------------|--------------|
| 1. S. J. Nowicki   | NRC          |
| 2. R. W. Krieger   | SCE          |
| 3. E. G. Igne      | NRC          |
| 4. C. Y. Cheng     | NRC          |
| 5. B. L. Curtis    | SCE          |
| 6. W. J. Collins   | NRC          |
| 7. F. Almeter      | NRC          |
| 8. B. Turovlin     | NRC          |
| 9. C. Hinson       | NRC          |
| 10. J. Wing        | NRC          |
| 11. B. D. Liaw     | NRC          |
| 12. S. S. Pawlicki | NRC          |
| 13. G. Georgiev    | NRC          |
| 14. R. Dermann     | NRC          |
| 15. D. Huang       | NRC          |
| 16. E. Murphy      | NRC          |
| 17. R. Emch        | NRC          |
| 18. F. Witt        | NRC          |
| 19. L. Barrett     | NRC          |
| 20. E. Brown       | NRC          |
| 21. H. Conroad     | NRC          |
| 22. L. Frank       | NRC          |
| 23. D. Meoli       | NSD <u>W</u> |
| 24. P. Dtosia      | <u>W</u> NSD |
| 25. T. Timmons     | <u>W</u> NTD |
| 26. A. Klein       | <u>W</u> NTD |
| 27. E. Murphy      | <u>W</u> BLO |
| 28. C. Hirst       | <u>W</u> NSD |
| 29. J. Taylor      | <u>W</u> NSD |
| 30. P. Matthews    | NRC          |

SCE MEETING WITH NRC

JULY 31, 1980

AGENDA

|                                       |          |
|---------------------------------------|----------|
| INTRODUCTION                          | SCE      |
| PROGRAM PLAN STATUS UPDATE            | SCE      |
| DECONTAMINATION PROCESS               | <u>W</u> |
| STEAM GENERATOR TUBE SLEEVING PROCESS | <u>W</u> |
| LICENSING CONSIDERATIONS              | SCE      |
| SUMMARY                               | SCE      |

## ACTIONS

- CONTINUE RPC EDDY CURRENT TESTING
- INDIVIDUAL PRESSURE TEST 5 LEAKERS IN SG-C
- INDIVIDUAL PRESSURE TEST TUBES (TEST FIRST WITH RPC)
- PULL TUBES (TEST FIRST WITH RPC)
- RCS PRESSURE TEST OF BUNDLE
- SS PRESSURE TEST OF BUNDLE
- PLUG TUBES
- CHEMISTRY FLUSHING
- INSTITUTE CHANGES IN CHEMISTRY CONTROL
- REDUCED CONDITIONS OPERATIONS
- REPAIR




OVERALL OBJECTIVE : Return the unit to power at earliest date consistent with safe operation.

REFERENCE APPROACH : Install leak tight sleeves in the largest number of tubes consistent with logistics and channel head access, with the intent to return the unit to 100% power operation.

ALTERNATE APPROACH : Mechanically plug the minimum number of tubes consistent with safe operation. Unit will be returned to operation at reduced conditions to arrest corrosion in unplugged tubes.

OPERATIONAL BASIS : Proceed in parallel with the following major tasks


- o Define zones for repair by means of eddy current testing, tube removals, individual tube pressure tests and primary hydro of tube bundle
- o Develop sleeving process and installation procedure
- o Design and qualify temporary plug to permit recovery of tubes removed from operation
- o Proceed with expedited production of 3/4" conventional plugs
- o Adapt abrasive DeCon System for operation in Model 27 SG's



SUMMARY OF TUBE EXAMINATION

|                              |   |
|------------------------------|---|
| R24-C71 (DISTORTED DENT)     | 95% MAX. WALL PENETRATION<br>SEM & MET. COMPLETE  |
| R31-C28 (GRAY TUBE)          | ~70% MAX. WALL PENETRATION<br>SEM & MET. COMPLETE   |
| R13-C67 (DISTORTED DENT)     | ~90% MAX. WALL PENETRATION<br>SEM & MET. COMPLETE<br>IGA ~250°  |
| R11-C69 (NON DISTORTED DENT) | ~90% MAX. WALL PENETRATION<br>SEM & MET. COMPLETE<br>IGA ~180°  |
| R32-C71 (LARGE DENT)         | EXAMINATION IN PROGRESS<br>IGA >50% BY VISUAL EXAMINATION   |
| R14-C70 (NORMAL T/S SIGNAL)  | BURST TEST COMPLETE<br>15,000 PSI MAX. PRESSURE<br>~1/8" LONGITUDINAL CRACK<br>VISUAL EXAMINATION COMPLETE<br>~50-60% WALL PENETRATION BY<br>VISUAL EXAMINATION |
| R17-C52 (CREVICE INDICATION) | ~80% MAX. WALL PENETRATION<br>MET. COMPLETE   |

SERIES 27  
SCE-A



← MANWAY

NOZZLE →


TUBES REMOVED-3(INLET)  
PLUGGED PRIOR TO APRIL, 1980

ROWS  
48  
47  
45  
43  
41  
39  
37  
35  
33  
31  
29  
27  
25  
23  
21  
19  
17  
15  
13  
11  
9  
7  
5  
3  
1

COLUMNS  
2  
4  
6  
8  
10  
12  
14  
16  
18  
20  
22  
24  
26  
28  
30  
32  
34  
36  
38  
40  
42  
44  
46  
48

SERIES 27

SCE-C



← --- MANWAY

NOZZLE --- →

○ TUBES REMOVED-4(INLET)

■ PLUGGED PRIOR TO APRIL, 1980

100  
99  
97  
95  
93  
91  
89  
87  
85  
83  
81  
79  
77  
75  
73  
71  
69  
67  
65  
63  
61  
59  
57  
55  
53  
51  
49  
47  
45  
43  
41  
39  
37  
35  
33  
31  
29  
27  
25  
23  
21  
19  
17  
15  
13  
11  
9  
7  
5  
3  
1

COLUMNS

48  
47  
46  
45  
44  
43  
42  
41  
40  
39  
38  
37  
36  
35  
34  
33  
32  
31  
30  
29  
28  
27  
26  
25  
24  
23  
22  
21  
20  
19  
18  
17  
16  
15  
14  
13  
12  
11  
10  
9  
8  
7  
6  
5  
4  
3  
2  
1

ROWS

## TUBE REMOVAL AND EXAMINATION

- Reasons:
1. To verify RPC data
  2. To provide sludge free sample for burst test in laboratory
  3. To outline boundary for sleeving

### Sample Removal:

Samples #1 & 2: Periphery tube, judged to have a small dent, but in good condition, i.e., <20% wall penetration. This tube will be used to obtain information to support items #1 and #3 above.

Samples #3, 4, & 5: Tubes judged to have penetration of <20%, 35%, and 62% as determined by RPC. Examinations and laboratory burst tests of these tubes will be used to support items #1 and #2 above.


Sample #6: Central region tube judged to be a non-dented "good" (NDD) by RPC. Examination of this tube will be used to support items #1 and #3 above.

### Logic:

Sample #1 will be removed first and a preliminary examination undertaken on site. This examination will consist of Visual Examination, Radiography, and Eddy Current testing. The result of this examination will enable a preliminary evaluation to be made on the validity of RPC and the condition of the corrosion free periphery area.

Sample #6 will be removed second to establish the condition of the central corrosion free region.

If sample #1 & #6 agree with expected results, tubes #3, 4, 5 and 2 will then be removed to obtain further confidence in the RPC data and to obtain representative tubes for laboratory pressure/leak rate/burst tests. If sample #1 and #6 do not agree with expected results, tubes #3, 4, 5 and 2 will not be removed since there will be uncertainty as to the actual tube condition and the RPC data is judged to be suspect.



SAN ONOFRE UNIT 1 TUBE PULL

SAN ONOFRE #1


TUBE PULL CANDIDATES

| CANDIDATE |          | BOBBIN         |         |                | RPC |
|-----------|----------|----------------|---------|----------------|-----|
| No.       | SG/R-C   | 400 kHz        | 100 kHz | Mixed          | %   |
| #1        | A-R23C83 | Med. Dent      | Yes     | Med. Dent      | NDD |
| #2a       | A-R22C83 | Med. Dent      | Yes     | Med. Dent      | NDD |
| #2b       | A-R22C84 | Sm. Dist. Dent | Yes     | Sm. Dent       | NDD |
| #3        | A-R12C70 | Sm. Dent       | Yes     | Sm. Dent       | 20% |
| #4a       | A-R15C70 | Sm. Dist. Dent | Yes     | Sm. Dist. Dent | 35% |
| #4b       | A-R20C85 | Med. Dent      | Yes     | Med. Dent      | 38% |
| #5        | A-R17C61 | Sm. Dent       | Yes     | Dist. Dent     | 62% |
| #6        | A-R20C60 | Normal Entry   | NDD     | NDD            | NDD |



SERIES 27

SCE-A



OR TUBES REMOVED-GUNLET) (OUTLET)  
PLUGGED PRIOR TO APRIL, 1980

## COLD LEG TUBE REMOVAL AND EXAMINATION

Reasons: To determine the need for additional tubing and to establish the need for sleeving the cold leg side of the steam generators.


Sample Removal: The sample to be removed should be one showing a large indication by bobbin and/or R.P.C.

Logic: The sample will be removed in a manner that will expedite on site determination of tube conditions. This on site examination will consist of radiography, eddy current and visual examination. This examination will provide the basis for a decision regarding immediate tube procurement. The tube will then be sent to Pittsburgh for a more critical examination to determine its condition.

Logic Chart: See attachment.

SERIES 27

SCE-A




←-- MANWAY  
JULY 12, 1980

SAN ONOFRE #1  
ROTATING PANCAKE COIL  
INSPECTION PLAN

NOZZLE ---> 107 Tubes  
COLD LEG to #1 TSP

7/12/80

COLD LEG TUBE REMOVAL



## INDIVIDUAL PRESSURE TESTS

### 1. Define good tubes/zone boundaries.

Pressurize to  $\geq 3000$  psig


If no leak, tube can withstand accident conditions

If tube leaks, evaluate options

- a) Sleeve
- b) Plug
- c) Operate at reduced conditions
- d) Combinations of a) to c).

### 2. Establish integrity of corroded tube

- a) In good zones
- b) In active zones



SCE #1/A TUBE PRESSURE TEST SELECTION


|        | <u>R-C</u> | <u>RPC</u><br>% <u>Arc°</u> | <u>CONV.</u> | <u>TYPE</u> |
|--------|------------|-----------------------------|--------------|-------------|
| ZONE 1 | A-13-70    | 55% 220°                    | NDD          | 1           |
|        | 13-71      | 89 240                      | NDD          | 2           |
|        | 11-60      | 97 350                      | NDD          | 4           |
| ZONE 2 | A-12-33    | 50% 180°                    | NDD          | 1           |
|        | 13-42      | 86 240                      | 80%          | 2           |
|        | 9-43       | 97 180                      | 45%          | 3           |
|        | 12-27      | <20 90                      | NDD          | 5           |
| ZONE 3 | A-24-39    | 69% 120°                    | NDD          | 1           |
|        | 24-43      | 64 150                      | NDD          | 1           |
|        | 24-42      | 83 120                      | NDD          | 2           |
|        | 17-63      | 96 180                      | NDD          | 3           |
|        | 17-48      | 94 210                      | NDD          | 4           |
| ZONE 4 | A-35-47    | 55% 90°                     | NDD          | 1           |
|        | 38-51      | 88 210                      | NDD          | 2           |
|        | 38-53      | 91 180                      | 33%          | 3           |
|        | 39-58      | 96 150                      | NDD          | 3           |
|        | 29-73      | 96 360                      | NDD          | 4           |
| ZONE 5 | A-34-76    | NDD -                       | NDD          | 5           |
|        | 43-59      | NDD -                       | NDD          | 5           |
|        | 40-34      | NDD -                       | NDD          | 5           |
|        | 28-18      | NDD -                       | NDD          | 5           |
|        | 12-13      | NDD -                       | NDD          | 5           |
|        | 8-90       | NDD -                       | NDD          | 5           |
| ZONE 6 | A-15-54    | NDD -                       | NDD          | 5           |
|        | 28-52      | NDD -                       | NDD          | 5           |

ZONE 1 - S/L Accessible Manway  
 2 - S/L Accessible Nozzle  
 3 - Quiet Centre  
 4 - Active Zone R34-40 C40-60  
 5 - Outer Periphery  
 6 - Central

TYPE 1 - <80%  
 2 - 80-90 Large Arc Length  
 3 - 90-100 Small Arc Length  
 4 - ≥94% Large Arc Length  
 5 - ≤20 or NDD

SERIES 27

SCE-A



← ← ← MANWAY

NOZZLE → → →

\* P.I.C. TESTED - 22  
\* P.I.C. TESTED - 100 TO APRIL, 1980

BASIS FOR DEFINING ACTIVE/INACTIVE ZONES


- 1) Plot RPC and bobbin EC data. Define zones encompassing all indications at top of tubesheet - SG-A.
- 2) Validate zone boundaries with results of tube pressure tests and tube pull results.
- 3) Obtain RPC data for B and C and repeat step 1).
- 4) Establish zone boundaries with similitude arguments from SG-A tube pressure tests and tube removal results
- 5) Confirm by results of primary hydro tests.



SERIES 27

SCE-A

INLET



← MANWAY

\* DISTORTED SIGNALS - 1353


NOZZLE →

ROWS

COLUMNS

SERIES 27

SCE-B  
INLET




←--- BANGA T

\* DISTORTED SIGNALS-1385

NOZZLE --->

48  
47  
46  
45  
44  
43  
42  
41  
40  
39  
38  
37  
36  
35  
34  
33  
32  
31  
30  
29  
28  
27  
26  
25  
24  
23  
22  
21  
20  
19  
18  
17  
16  
15  
14  
13  
12  
11  
10  
9  
8  
7  
6  
5  
4  
3  
2  
ROWS

COLUMNS




←-- MANWAY

SAN ONOFRE SLEEVING ZONE  
TENTATIVE SELECTION

NOZZLE --->  
ALL 3 STEAM GENERATORS

approximately 2500/SG  
approximately 1 tube beyond any pluggable indication  
applies to SG A, B, and C



DECON PROCESS DEVELOPMENT  
FOR STEAM GENERATOR  
CHANNELHEAD MAINTENANCE ACTIVITIES

HIGH PRESSURE WATER  
CHEMICAL  
DRY GRIT  
HYDRO/GRIT

## HYDRO/GRIT

- GRIT OPTIONS

- BORIC ACID
- MAGNETITE
- ALUMINA

- EXPECTED SURFACE DF

- BORIC ACID      5 - 10
- MAGNETITE      20 - 50
- ALUMINA        20 - 50

MAGNETITE GRIT

RECOMMENDED PROCESS

HI DF - 10 OR GREATER

RECYCLE - MINIMIZE WASTE VOLUME




FIGURE 1: DECON RECYCLE SYSTEM



## EXPERIENCE

### BORIC ACID GRIT - ONCE THRU SYSTEM

- DEVELOPMENT PROGRAM QUALIFICATION COMPLETE
- POINT BEACH, ONE CHANNEL HEAD - NO SIGNIFICANT DF
- TAK I, SIX CHANNEL HEAD - 2.5 DF.

### MAGNITATE GRIT - RECYCLE SYSTEM

- QUALIFIED DURING RETUBE PROGRAM
- HOT TEST SURFACE DF OF GREATER THAN 10 ACHIEVED

## TECHNICAL ISSUES

1. CLAD CONDITION AFTER DECON
2. RESIDUAL GRIT
  - CHEMISTRY COMPATIBLE
  - R.C. PUMP SEALS/CROM
3. DILUTION
4. WASTE HANDLING

EXPECTED WASTE PER STEAM GENERATOR

- THREE TONS OF MAGNETITE GRIT, (APPROXIMATELY 5 MICROCURIES PER GRAM)
- EIGHT TO TWELVE, 55 GALLON DRUMS
- 600 GALLON OF RECYCLE WATER (0.5 MICROCURIES PER MILLILITER)
- 2000 GALLONS OF RINSE WATER

- MORE ABRASIVE GRIT

- TUBE DECON

- PIPE NOZZLE SHIELD

- HAND CLEANUP

PRELIMINARY LICENSING INFORMATION SCHEDULE

|                                   |                 |
|-----------------------------------|-----------------|
| PRELIMINARY DISCUSSIONS W/NRC     | 6/18, 7/1, 7/10 |
| PRESENTATION OF PROGRAM PLAN      | 7/22            |
| NRC MEETING TO DISCUSS SLEEVING   | 7/31            |
| NRC MEETING TO UPDATE INFORMATION | 8/15            |
| NRC MEETING & SLEEVING REPORT     | 9/1             |
| NRC APPROVAL TO INSTALL SLEEVES   | 9/10            |
| FINAL 50.59 REPORT                | 10/7            |
| NRC APPROVAL TO RESUME OPERATION  | 11/1            |

PURPOSE OF MEETING

- OPENING TECHNICAL DISCUSSION OF THE SCE SLEEVING PROGRAM
  
- DESIGN AND PROCESS DISCUSSION
  
- ALARA CONSIDERATIONS
  
- ESTABLISH CONTENTS OF 8/15 MEETING.

## SLEEVING PROGRAM

### PURPOSE

- TO DEVELOP A REPAIR PROCEDURE FOR A DEFECTIVE TUBE AS AN ALTERNATE TO PLUGGING, THUS EXTENDING STEAM GENERATOR LIFE

### OVERALL TECHNICAL OBJECTIVE

- DEVELOP A LEAK TIGHT BOND BETWEEN SLEEVE AND TUBE
- DEVELOP A REMOTE TOOLING INSTALLATION SYSTEM


### POTENTIAL SEALING METHODS

- BRAZING
- MECHANICAL
- WELDING

### POTENTIAL EXPANSION METHODS

- HYDRAULIC
- ROLL

SERIES 27





## ALARA ACTIVITIES

- DECON BOWL AND TUBES
- REMOTE TOOLING
- SHIELDING
- MOCK-UP TRAINING
- TV SURVEILLANCE
- ADMINISTRATION CONTROLS
- ENVIRONMENTAL CONTROLS
- MODEL AND MONITOR EXPOSURES

Licensing Information Schedule

|  |                 |
|--|-----------------|
| Preliminary Discussions w/NRC                              | 6/18, 7/1, 7/10 |
| Presentation of Program Plan                               | 7/22            |
| NRC Meeting to Discuss Slewing                             | 7/31            |
| NRC Meeting to Update Info                                 | 8/15            |
| NRC Mtg & Slewing Report<br>Including Zones to be Repaired | 9/1             |
| NRC Approval to Install Sleeves                            | 9/10            |
| Final Revised Reload Safety Evaluation Report              | 10/7            |
| NRC Approval to Resume Operation                           | 11/1            |

SLEEVING REPORT  
LICENSING INFORMATION

- Design Concept
- Design Analysis
- Prototype Testing
  - Pressure Testing
  - Thermal Cycling
  - Corrosion Testing
- Inspectability
  - Installation
  - Inservice
- Material Compatibility
- Installation Concept
- ALARA
- Criteria for Zones Repaired
- 10 CFR 50.59 Design Change Review

## Revised Reload Safety Evaluation Report

### Description of Repaired Steam Generators

- Inspection Results
- Tube Removal and Examination Results
- Individual Tube Pressure Test Results
- Zones Repaired (Sleeved and/or Plugged)
- Sleeving Report (Referenced)

### Evaluation of Plant Performance

- Reduced Temperature, Pressure and Power
- T/H Effects of Sleeving
- LOCA Analyses
- Non-LOCA Analyses
- Functional Set Point Changes

### Licensing and Technical Specification Changes

### Operational Considerations

- Chemical Flushing
- Chemical Control Improvements