



Southern California Edison Company NRC

P. O. BOX 800

2244 WALNUT GROVE AVENUE

ROSEMEAD, CALIFORNIA 91770

RECEIVED
NRC
REGION V

PROC JAN 13 A 10:02

M. O. MEDFORD
MANAGER OF NUCLEAR ENGINEERING
AND LICENSING

TELEPHONE
(818) 302-1749

January 12, 1988

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. John B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-206, 50-361 and 50-362
San Onofre Nuclear Generating Station
Units 1, 2 and 3

As requested in NRC Compliance Bulletin No. 87-02, Fastener Testing to Determine Conformance with Applicable Material Specifications, Southern California Edison (SCE) hereby provides information on the adequacy of fasteners for use at San Onofre Units 1, 2 and 3. The information concerning fastener receipt inspection, internal control procedures and results of independent testing is provided in the enclosure to this letter in accordance with Actions 1 through 6 in the bulletin.

Based upon the review conducted by SCE to develop the requested information, it is concluded that the safety related and non-safety related fasteners at San Onofre are properly identified and the safety related fasteners satisfy the procurement specifications. Non-safety related fasteners satisfy material code specifications.

8801270123 880112
PDR ADOCK 05000206
Q PDR

11
TE-11

Mr. J. B. Martin

-2-

January 12, 1988

Minor warehouse procedure changes have recently been initiated which should provide additional assurance that fasteners are properly controlled. No additional changes are considered necessary.

Subscribed on this 12th day of January, 1988.


Respectfully submitted,

SOUTHERN CALIFORNIA EDISON COMPANY

By: M O Medford
M. O. Medford
Manager of Nuclear Engineering
and Licensing

Subscribed and sworn to before me this
12th day of January 1988.

Agnes Crabtree
Notary Public in and for the County of
Los Angeles, State of California



Enclosure

cc: U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555
C. Trammel, NRR Project Manager, San Onofre Unit 1
D. Hickman, NRR Project Manager, San Onofre Units 2 and 3
F. R. Huey, NRC Senior Resident Inspector, San Onofre Units 1, 2 and 3

