



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
RELATED TO AMENDMENT NO. 150 TO FACILITY OPERATING LICENSE NO. DPR-13

SOUTHERN CALIFORNIA EDISON COMPANY

SAN DIEGO GAS AND ELECTRIC COMPANY

SAN ONOFRE NUCLEAR GENERATING STATION, UNIT NO. 1

DOCKET NO. 50-206

1.0 INTRODUCTION

By letter dated April 2, 1992, Southern California Edison Company (SCE or the licensee) proposed to amend Facility Operating License No. DPR-13 to a Possession-Only License (POL) for the San Onofre Nuclear Generating Station, Unit 1 (SONGS-1 or the facility). The POL would permit the licensee to possess but not operate the facility. Although the SONGS-1 reactor has not been shut down, the licensee has proposed that a POL be approved while the facility is still operating, to become effective upon the permanent cessation of operation and certification to the NRC that all fuel has been offloaded from the reactor and stored in the spent fuel pool. On May 13, 1992, the NRC published in the Federal Register (57 FR 20518), a Notice of Consideration of Issuance of Amendment to Facility Operating License and Proposed No Significant Hazards Consideration Determination and Opportunity for Hearing for the requested amendment. No public comments nor requests for intervention were received.

2.0 BACKGROUND

SONGS-1 received a Provisional Operating License on March 27, 1967 and began commercial operation on January 1, 1968. A Full-Term Operating License (OL) was not issued until September 26, 1991. The OL was to expire on March 2, 2004, 40 years after the issuance of the SONGS-1 Construction Permit. The delay in issuing the OL was due primarily to an NRC staff reevaluation of the plant design to reconfirm its safety in light of operating experience and updated design standards that had developed since the plant was built in the 1960s.

The NRC staff review concluded that numerous modifications were required to SONGS-1 to upgrade the plant to safety standards that were in effect at newer nuclear power stations. SCE made many of the identified upgrades and

9801080365 921023  
PDR ADDOCK 05000206  
P PDR

committed to complete most of the modifications before restarting the reactor from Refueling Outage 12. Refueling Outage 12 was scheduled at the end of 1992. The NRC formalized the licensee's commitment to complete the SONGS-1 modifications by issuing a Confirmatory Order on January 2, 1990. Based on the formalized commitment to upgrade the plant to contemporary safety standards, the NRC issued the OL in 1991.

While reviewing the SCE rate case, the California Public Utilities Commission (CPUC) concluded that the required upgrades for SONGS-1 were not cost effective and refused to permit the licensee to pass on the cost of the plant modifications to the ratepayers. Lacking a means to recoup the cost of the NRC mandated upgrades, SCE decided to stop power operations at SONGS-1 and requested to amend the license to a POL.

### 3.0 DISCUSSION AND EVALUATION

The licensee has requested that the POL become effective upon certification that all reactor fuel has been removed from the reactor and stored in the spent fuel pool. The SCE letter of April 2, 1992, requested changes to the license that would permit the licensee to possess and maintain the facility but not operate it. The requested changes to the license are consistent with the expected permanent cessation of operation and reactor defueling. The staff's safety evaluation of the requested license changes is provided in the following paragraphs.

The probability of previously analyzed design basis accidents occurring with the plant in a defueled condition will be significantly reduced for the following reasons: (1) no significant safety hazards could result as the facility will be in a nonoperating condition and the entire core will be in the spent fuel pool; the consequences of credible fuel pool accidents, which are analyzed in Chapters 9 and 15 of the Final Safety Analysis Report, would be unchanged by the POL issuance; and (2) there is reasonable assurance that the common defense and security and the health and safety of public will not be endangered by the defueled, nonoperating status of the reactor. Based on the above, the staff concludes that there are no significant hazards considerations that would result from the issuance of a POL that becomes effective upon the complete defueling of the reactor vessel to the spent fuel pool.

The licensee's letter of April 2, 1992, proposed modifications to the Facility Operating License in order to convert it to a Possession Only License. The staff reviewed these proposals and determined that they are acceptable for the future nonoperating and defueled status of the reactor. In summary, the changes permit the licensee to maintain and possess the facility but not to operate it. The staff's evaluation of these changes is presented below:

1. Modify license paragraph 2.B.(1) to replace the reference to use and operation with possession but not operation.

Evaluation: This change is acceptable as it removes the facility from an operating status.

2. Modify license paragraph 2.B.(2) to remove the authorization to receive and use special nuclear material used as reactor fuel at the facility.

Evaluation: This change is acceptable as it removes the licensee's authority to receive and use special nuclear material as reactor fuel. This change is consistent with the eventual nonoperating status of the facility.

3. Modify license paragraph 2.B.(3) to remove the reference to reactor startup.

Evaluation: This change is acceptable as it removes an unnecessary use of special nuclear material as sealed neutron sources used only for startup. In addition, the remainder of this paragraph would properly allow the licensee to receive, possess, and use radioactive devices needed for radiation monitoring and instrument calibration as this use enables monitoring plant and environmental conditions which remain a condition of the POL and the Technical Specifications.

4. Modify license paragraph 2.C.(1) to remove the wording which authorizes the facility to operate at core power levels not in excess of 1346 megawatts thermal.

Evaluation: This change is acceptable as it removes the licensed authority to operate the facility. The new paragraph 2.C.(1) will read: "The licensee is not authorized to operate the facility as a nuclear reactor."

5. Modify license paragraph 2.F to reflect that this amendment is effective when the licensee provides certification in writing that all reactor fuel has been permanently offloaded from the reactor and stored in the spent fuel pool.

Evaluation: This change is acceptable in that it reflects the conditions of the reactor vessel that provide the basis for the staff's finding of no significant hazards considerations that would result from the issuance of this POL.

#### 4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the California State official was notified of the proposed issuance of the amendment. The State official had no comments.

#### 5.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes surveillance requirements. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative

occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (57 FR 20518). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

## 6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: John P. Moulton

Date: October 23, 1992



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

October 23, 1992

13E16

November 12, 1992

57 FR 53792

MEMORANDUM: Sholly Coordinator

FROM: John O. Bradfute, Acting Project Manager  
Project Directorate V  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactors Regulation

SUBJECT: REQUEST FOR PUBLICATION IN BIWEEKLY FR NOTICE - NOTICE OF  
ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE  
(TAC NO. M83123)

Southern California Edison Company, et al., Docket No. 50-206, San Onofre  
Nuclear Generating Station, Unit No. 1, San Diego County, California

Date of application for amendment: April 2, 1992

Brief description of amendment: The amendment modifies Facility Operating  
License No. DPR-13 to a Possession Only License (POL) upon the permanent  
cessation of operations and the removal of all fuel from the core.

Date of issuance: October 23, 1992

Effective date: Upon certification to the NRC that all reactor fuel has been  
permanently offloaded from the reactor and stored in the spent fuel pool.

Amendment No.: 150

Facility Operating License No. DPR-13: The amendment modifies the operating  
license to a POL.

Date of initial notice in FEDERAL REGISTER: May 13, 1992 (57 FR 20518)

The Commission's related evaluation of the amendment is contained in a Safety  
Evaluation dated October 23, 1992.

No significant hazards consideration comments received: No.

Sholly Coordinator

October 23, 1992

Local Public Document Room location: Main Library, University of California,  
P. O. Box 19557, Irvine, California 92713

*Theodore B. May for*

John O. Bradfute, Acting Project Manager  
Project Directorate V  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

DISTRIBUTION:

Docket File 50-206  
ONDD Reading File  
PDV Reading File  
JBradfute  
SWeiss  
EHylton  
~~DFoster~~  
Sholly Coordinator (Orig+1)  
OGC (MS15B18)  
JMoulton  
TQuay  
RDudley

\*See Previous concurrence

PDV/LA	PDNP/PE*	PDV/PM <i>pm</i>	PDNP/D*	
DFoster <i>DFoster</i>	JMoulton/vsb	JBradfute <i>JBradfute</i>	SWeiss	
10/23/92	09/03/92	10/23/92	09/08/92	

DOCUMENT NAME: M83123.JM

Big Rock Point Inservice Inspection Program be performed in accordance with the Big Rock Point Intergranular Stress Corrosion Cracking (IGSCC) Program.

*Date of issuance:* October 19, 1992

*Effective date:* October 19, 1992

*Amendment No.:* 108

*Facility Operating License No.* DPR-6. The amendment revises the Technical Specifications.

*Date of initial notice in Federal Register:* April 29, 1992 (57 FR 18172) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 19, 1992. No significant hazards consideration comments received: No.

*Local Public Document Room location:* North Central Michigan College, 1515 Howard Street, Petoskey, Michigan 49770.

*Indiana Michigan Power Company, Docket No. 50-315, Donald C. Cook Nuclear Plant, Unit No. 1, Berrien County, Michigan*

*Date of application for amendment:* October 29, 1990 as supplemented June 18, 1991 and April 13, 1992.

*Brief description of amendments:* This amendment changes Technical Specifications (TS) concerning, "Pressure-Temperature Limits," to limit the maximum heat-up rate to 60 F/hr and to provide revised heat-up and cooldown pressure-temperature (P-T) limit curves. In addition, the amendment changes the TS to reflect revisions to the pressure set point and enable temperature for the low-temperature overpressure protection system. The revisions are based on a reanalysis of reactor vessel sample material in accordance with Regulatory Guide 1.99, Revision 2. Through this licensing action the guidance of Generic Letter 88-11 has been followed for D. C. Cook, Unit No. 1.

*Date of issuance:* October 28, 1992

*Effective date:* October 28, 1992

*Amendments Nos.:* 167 Facility Operating Licenses Nos. DPR-58 and DPR-74. Amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* November 28, 1990 (55 FR 49452). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated October 28, 1992. No significant hazards consideration comments received: No.

*Local Public Document Room location:* Maude Preston Palenske Memorial Library, 500 Market Street, St. Joseph, Michigan 49085.

*Pennsylvania Power and Light Company, Docket No. 50-388, Susquehanna Steam Electric Station, Unit 2, Luzerne County, Pennsylvania*

*Date of application for amendment:* June 30, 1992, as supplemented July 21, 1992, and October 19, 1992

*Brief description of amendment:* This amendment changes the Technical Specifications in support of the Unit 2, Cycle 6 reload, which will consist of fresh SNP 9x9(SQB-5) fuel assemblies and irradiated SNP 9x9(XN-3), (XN-2) and (XN-1) assemblies. Changes have been made to the following TS and Bases: a. B 2.1 Safety Limits b. 3/4.2.1 Average Planar Linear Heat Generation Rate c. 3/4.2.2 APRM Setpoints d. 3/4.2.3 Minimum Critical Power Ratio e. 3/4.2.4 Linear Heat Generation Rate f. 3/4.4.1 Recirculation System g. B 3/4.1 Reactivity Control System h. B 3/4.2 Power Distribution Limits i. B 3/4.4.1 Recirculation System j. 5.3.1 Fuel Assemblies

*Date of issuance:* October 28, 1992

*Effective date:* October 28, 1992

*Amendment No.:* 91

*Facility Operating License No.* NPF-22. This amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* September 16, 1992 (57 FR 42776) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 28, 1992. No significant hazards consideration comments received: No

*Local Public Document Room location:* Osterhout Free Library, Reference Department, 71 South Franklin Street, Wilkes-Barre, Pennsylvania 18701.

*Pennsylvania Power and Light Company, Docket No. 50-388, Susquehanna Steam Electric Station, Unit 2, Luzerne County, Pennsylvania*

*Date of application for amendment:* August 7, 1992

*Brief description of amendment:* This amendment would make a change to the Susquehanna Steam Electric Station (SSES), Unit 2 Technical Specifications that changes the isolation signal for suppression pool cleanup line valves HV-25766 and HV-25768 from reactor vessel low water level 3 (+13") or high drywell pressure to reactor vessel low water level 2 (-38") or high drywell pressure.

*Date of issuance:* October 29, 1992

*Effective date:* October 29, 1992

*Amendment No.:* 92

*Facility Operating License No.* NPF-22. This amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* September 2, 1992 (57 FR 40218) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 29, 1992. No significant hazards consideration comments received: No

*Local Public Document Room location:* Osterhout Free Library, Reference Department, 71 South Franklin Street, Wilkes-Barre, Pennsylvania 18701.

*Southern California Edison Company, et al., Docket No. 50-206, San Onofre Nuclear Generating Station, Unit No. 1, San Diego County, California*

*Date of application for amendment:* April 2, 1992

*Brief description of amendment:* The amendment modifies

*Facility Operating License No.* DPR-13 to a Possession Only License (POL) upon the permanent cessation of operations and the removal of all fuel from the core.

*Date of issuance:* ~~April 2, 1992~~ Oct 23, 1992

*Effective date:* Upon certification to the NRC that all reactor fuel has been permanently offloaded from the reactor and stored in the spent fuel pool.

*Amendment No.:* 150

*Facility Operating License No.* DPR-13: The amendment modifies the operating license to a POL.

*Date of initial notice in Federal Register:* May 13, 1992 (57 FR 20518) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 23, 1992. No significant hazards consideration comments received: No.

*Local Public Document Room location:* Main Library, University of California, P. O. Box 19557, Irvine, California 92713

*Tennessee Valley Authority, Docket Nos. 50-259, 50-260 and 50-296, Browns Ferry Nuclear Plant, Units 1, 2 and 3, Limestone County, Alabama*

*Date of application for amendments:* April 1, 1992 (TS 311)

*Brief description of amendments:* These license amendments revise the Browns Ferry Nuclear Plant Technical Specifications by removing provisions that limit the combined interval of consecutive surveillances to less than 3.25 times the specified interval in accordance with the guidance of Generic Letter 89-14.

*Date of issuance:* October 19, 1992

*Effective date:* October 19, 1992

*Amendment Nos.:* 188 Unit 1; 203 Unit 2; 160 Unit 3



UNITED STATES  
**NUCLEAR REGULATORY COMMISSION**  
 WASHINGTON, D.C. 20555

December 14, 1992

DISTRIBUTION  
 Docket File (50-206)  
 PDV Reading File  
 JBradfute  
 ✓DFoster  
 EHylton, 11B20

DOCKET NO. 50-206

**MEMORANDUM FOR:** Regulatory Publications Branch  
 Division of Freedom of Information and Publications Services  
 Office of Administration and Resources Management

**FROM:** Office of Nuclear Reactor Regulation

**SUBJECT:** SAN ONOFRE NUCLEAR GENERATING STATION UNIT 1

One signed original of the *Federal Register* Notice identified below is enclosed for your transmittal to the Office of the Federal Register for publication. Additional conformed copies ( 5 ) of the Notice are enclosed for your use.

- Notice of Receipt of Application for Construction Permit(s) and Operating License(s).
- Notice of Receipt of Partial Application for Construction Permit(s) and Facility License(s); Time for Submission of Views on Antitrust Matters.
- Notice of Consideration of Issuance of Amendment to Facility Operating License. (Call with \_\_\_-day insert date).
- Notice of Receipt of Application for Facility License(s); Notice of Availability of Applicant's Environmental Report; and Notice of Consideration of Issuance of Facility License(s) and Notice of Opportunity for Hearing.
- Notice of Availability of NRC Draft/Final Environmental Statement.
- Notice of Limited Work Authorization.
- Notice of Availability of Safety Evaluation Report.
- Notice of Issuance of Construction Permit(s).
- Notice of Issuance of Facility Operating License(s) or Amendment(s).
- Order.
- Exemption.
- Notice of Granting Exemption.
- Environmental Assessment.
- Notice of Preparation of Environmental Assessment.
- Receipt of Petition for Director's Decision Under 10 CFR 2.206.
- Issuance of Final Director's Decision Under 10 CFR 2.206.
- Other: Correction to Biweekly Notice

Division of Reactor Project III/IV/V  
 Office of Nuclear Reactor Regulation

Enclosure:  
 As stated

Contact: J. Bradfute  
 Phone: (301) 504-1381



NUCLEAR REGULATORY COMMISSION

CORRECTION TO BIWEEKLY NOTICE

APPLICATIONS AND AMENDMENTS TO OPERATING LICENSES INVOLVING


NO SIGNIFICANT HAZARDS CONSIDERATIONS

In the Biweekly Notice beginning on page 53792 in the issue of Thursday, November 12, 1992, make the following correction:

On page 53792, "Date of issuance: April 2, 1992" should read

"Date of issuance: October 23, 1992."

FOR THE NUCLEAR REGULATORY COMMISSION

  
James W. Clifford, Director  
Project Directorate V  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

NUCLEAR REGULATORY COMMISSION  
CORRECTION TO BIWEEKLY NOTICE  
APPLICATIONS AND AMENDMENTS TO OPERATING LICENSES INVOLVING  
NO SIGNIFICANT HAZARDS CONSIDERATIONS

In the Biweekly Notice beginning on page 53792 in the issue of Thursday, November 12, 1992, make the following correction:

On page 53792, "Date of issuance: April 2, 1992" should read "Date of issuance: October 23, 1992."

FOR THE NUCLEAR REGULATORY COMMISSION

Original signed by

James W. Clifford, Director  
 Project Directorate V  
 Division of Reactor Projects III/IV/V  
 Office of Nuclear Reactor Regulation

DISTRIBUTION:

Docket File (50-206)  
 PDV Reading File  
 J. Bradfute  
 D. Foster  
 B. Golden (Orig. + 5 cys)  
 T. Quay  
 J. Clifford

OFC	LA/PDV/DRPW	PM/PDV/DRPW	AD/PDV/DRPW
NAME	DFoster <i>DFoster</i>	JBradfute:mc	JClifford <i>JClifford</i>
DATE	12/14/92	12/14/92	12/14/92

OFFICIAL RECORD COPY

DOCUMENT NAME: B WEEKLY.COR

Endowment for the Arts, Washington, DC 20506, or call (202) 662-5439.

Dated: December 15, 1992.

Yvonne M. Sabine,

Director, Panel Operations, National Endowment for the Arts.

[FR Doc. 92-30906 Filed 12-18-92; 8:45 am]

BILLING CODE 7537-01-M

## NATIONAL SCIENCE FOUNDATION

### Special Emphasis Panel in Atmospheric Sciences; Notice of Meeting

In accordance with the Federal Advisory Committee Act (Pub. L. 92-463, as amended), the National Science Foundation announces the following meeting.

*Date and Time:* Wednesday, January 6, 1993; 8 a.m. to 5 p.m.

*Place:* Room 523, National Science Foundation, 1800 G Street, NW., Washington, DC.

*Type of Meeting:* Closed

*Contact Person:* Dr. Richard S. Greenfield, Section Head, Lower Atmosphere Research, Division of Atmospheric Sciences, National Science Foundation, 1800 G St. NW., Washington, DC 20550. Telephone: (202) 357-7645.

*Purpose of Meeting:* To provide advice and recommendations concerning proposal submitted to NSF for financial support.

*Agenda:* To review and evaluate the NCAR Research Aircraft Fleet Restructuring proposal as part of the selection process for an award.

*Reason for Closing:* The proposal being reviewed includes information of a proprietary or confidential nature, including technical information; financial data, such as salaries; and personal information concerning individuals associated with the proposal. These matters are exempt under 5 U.S.C. 552(b)(4), (4) and (6) of the Government in the Sunshine Act.

Dated: December 14, 1992.

M. Rebecca Winkler,

Committee Management Officer.

[FR Doc. 92-30902 Filed 12-18-92; 8:45 am]

BILLING CODE 7565-01-M

## NUCLEAR REGULATORY COMMISSION

### Correction to Biweekly Notice Applications and Amendments to Operating Licenses Involving No Significant Hazards Considerations

In the Biweekly Notice beginning on page 53781 in the issue of Thursday, November 12, 1992, make the following correction:

On page 53792, in the third column, under the Southern California Edison Company, et. al. heading, "Date of

issuance: April 2, 1992" should read "Date of issuance: October 23, 1992."

For the Nuclear Regulatory Commission.

James W. Clifford,

Director, Project Directorate V, Division of Reactor Projects III/IV/V, Office of Nuclear Reactor Regulation.

[FR Doc. 92-30856 Filed 12-18-92; 8:45 am]

BILLING CODE 7530-01-M

[Docket Nos. 50-424-OLA-3 50-425-OLA-3

Georgia Power Co., et al.; (Vogtle Electric Generating Plant, Units 1 and 2)

Atomic Safety and Licensing Board

Before Administrative Judges:

Peter B. Bloch, Chair

Dr. James H. Carpenter

Thomas D. Murphy

Re: License Amendment (Transfer to Southern Nuclear)

ASLBP No. 96-671-01-OLA-3

December 14, 1992.

(Limited Appearances; Prehearing Conference)

Pursuant to 10 CFR 2.715 and 2.752<sup>1</sup>, we will hold a public limited appearance session from 7 pm to up to 10 pm (as required), January 11, 1993, and a public prehearing conference from 9 am until 11 am on January 12, at the Law Enforcement Center, room 240, 401 Walton Way, Augusta, Georgia 30911.

Limited appearances may be written or oral. People wishing to speak at the limited appearance session may obtain priority by mailing a letter on or before January 5 to: Licensing Board (Georgia Power), U.S. Nuclear Regulatory Commission, Washington, DC 20555. Written appearances may be mailed to the same address or submitted at the Limited Appearance session. Limited Appearances will be listened to or read carefully but are not part of the decisional record and may not, therefore, form a basis for the opinion of the Board. Each appearance will be limited to from five to ten minutes, depending on the number of speakers; the time limit will be announced at the beginning of the session.

For the Atomic Safety and Licensing Board, Bethesda, Maryland.

Peter B. Bloch,

Chair.

[FR Doc. 92-30859 Filed 12-18-92; 8:45 am]

BILLING CODE 7530-01-M

<sup>1</sup> See also § 2.751a.

[Docket No. 50-445]

### TU Electric Co.; Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for Hearing

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-87 issued to TU Electric Company (the licensee) for operation of the Comanche Peak Steam Electric Station, Unit 1 (CPSES) located in Somervell County, Texas.

The proposed amendment would revise the Unit 1 Technical Specifications to include revised heatup and cooldown curves for the reactor coolant system, revised limits for the power-operated relief valve (PORV) setpoints, and the addition of a specification for feedwater isolation valve pressure/temperature limits. These changes are required to support the licensing of Comanche Peak Steam Electric Station Unit 2.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

The Commission has made a proposed determination that the amendment request involves no significant hazards consideration. Under the Commission's regulations in 10 CFR 50.92, this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

(1) The proposed changes do not involve a significant increase in the probability or consequences of an accident previously evaluated.

The following changes affect the pressure/temperature limits which define the acceptable regions of operation:

- The 50 psi decrease in heatup/ cooldown curve;
- The 39 psi decrease in a portion of the PORV setpoint curve;
- The addition of the 20°F/hour heatup curve; and

Endowment for the Arts, Washington, DC 20506, or call (202) 682-5439.

Dated: December 15, 1992.

Yvonne M. Sabine,

Director, Panel Operations, National Endowment for the Arts.

[FR Doc. 92-30906 Filed 12-18-92; 8:45 am]

BILLING CODE 7537-01-M

## NATIONAL SCIENCE FOUNDATION

### Special Emphasis Panel In Atmospheric Sciences; Notice of Meeting

In accordance with the Federal Advisory Committee Act (Pub. L. 92-463, as amended), the National Science Foundation announces the following meeting.

**Date and Time:** Wednesday, January 6, 1993; 8 a.m. to 5 p.m.

**Place:** Room 523, National Science Foundation, 1800 G Street, NW., Washington, DC.

**Type of Meeting:** Closed

**Contact Person:** Dr. Richard S. Greenfield, Section Head, Lower Atmosphere Research, Division of Atmospheric Sciences, National Science Foundation, 1800 G St. NW., Washington, DC 20550. Telephone: (202) 357-7645.

**Purpose of Meeting:** To provide advice and recommendations concerning proposal submitted to NSF for financial support.

**Agenda:** To review and evaluate the NCAR Research Aircraft Fleet Restructuring proposal as part of the selection process for an award.

**Reason for Closing:** The proposal being reviewed includes information of a proprietary or confidential nature, including technical information; financial data, such as salaries; and personal information concerning individuals associated with the proposal. These matters are exempt under 5 U.S.C. 552b(c), (4) and (6) of the Government in the Sunshine Act.

Dated: December 14, 1992.

M. Rebecca Winkler,

Committee Management Officer.

[FR Doc. 92-30902 Filed 12-18-92; 8:45 am]

BILLING CODE 7555-01-M

## NUCLEAR REGULATORY COMMISSION

### Correction to Biweekly Notice Applications and Amendments to Operating Licenses Involving No Significant Hazards Considerations

In the Biweekly Notice beginning on page 53781 in the issue of Thursday, November 12, 1992, make the following correction:

On page 53792, in the third column, under the Southern California Edison Company, et. al. heading, "Date of

issuance: April 2, 1992" should read "Date of issuance: October 23, 1992."

For the Nuclear Regulatory Commission.

James W. Clifford,

Director, Project Directorate V, Division of Reactor Projects III/IV/V, Office of Nuclear Reactor Regulation.

[FR Doc. 92-30858 Filed 12-18-92; 8:45 am]

BILLING CODE 7590-01-M

[Docket Nos. 50-424-OLA-3 50-425-OLA-3

### Georgia Power Co., et al.; (Vogtle Electric Generating Plant, Units 1 and 2)

Atomic Safety and Licensing Board

Before Administrative Judges:

Peter B. Bloch, Chair

Dr. James H. Carpenter

Thomas D. Murphy

Re: License Amendment (Transfer to Southern Nuclear)

ASLBP No. 96-671-01-OLA-3

December 14, 1992.

(Limited Appearances; Prehearing Conference)

Pursuant to 10 CFR 2.715 and 2.752<sup>1</sup>, we will hold a public limited appearance session from 7 pm to up to 10 pm (as required), January 11, 1993, and a public prehearing conference from 9 am until 11 am on January 12, at the Law Enforcement Center, room 240, 401 Walton Way, Augusta, Georgia 30911.

Limited appearances may be written or oral. People wishing to speak at the limited appearance session may obtain priority by mailing a letter on or before January 5 to: Licensing Board (Georgia Power), U.S. Nuclear Regulatory Commission, Washington, DC 20555. Written appearances may be mailed to the same address or submitted at the Limited Appearance session. Limited Appearances will be listened to or read carefully but are not part of the decisional record and may not, therefore, form a basis for the opinion of the Board. Each appearance will be limited to from five to ten minutes, depending on the number of speakers; the time limit will be announced at the beginning of the session.

For the Atomic Safety and Licensing Board, Bethesda, Maryland.

Peter B. Bloch,

Chair.

[FR Doc. 92-30859 Filed 12-18-92; 8:45 am]

BILLING CODE 7590-01-M

<sup>1</sup> See also § 2.751a.

[Docket No. 50-445]

### TU Electric Co.; Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for Hearing

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-87 issued to TU Electric Company (the licensee) for operation of the Comanche Peak Steam Electric Station, Unit 1 (CPSES) located in Somervell County, Texas.

The proposed amendment would revise the Unit 1 Technical Specifications to include revised heatup and cooldown curves for the reactor coolant system, revised limits for the power-operated relief valve (PORV) setpoints, and the addition of a specification for feedwater isolation valve pressure/temperature limits. These changes are required to support the licensing of Comanche Peak Steam Electric Station Unit 2.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

The Commission has made a proposed determination that the amendment request involves no significant hazards consideration. Under the Commission's regulations in 10 CFR 50.92, this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

(1) The proposed changes do not involve a significant increase in the probability or consequences of an accident previously evaluated.

The following changes affect the pressure/temperature limits which define the acceptable regions of operation:

- The 50 psi decrease in heatup/cooldown curve;
- The 39 psi decrease in a portion of the PORV setpoint curve;
- The addition of the 20°F/hour heatup curve; and

**Southern California Edison Company**

23 PARKER STREET

IRVINE, CALIFORNIA 92718

HAROLD B. RAY  
SENIOR VICE PRESIDENT

April 2, 1992

TELEPHONE  
714-458-4400

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

Subject: **Docket No. 50-206**  
**Amendment Application No. 203,**  
**San Onofre Nuclear Generating Station, Unit 1**


Enclosed is Amendment Application No. 203 to the Facility Operating License No. DPR-13 for San Onofre Nuclear Generating Station, Unit 1. Amendment Application No. 203 consists of Proposed Change No. 254.

The proposed change will modify the Facility License to a "Possession Only License" to allow San Onofre Nuclear Generating Station Unit 1 (SONGS 1) to possess special nuclear material but not operate the nuclear reactor at the completion of Fuel Cycle 11. SCE has reached an agreement with the California Public Utilities Commission staff to permanently close the plant at the end of fuel cycle 11, including the possibility of a fuel shuffle and extended fuel cycle operation.

The purpose of the Possession Only License is to provide the licensing basis for the Nuclear Regulatory Commission (NRC) to grant Southern California Edison (SCE) regulatory relief from certain operating requirements that are inappropriate for a permanently shutdown and defueled reactor.

If you have any comments or questions regarding this amendment application, please contact me.

Very truly yours,



cc: J. B. Martin, Regional Administrator, NRC Region V  
George Kalman, NRC Senior Project Manager, San Onofre Unit 1  
J. O. Bradfute, NRC Project Manager, San Onofre Unit 1  
C. W. Caldwell, NRC Senior Resident Inspector, San Onofre Units 1, 2&3  
J. H. Hickman, California Department of Health Services

9204070136-920402  
PDR ADOCK 05000206  
P PDR

A001