

June 1, 1989

Docket Nos. 50-361
50-362

FACILITIES: San Onofre Nuclear Generating Station, Unit Nos. 2 and 3

LICENSEE: Southern California Edison Company

SUBJECT: SUMMARY OF MEETING HELD ON MAY 23, 1989 TO DISCUSS
CAPACITY OF STEAM GENERATOR SAFETY VALVES

On May 23, 1989, the NRC staff met with representatives of Southern California Company (SCE) to discuss the relief capacity of the steam generator safety valves at SONGS 2 and 3. Persons attending are identified on Enclosure 1. Viewgraphs presented at the meeting are shown on Enclosure 2. The meeting was held pursuant to notice issued on May 15, 1989. Highlights of the meeting are summarized below.

Following issuance of NRC Information Notice No. 86-05 on January 31, 1986 on main steam safety valves, a Westinghouse Owners Group Subcommittee was formed representing about sixteen licensees of plants fitted with Crosby safety valves to investigate why the Seabrook and Vogtle valves had low capacities. The test program involved four valve types, eleven different springs, five different nozzle and guide ring settings and various set pressures involving some 235 tests. The test report prepared by the owner's group subcommittee will be formally transmitted to NRC in about two weeks. An advance copy was delivered at the meeting. Each licensee will need to evaluate the results for its specific plant, e.g., current ring settings, and evaluate the effect of changing ring settings as required.

As applied to SONGS 2 and 3, the currently installed valves have about 75% of the nameplate rating, whereas only 66% capacity is needed to meet the capacity requirements for the worst overpressure transient (loss of load w/no turbine bypass). SCE plans to restore nameplate capacity by adjustments to both the guide and nozzle rings at each unit's next refueling outage (September 1989 for Unit 2; March 1990 for Unit 3).

SCE will be issuing a Licensee Event Report on this matter within 30 days.

/s/

Charles M. Trammell, Senior Project Manager
Project Directorate V
Division of Reactors Projects III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Attendance List
- 2. Viewgraphs

cc w/enclosures
See next page

SUMMARY MEETING 5/23-S023
LOG p6 5/25

DISTRIBUTION

Docket File
CTrammell

NRC & Local PDRs
OGC (f/info only)

PD #5 Reading
EJordan

MVirgilio
BGrimes

JLee

PDE/DRSP
CTrammell:rw
5/31/89

[Signature]
D:PDV:DRSP
GKnighton
6/1/89

DFoI
1/1

MEMO 4
[Signature]

8906070264 890601
PDR ADDCK 05000361
PDC



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

June 1, 1989

Docket Nos. 50-361
50-362

FACILITIES: San Onofre Nuclear Generating Station, Unit Nos. 2 and 3

LICENSEE: Southern California Edison Company

SUBJECT: SUMMARY OF MEETING HELD ON MAY 23, 1989 TO DISCUSS
CAPACITY OF STEAM GENERATOR SAFETY VALVES

On May 23, 1989, the NRC staff met with representatives of Southern California Company (SCE) to discuss the relief capacity of the steam generator safety valves at SONGS 2 and 3. Persons attending are identified on Enclosure 1. Viewgraphs presented at the meeting are shown on Enclosure 2. The meeting was held pursuant to notice issued on May 15, 1989. Highlights of the meeting are summarized below.

Following issuance of NRC Information Notice No. 86-05 on January 31, 1986 on main steam safety valves, a Westinghouse Owners Group Subcommittee was formed representing about sixteen licensees of plants fitted with Crosby safety valves to investigate why the Seabrook and Vogtle valves had low capacities. The test program involved four valve types, eleven different springs, five different nozzle and guide ring settings and various set pressures involving some 235 tests. The test report prepared by the owner's group subcommittee will be formally transmitted to NRC in about two weeks. An advance copy was delivered at the meeting. Each licensee will need to evaluate the results for its specific plant, e.g., current ring settings, and evaluate the effect of changing ring settings as required.

As applied to SONGS 2 and 3, the currently installed valves have about 75% of the nameplate rating, whereas only 66% capacity is needed to meet the capacity requirements for the worst overpressure transient (loss of load w/no turbine bypass). SCE plans to restore nameplate capacity by adjustments to both the guide and nozzle rings at each unit's next refueling outage (September 1989 for Unit 2; March 1990 for Unit 3).

SCE will be issuing a Licensee Event Report on this matter within 30 days.

A handwritten signature in cursive script that reads "Charles M. Trammell".

Charles M. Trammell, Senior Project Manager
Project Directorate V
Division of Reactors Projects III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosures:

1. Attendance List
2. Viewgraphs

cc w/enclosures
See next page

Mr. Kenneth P. Baskin
Southern California Edison Company

San Onofre Nuclear Generating
Station, Units 2 and 3

cc:

Charles R. Kocher, Esq.
James A. Beoletto, Esq.
Southern California Edison Company
2244 Walnut Grove Avenue
P. O. Box 800
Rosemead, California 91770

Mr. Mark Medford
Southern California Edison Company
2244 Walnut Grove Avenue
P. O. Box 800
Rosemead, California 91770

Orrick, Herrington & Sutcliffe
ATTN: David R. Pigott, Esq.
600 Montgomery Street
San Francisco, California 94111

Mr. Robert G. Lacy
Manager, Nuclear Department
San Diego Gas & Electric Company
P. O. Box 1831
San Diego, California 92112

Alan R. Watts, Esq.
Rourke & Woodruff
701 S. Parker St. No. 7000
Orange, California 92668-4702

Mr. Paul Szalinski, Chief
Radiological Health Branch
State Department of Health Services
714 P Street, Building #8
Sacramento, California 95814

Mr. Sherwin Harris
Resource Project Manager
Public Utilities Department
City Hall of Riverside
City Hall
3900 Main Street
Riverside, California 92522

Resident Inspector, San Onofre NPS
c/o U.S. Nuclear Regulatory Commission
Post Office Box 4329

Mayor, City of San Clemente
San Clemente, California 92672

Mr. Charles B. Brinkman
Combustion Engineering, Inc.
12300 Twinbrook Parkway, Suite 330
Rockville, Maryland 20852

Regional Administrator, Region V
U.S. Nuclear Regulatory Commission
1450 Maria Lane/Suite 210
Walnut Creek, California 94596

Mr. Dennis F. Kirsh
U.S. Nuclear Regulatory Commission
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

Chairman, Board Supervisors
San Diego County
1600 Pacific Highway, Room 335
San Diego, California 92101

Mr. Don Womeldorf
Chief Environmental Management Branch
California Department of Health
714 P Street, Room 616
Sacramento, California 95814

ENCLOSURE 1

Attendance List

May 23, 1989 Meeting

NRC

G. Knighton
C. Trammell
G. Hammer
P. T. Kuo
K. Desai
J. Bradfute
S. Juergens
F. Cherry

SCE

F. Nandy
M. Kerschthal
A. Sistos
T. McLeod

Other

T. Hicks, Southern Technical Services

Main Steam Safety Valve
San Onofre Nuclear Generating Station
Units 2 and 3
AGENDA

- I. Introduction
- II. Background
- III. Westinghouse Owner's Group Subcommittee on Main Steam Safety Valves
 - A. Objective
 - B. Test Program
 - C. Safety Valve Computer Model
 - D. Extended Blowdown Analysis
- IV. SONGS 2 and 3 Assessment
 - A. Main Steam Safety Valve Configuration and Data
 - B. Design Basis
 - C. SONGS 2 Trip
 - D. Recent Secondary System Pressure Evaluation
- V. Long Term Modifications
- VI. Technical Specification Changes
- VII. Conclusions

BACKGROUND

2 Seabrook MSSVs were high flow tested at Wylie laboratories and found to have low lifts. (Testing was performed in 1984 and 1985)

5 Plant Vogtle MSSVs were high flow tested at Wylie laboratories and found to have low lifts. (Testing was performed in May, 1986)

In both instances, the large positive guide ring settings were changed to a negative setting

Information Notice No. 86-05 was issued January 31, 1986.

Supplement 1 to IEN 86-05 was issued October 16, 1986

On August 12, 1986, SONGS 2 experienced a spurious MSIS challenging the secondary overpressure protection system. All MSSVs actuated. No design parameters were exceeded.

SCE requested Crosby to evaluate the adequacy of the SONGS 2 & 3 MSSVs in November 1986

SCE joined the Westinghouse Owner's Group MSSV Subcommittee in January 1987

WESTINGHOUSE OWNERS GROUP

MSSV SUBCOMMITTEE

- * Subcommittee formed in September 1986 to address the issues raised by Information Notice 86-05
- * Subcommittee Members:
 - * Several Licensees
 - * Crosby Valve & Gage Company
 - * EPRI
 - * Continuum Dynamics

SUBCOMMITTEE OBJECTIVES

* Formed to determine the root cause for the inadequate capacities of the Seabrook and Vogtle MSSVs

* Establish "generic" ring settings to provide rated capacity at 3% accumulation and a maximum 10% blowdown

* Determine the effects of spring rate and ring settings on blowdown and accumulation


* Develop an analytical model which can predict valve performance:

- * Blowdown
- * Lift

Given:

- * Ring Settings
- * Geometry
- * Spring rate
- * Accumulation


MSSV INTERNALS



TEST PROGRAM

- * A matrix of high flow tests were performed at Crosby Valve Gage Company
- * Test procedure was written by Crosby and approved by the Subcommittee
- * The following MSSV transient data was recorded for each test:
 - * Inlet pressure
 - * Outlet pressure
 - * Valve lift
- * Test data was copied to a computer
- * Test data was sent to Continuum Dynamics for development and verification of the COUPLE Code
- * Analysis of test data performed by Crosby and Continuum Dynamics

FIGURE 2



TEST PROGRAM

* All of the Crosby MSSVs were tested:

- * 6R10
- * 6Q8
- * 6Q8x8

* Eleven springs with spring rates bounding design limits were tested

* Five different ring settings were tested:

<u>Nozzle Ring</u>	<u>Guide Ring</u>
-75	-100
-100	-75
-100	-50
-50	-75
-75	-75

* Large number of set pressures were tested

FIGURE 1

	<u>Test Number</u>	<u>Valve</u>	<u>Spring</u>	<u>Set Pressure (psig)</u>	<u>Ring* Setting</u>	<u>Number Cycles</u>
Phase I	1	1 (6R10 #1)	DK	1064	1	3
	2	1 (6R10 #1)	DK	1064	2	3
	3	1 (6R10 #1)	DK	1064	3	3
	4	1 (6R10 #1)	DK	1090	3	3
	5	1 (6R10 #1)	DK	1090	2	3
	6	1 (6R10 #1)	DK	1090	1	3
	7	1 (6R10 #1)	DK	1115	1	3
	8	1 (6R10 #1)	DK	1115	2	3
	9	1 (6R10 #1)	DK	1115	3	3
	10	1 (6R10 #1)	DK	1140	3	3
	11	1 (6R10 #1)	DK	1140	2	3
	12	1 (6R10 #1)	DK	1140	1	3
	13	1 (6R10 #1)	DK + 10%	1140	1	3
	14	1 (6R10 #1)	DK + 10%	1140	2	3
	15	1 (6R10 #1)	DK + 10%	1140	3	3
	16	1 (6R10 #1)	DK + 10%	1115	3	3
	17	1 (6R10 #1)	DK + 10%	1115	2	3
	18	1 (6R10 #1)	DK + 10%	1115	1	3
	19	1 (6R10 #1)	DK + 10%	1090	1	3
	20	1 (6R10 #1)	DK + 10%	1090	2	3
	21	1 (6R10 #1)	DK + 10%	1090	3	3
	22	1 (6R10 #1)	DK + 10%	1064	3	3
	23	1 (6R10 #1)	DK + 10%	1064	2	3
	24	1 (6R10 #1)	DK + 10%	1064	1	3
	25	2 (6R10 #2)	DK	1140	3	3
	26	3 (6R10 #3)	DK + 10%	1064	3	3
	27	4 (6R10 #4)	DK	1140	3	3
	28	2 (6R10 #2)	DK + 10%	1064	3	3
	29	3 (6R10 #3)	DK	1140	3	3
	30	4 (6R10 #4)	DK + 10%	1064	3	3
Phase II	31	1 (6R10 #1)	EK	1170	3	3
	32	1 (6R10 #1)	EK	1260	3	3
	33	1 (6R10 #1)	EK + 10%	1260	3	3
	34	1 (6R10 #1)	EK + 10%	1170	3	3
	35	2 (6R10 #2)	EK(-0%,+10%)	1170	3	3
	36	2 (6R10 #2)	EK(-0%,+10%)	1260	3	3

FIGURE 1


	<u>Test Number</u>	<u>Valve</u>	<u>Spring</u>	<u>Set Pressure (psig)</u>	<u>Ring* Setting</u>	<u>Number Cycles</u>
Phase II (cont)						
	37	3 (6R10 #3)	EK(-0%,+10%)	1260	3	3
	38	3 (6R10 #3)	EK(-0%,+10%)	1170	3	3
Phase III	39	5 (6Q8 #1)	BK	1050	4	3
	40	5 (6Q8 #1)	BK	1050	5	3
	41	5 (6Q8 #1)	BK	1105	5	3
	42	5 (6Q8 #1)	BK	1105	4	3
	43	5 (6Q8 #1)	BK + 10%	1105	4	3
	44	5 (6Q8 #1)	BK + 10%	1105	5	3
	45	5 (6Q8 #1)	BK + 10%	1050	5	3
	46	6 (6Q8 #1)	BK + 10%	1050	4	3
	47	6 (6Q8 #2)	BK(-0%,+10%)	1050	4	3
	48	6 (6Q8 #2)	BK(-0%,+10%)	1105	4	3
Phase IV	49	6 (6Q8 #2)	AK	1035	4	3
	50	6 (6Q8 #2)	AK	985	4	3
	51	6 (6Q8 #2)	AK + 10%	985	4	3
	52	6 (6Q8 #2)	AK + 10%	1035	4	3
	53	5 (6Q8 #1)	AK(-0%,+10%)	1035	4	3
	54	5 (6Q8 #1)	AK(-0%,+10%)	985	4	3
Phase V	55	5 (6Q8 #1)	CK	1175	4	3
	56	5 (6Q8 #1)	CK	1190	4	3
	57	5 (6Q8 #1)	CK + 10%	1190	4	3
	58	5 (6Q8 #1)	CK + 10%	1175	4	3
	59	6 (6Q8 #2)	CK(-0%,+10%)	1175	4	3
	60	6 (6Q8 #2)	CK(-0%,+10%)	1190	4	3
Phase VI	61	7 (6R8x8 #1)	EK	1235	3	3
	62	7 (6R8x8 #1)	EK	1185	3	3
	63	8 (6R8x8 #2)	EK + 10%	1185	3	3
	64	8 (6R8x8 #2)	EK + 10%	1235	3	3
Phase VII	65	9 (6Q8x8 #1)	CK	1200	4	3
	66	9 (6Q8x8 #1)	CK	1130	4	3
	67	10 (6Q8x8 #2)	CK + 10%	1130	4	3
	68	10 (6Q8x8 #2)	CK + 10%	1200	4	3
Phase VIII	69	2 (6R10 #2)	FK(-0%,+10%)	985	3	3
	70	2 (6R10 #2)	FK(-0%,+10%)	1025	3	3
	71	1 (6R10 #1)	FK(-0%,+10%)	1025	3	3
	72	1 (6R10 #1)	FK	985	3	3

TEST PROGRAM

- * **Test results plotted lift and blowdown:**
 - * Nondimensional lift (lift/bore, L/D) plotted vs. nondimensional pressure (opening pressure*bore/spring rate, $D^*P_{op}/K\text{-rate}$)
 - * Blowdown plotted vs. nondimensional pressure


WOG Test Results

Phase I, II, VI & VIII, -100/-50



WOG Test Results

Phase I, II, VI & VIII, -100/-50



TEST PROGRAM

- * Additional testing performed in late 1988 to determine the cause of low lift/high blowdown test results
- * Valve springs were also tested by Continuum Dynamics at Princeton University to determine if large eccentricities caused anomalous test results
 - * Large eccentricities can result in excessive stem to bearing friction affecting valve performance
- * Additional testing resulted in expected MSSV lift and blowdowns
- * One spring was found to have an exceptionally large eccentricity



Test Report Number 4388
Supplement 1, Revision 1

FIGURE 1

	<u>Test Number</u>	<u>Valve</u>	<u>Spring</u>	<u>Set Pressure (psig)</u>	<u>Ring* Setting</u>	<u>Number Cycles</u>	
Additional	73	7 (6R8x8 #1)	EK + 10%	1185	3	3	-1
Tests	74	7 (6R8x8 #1)	EK + 10%	1235	3	3	-1
	75	8 (6R8x8 #2)	EK	1185	3	3	-1
	76	8 (6R8x8 #2)	EK	1235	3	3	-1
	77	7 (6R8x8 #1)	EK(-0%,+10%)	1170	3	3	-1
	78	8 (6R8x8 #2)	EK(-0%,+10%)	1170	3	3	-1

TEST PROGRAM

- * Meeting conducted with the NRC on March 8, 1988 to discuss the program
- * Crosby Test Report 4388, rev. 1 was issued Nov. 30, 1988
- * Crosby Test Report 4388, Supplement 1, was issued Feb. 2, 1989
 - * Supplement report includes test runs 73 through 78
- * Continuum Dynamics Test Report and Model Report will be issued in June, 1989

TEST PROGRAM

- * Each licensee is to utilize the results of the Owner's Group:
 - * Evaluate the effect of the current MSSV ring settings on continued plant operation
 - * Evaluate the effect of changing ring settings (if required)


MSSV Computer Model

- * COUPLE code developed by Continuum Dynamics and EPRI as part of the primary Safety Valve test program in early 1980's
- * Predicts safety valve lift and blowdown given:
 - * Ring setting
 - * Inlet pressure
 - * Spring rate
 - * Valve geometry
- * COUPLE has been refined and verified using high flow MSSV tests performed at Crosby and 1986 Seabrook MSSV test results
- * Code showed that even though rated capacity was not achieved at 3% accumulation, rated capacity would be achieved at a higher accumulation

SEABROOK U-25 TABLE 1 RUN 1 EK+10


$\eta_n = -25$
 $\eta_g = +150$

VALUE STEM POSITION (IN)



197302


SEABROOK U-25 TABLE 1 RUN 2 EK+10



CUSL8131

MODIFICATIONS REQUIRED TO PREDICT LIMITED LIFT SEABROOK DATA

When disk is below guide ring
guide ring doesn't control deflection
of exiting jet



EXTENDED BLOWDOWN ANALYSIS


Westinghouse prepared and issued "Analytical Report For The Effect Of Increased MSSV Blowdown" in Nov., 1988

- Larger blowdowns than those used in Safety Analyses may occur as a result of implementing ring setting changes to provide stronger lifts
- Conservative analysis of the effects of larger blowdowns on the Loss of Load and Steam Generator Tube Rupture Events was performed
- Analysis shows that increasing the blowdown to 15% and 20% does not result in exceeding any plant safety limit or 10CFR100 off site dose limits

IV. SONGS 2 & 3 Assessment

- Plant Configuration & Main Steam Safety Valve Data
 - 18 valves total, 9 per steam generator
 - Valves are Crosby, Spring loaded, enclosed bonnet, safety valves with an "R" orifice (16 in² orifice area)
 - The valves were designed, manufactured and certified in accordance with Section III of the ASME Boiler & Pressure Vessel Code, 1974 Edition.
 - The valves lift sequentially in pairs, the first two valves lift at 1100 psia (Main Steam Design Pressure) and the last two at 1155 psia (105% design pressure)
 - Figure 1 illustrates the main steam pressure relief schematic

SECONDARY SIDE PRESSURE RELIEF SCHEMATIC



STEAM LINE SAFETY VALVES PER LOOP

VALVE NUMBER		LIFT SETTING ($\pm 1\%$) ^a	ORIFICE SIZE
Line No. 1	Line No. 2		
a. 2PSV-8401	2PSV-8410	1100 psia	16 in ²
b. 2PSV-8402	2PSV-8411	1107 psia	16 in ²
c. 2PSV-8403	2PSV-8412	1114 psia	16 in ²
d. 2PSV-8404	2PSV-8413	1121 psia	16 in ²
e. 2PSV-8405	2PSV-8414	1128 psia	16 in ²
f. 2PSV-8406	2PSV-8415	1135 psia	16 in ²
g. 2PSV-8407	2PSV-8416	1142 psia	16 in ²
h. 2PSV-8408	2PSV-8417	1149 psia	16 in ²
i. 2PSV-8409	2PSV-8418	1155 psia	16 in ²

FIG. 1

• DESIGN BASIS

- The sizing calculation for the Main Steam Safety Valves was issued by Bechtel on 11/17/75.
- The design basis for sizing the Safety Valves is as follows:

In accordance with subarticle NC-7300 of Section III of the ASME Code, the total rated relieving capacity of the Safety Valves shall be sufficient to prevent a rise in pressure of more than 10% above the design pressure under the most severe anticipated operational transient. The design pressure of the Main Steam Safety Valve is 1100 psia.

- In the absence of specific FSAR transient analysis, the Safety Valves were conservatively design to handle the "valves wide open" steam flow rate of 15.1×10^6 lb/hr (100% of rated reactor power, 3410 MWt)
- The valves rated capacity at their lift settings range from 818,685 to 859,646 lb/hr at 3% overpressure.

- On 7/82, Combustion Engineering issued Rev. 2 of the overpressure protection report for the Nuclear Steam Supply Systems.
- The Following assumptions were used:
 - Reactor power at 3480 (rated power plus 2% uncertainty)
 - Reactor does not trip on loss-of-load but will trip on high pressurizer pressure
 - No credit for letdown, charging, pressurizer spray, secondary bypass, nor feedwater flow
 - Safety valves lift at their maximum popping pressure
- The most severe anticipated transient was concluded to be a loss of turbine generator load with a delayed reactor trip.
- Under this transient, the maximum steam generator pressure achieved was 1150 psia with only 16 valves lifting
- The results of this analysis are summarized in appendix 5.2A of the FSAR.
- For more detailed evaluation of the loss-of-load transients, Appendix 5.2A refers to Section 15.2 of the FSAR.


FSAR ACCIDENT ANALYSIS

- Section 15.2 of the FSAR addresses loss of external load incidents. The most severe of this incidents was determined to be a loss of condenser vacuum with a concurrent single failure
- The postulated failure of a pressurizer level measurement channel is considered to produce the most adverse effects following a loss of condenser vacuum
- FSAR Table 15.2-2 lists the assumptions used for the loss of condenser vacuum
- FSAR Table 15.2-5 summarizes the sequence of events and results obtained in this analysis
- The analysis concludes that for the most severe operational transient, the main steam peak pressure remains below 110% of design pressure

SONGS 2 TRIP

- * On Aug. 12, 1986, a spurious Main Steam Isolation Signal (MSIS) resulted in the closure of both Main Steam Isolation Valves (MSIVs) and a Loss of Load transient
- * Event parallels Loss of Condenser Vacuum (LOCV) event described in FSAR section 15.2
- * Plant response from this transient was reviewed and no design parameters were exceeded
- * Transient was modelled using RETRAN in an effort to determine installed MSSV characteristic (i.e., flow vs. accumulation)

Fig. 2 RETRAN Model of Main Steam Safety Valve Lifting Characteristics (MSSV Model B).




Pn = nominal safety valve setpoint pressure, see Table 3.

Pt = safety valve lifting pressure with positive tolerance, see Table 3.


Pa = accumulation pressure
= 105% of Pt

Fig. 8 Steam Generator Pressure Response to the SONGS 2
8/12/1986 MSIV Closure Event



SAN ONOFRE NUCLEAR GENERATING STATION

MAIN STEAM SAFETY VALVE LIFT



SAFETY ANALYSIS EVALUATION

- * Combustion Engineering (CE) has modelled the LOCV event using CESEC code
- * Initial conditions have been modified to maximise peak secondary pressure
- * Two MSSV models were used:
 - * Linear flowrate vs. accumulation (0 % flow capacity at 0% accumulation and 75% flow capacity, max., at 3% accumulation)
 - * "Best estimate" model using COUPLE code and RETRAN analysis of SONGS 2 trip
 - * Additional analysis will be performed and the MSSV models will be refined

SOUTHERN CALIFORNIA EDISON COMPANY
San Onofre Nuclear Generating Station

Initial Conditions For The Loss Of Condenser Vacuum Analysis

<u>PARAMETER</u>	<u>FSAR ASSUMPTIONS</u>	<u>SONGS UNIT 2 TRIP</u>	<u>CE ANALYSIS</u>
Initial core power level, Mwt.	3,478	3,410	3,478/3,478
Core inlet coolant temperature, degrees F.	542	553	560/560
Core mass flowrate, 10^6 lb _m /hr.	164.9	---	----
Reactor coolant system pressure, lb/in. ² a.	2,050	2,250	2,050/2,050
Steam generator pressure, lb/in. ² a.	810	930	954.5/954.5
Moderator temperature coefficient, 10^{-4} % / F	+0.13	-2.09	-0.7/0.0
Steam Bypass control system	Inoperative	Not available	Inop/Inop
Reactor trip on turbine trip	Inoperative	Ocurred after High Pzr Trip	Inop/Inop
Pressurizer level control system	Inoperative	Operable	Inop/Inop
Pressurizer pressure control system	Inoperative	Operable	Inop/Inop

SOUTHERN CALIFORNIA EDISON COMPANY
San Onofre Nuclear Generating Station

Sequence Of Events For The Loss Of Condenser Vacuum

EVENT	FSAR		SONGS Unit 2 Trip		CE Analysis	
	TIME SECONDS	VALUES	TIME SECONDS	VALUES	TIME SECONDS	VALUES
Closure of turbine stop valves on turbine trip due to loss of condenser vacuum. (Unit 2 event was a spurious trip of the MSIVs)	0.0	-----	0.0	-----	0.0/0.0	-----
High-pressurizer trip signal condition, 1b/in. ² a.	8.4	2,422	3.5	2,378	5.9/5.9	2,422/2,422
High-pressurizer trip signal condition generated.	9.5	-----	3.7	-----	7.0/7.0	-----
Pressurizer safety valves begin to open, 1b/in. ² a.	10.0	2,525	DID NOT REACH PRESSURE TO LIFT		8.1/8.1	2,525/2,525
Steam generator safety valves begin opening, 1b/in. ² a.	10.1	1,100	4.5	1,100	3.95/3.95	1,111/1,111
CEAs begin to drop into core.	10.3	-----	6.0	-----	8.91/8.91	-----
Maximum core power.	10.3	103.2% OF FULL POWER	0.0	100%	----	-----
Maximum RCS pressure, 1b/in. ² a.	12.4	2,746	7.0	2,480	8.65/8.65	2,631/2,636
Maximum pressurizer liquid volume, ft. ³ .	15.0	935	12.0	65% LEVEL	----	-----
Pressurizer safety valves closed, 1b/in. ² a.	15.5	2,463	NEVER OPENED		11.20/12.55	2,400/2,400
Maximum steam generator pressure, 1b/in. ² a.	16.9	1,154	10.0	1,175	14.8/14.2	1208.5/1199.5
Steam generator safety valves close, 1b/in. ² a.	650.0	1,056	----	----	----	-----
Operator opens atmospheric steam dump valves to begin plant cooldown to shutdown cooling.	1,800.0	-----	27.0	----	----	-----
Shutdown cooling initiated.	11,600.0	-----				

SAFETY ANALYSIS RESULTS

* Using linear MSSV model:

- * Using $MTC = -0.7 \times 10^{-4} \% \Delta \rho / ^\circ F$ (corresponds to current SONGS 3 MTC at 250 EFPD, SONGS 2 MTC is more negative), peak secondary pressure is 1208.5 psia
- * Using $MTC = 0.0 \times 10^{-4} \% \Delta \rho / ^\circ F$ (Technical Specification maximum), peak secondary pressure is 1214 psia

* Using best estimate MSSV model:

- * Peak secondary pressure is 1199.5 psia

LONG TERM MODIFICATIONS

- * Change ring settings:
 - * Nozzle ring to -100 notches
 - * Guide ring to -50 notches
- * Measure spring rates of all MSSVs
- * Modifications to be performed at cycle 5 refueling outages on Units 2 & 3 concurrent with valve overhauls

3/4.7 PLANT SYSTEMS

BASES

3/4.7.1 TURBINE CYCLE

3/4.7.1.1 SAFETY VALVES

The OPERABILITY of the main steam line code safety valves ensures that the secondary system pressure will be limited to within 110% (1210 psig) of its design pressure of 1100 psig during the most severe anticipated system operational transient. The maximum relieving capacity is associated with a turbine trip from 100% RATED THERMAL POWER coincident with an assumed loss of condenser heat sink (i.e., no steam bypass to the condenser).

The specified valve lift settings and relieving capacities are in accordance with the requirements of Section III of the ASME Boiler and Pressure Vessel Code, 1974 Edition. The total relieving capacity for all valves on all of the steam lines is 15,473,628 lbs/hr which is 102.3 percent of the total secondary steam flow of 15,130,000 lbs/hr at 100% RATED THERMAL POWER. A minimum of 1 OPERABLE safety valves per steam generator ensures that sufficient relieving capacity is available for removing decay heat.

STARTUP and/or POWER OPERATION is allowable with safety valves inoperable within the limitations of the ACTION requirements on the basis of the reduction in secondary system steam flow and THERMAL POWER required by the reduced reactor trip settings of the Power Level-High channels. The reactor trip setpoint reductions are derived on the following bases:

For two loop, four pump operation

$$SP = \frac{(X) - (Y)(V)}{X} \times 111.3$$

where:

SP = reduced reactor trip setpoint in percent of RATED THERMAL POWER.

V = maximum number of inoperable safety valves per steam line.

111.3 = Power Level-High Trip Setpoint for two-loop operation.

X = Total relieving capacity of all safety valves per steam line in lbs/hour (15,473,628 lbs/hr at 1190 psia).

Y = Maximum relieving capacity of any one safety valve in lbs/hour (859,646 lbs/hr at 1190 psia).