

REGULATORY DOCKET FILE COPY

DISTRIBUTION:

Docket 50-206

WRussell
RSilver
Attorney, OELD
OI&E(3)
JRBuchanan
TERA
ACRS(16)
DDavis

Flashe
McDonald
Evallner
BGump
JUN 18 1979
Desinhet

Docket No. 50-206

Mr. James H. Drake
Vice President
Southern California Edison Company
2244 Walnut Grove Avenue
Post Office Box 800
Rosemead, California 91770

Dear Mr. Drake:

RE: TOPIC VIII-3.B Request for Additional Information

To complete the evaluation of Topic VIII-3.B, a list of all alarms and voltage monitoring devices available to provide operability status indication to the operator for the Class IE batteries, associated chargers and direct current buses is required.

We have completed our search of the SEP Plant dockets for information relative to Topic VIII-3.B, "D. C. Power System Bus Voltage Monitoring and Annunciation". This effort indicates that some of this information is available. However, our experience has shown that only a portion of the alarms and monitoring devices would be shown on the available drawings. Thus, we expect that any list we might compile would be incomplete and would be sent to you for completion.

Therefore, rather than going through the intermediate steps, you are requested to provide the listing described above within thirty days of receipt of this letter.

Sincerely,

Original signed by
Dennis L. Ziemann

*See letter to Commonwealth Edison Company
50-10/237 for concurrences.

Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Operating Reactors

cc: See next page

APP3
CCP

7907250187

OFFICE➤	DOR:ORB#2	DOR:ORB#2	DOR:ORB#2	DOR:ORB#2		
SURNAME➤	*RSilver:sah	*HSmith	ABurger	DLZiemann		
DATE➤	6/ /79	6/ /79	6/18/79	6/18/79		

Mr. James H. Drake

- 2 -

June 18, 1979

CC

Charles R. Kocher, Assistant
General Counsel
Southern California Edison Company
Post Office Box 800
Rosemead, California 91770

David R. Pigott
Samuel B. Casey
Chickering & Gregory
Three Embarcadero Center
Twenty-Third Floor
San Francisco, California 94111

Jack E. Thomas
Harry B. Stoehr
San Diego Gas & Electric Company
P. O. Box 1831
San Diego, California 92112

U. S. Nuclear Regulatory Commission
ATTN: Robert J. Pate
P. O. Box 4167
San Clemente, California 92672

Mission Viejo Branch Library
24851 Chrisanta Drive
Mission Viejo, California 92676

K M C Inc.
ATTN: Mr. Richard E. Schaffstall
1747 Pennsylvania Avenue, N. W.
Suite 1050
Washington, D. C. 20006