

Southern California Edison Company



P. O. BOX 800

2244 WALNUT GROVE AVENUE

ROSEMEAD, CALIFORNIA 91770

J. H. DRAKE
VICE PRESIDENT

TELEPHONE
213-572-2258

September 18, 1979

Mr. H. R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Gentlemen:

Subject: Docket No. 50-206, Provisional
Operating License No. DPR-13
Amendment No. 83
San Onofre Nuclear Generating Station, Unit 1

Enclosed are three executed and thirty-seven conformed copies of Amendment No. 83 in Docket No. 50-206. Amendment No. 83 adds license conditions, to the above-numbered license, relating to the implementation of a secondary water chemistry monitoring and control program.

The proposed license condition is provided in response to your letter dated July 23, 1979, requesting that this proposed amendment be developed to replace the previously submitted Amendment No. 59 which was transmitted by letter dated December 28, 1976.

The secondary water chemistry monitoring program which is required by the proposed license condition is provided to inhibit steam generator tube degradation. Accordingly, the program would define sampling and monitoring requirements, data recording and maintenance procedures, a procedure for review of the chemistry data by qualified station personnel and procedures specifying corrective actions for conditions which may be outside of the operations guidelines. This program is in agreement with the Model License Condition which was provided as the enclosure to your letter dated July 23, 1979.

Since our previous application for a license amendment concerning steam generator monitoring requirements was submitted prior to March 22, 1978, no fee is being remitted with this license amendment.

Very truly yours,

App'd
1/3

Enclosure

7909210358