

ORIGINAL SOURCE FILE COPY

DISTRIBUTION

- NRC PDR
- Local PDR
- Docket
- ORB #2 Reading
- NRR Reading
- DLZiemann
- HSmith
- ABurger
- TJCarter
- WGAmill
- SMacKay
- GLainas
- OELD
- OI&E (3)
- JRBuchanan
- TERA
- ACRS (16)
- DCrutchfield

Docket No. 50-206

SEP 12 1979

Mr. James H. Drake  
 Vice President  
 Southern California Edison Company  
 2244 Walnut Grove Avenue  
 Post Office Box 800  
 Rosemead, California 91770

Dear Mr. Drake:

RE: STEAM GENERATOR WATER HAMMER - SAN ONOFRE, UNIT 1

In response to our letter of September 2, 1977, regarding steam generator water hammer at San Onofre, Unit 1, you indicated that, based on your operating experience, modifications were not necessary to further reduce the probability or consequences of steam generator water hammer at your facility. Although your operating history does not show that such water hammer has occurred in your present piping arrangement, we require further assurance that steam generator water hammer will not occur in the future and that surveillance procedures would be adequate to detect water hammer or damage from water hammer if it were to occur.

Your response to the enclosed request for additional information, together with previously supplied information, will provide a bases for a determination regarding the need for modifications to your feedwater system to prevent steam generator water hammer. Your response is needed within 60 days so that we may maintain our schedule for evaluating the potential for water hammer at your facility.

Sincerely,

Original signed by  
 Dennis L. Ziemann

Dennis L. Ziemann, Chief  
 Operating Reactors Branch #2  
 Division of Operating Reactors

7910040 413

Appls  
KB

Enclosure:  
 Request for Additional  
 Information

DBZ

OFFICE →		DOR:ORB #2	DOR:ORB #2		
cc	cc w/enclosure:	ABurger:ah	DLZiemann		
SURNAME →	See next page	9/12/79	9/12/79		
DATE →					

Mr. James H. Drake

- 2 -

September 12, 1979

cc w/enclosure:

Charles R. Kocher, Assistant  
General Counsel  
Southern California Edison Company  
Post Office Box 800  
Rosemead, California 91770

David R. Pigott  
Samuel B. Casey  
Chickering & Gregory  
Three Embarcadero Center  
Twenty-Third Floor  
San Francisco, California 94111

Jack E. Thomas  
Harry B. Stoehr  
San Diego Gas & Electric Company  
P. O. Box 1831  
San Diego, California 92112

U. S. Nuclear Regulatory Commission  
ATTN: Robert J. Pate  
P. O. Box 4167  
San Clemente, California 92672

Mission Viejo Branch Library  
24851 Chrisanta Drive  
Mission Viejo, California 92676

REQUEST FOR ADDITIONAL INFORMATION  
ON STEAM GENERATOR WATER HAMMER  
SAN ONOFRE, UNIT 1  
DOCKET NO. 50-206

---

1. Provide information that demonstrates that the feedwater system and steam generator water level at your facility have been subjected to those transient conditions that are conducive to water hammer, i.e., the addition of cold feedwater or auxiliary feedwater to steam-filled feedwater piping and feeding. See NUREG 0291 Page 4 that was forwarded to you on September 2, 1977. Include the following:
  - 1.1 Describe the expected behavior of steam generator water level as a result of reactor trip from power levels greater than 30% of full power. Include actual plant measurements of steam generator level and other available related data such as feedwater flow and auxiliary feedwater flow.
  - 1.2 Provide the number and causes of loss of feedwater events during the operational history of the plant. You may refer to material submitted previously.
  - 1.3 Provide the number and causes of loss of off-site power events during the operational history of the plant.
2. If administrative controls have been adopted to limit the flow of auxiliary feedwater for the purpose of reducing the probability of water hammer, show when they were adopted and give the answers to items 1.1, 1.2 and 1.3 for before and after such controls were established.
3. If administrative controls have been adopted to limit the flow of auxiliary feedwater for the purpose of reducing the probability of water hammer, show that an adequate water inventory and flow will be maintained to accommodate all postulated transient and accident conditions.
4. If auxiliary feedwater flow in your facility is not at present initiated automatically for normal and accident events, present your evaluation of whether automating the actuation of auxiliary feedwater might increase the probability of inducing steam generator water hammer. One of the signals that would automatically initiate the flow of auxiliary feedwater would be the steam generator low water level. This set point should be above the top of the main feedwater sparger to reduce the probability of steam generator water hammer.
5. Describe the means that will be used to monitor for the occurrence of steam generator water hammer and possible damage from such an event. Include all instrumentation that will be employed. Describe the inspections that will be performed and give the frequency of such inspections.
6. Describe the reporting procedures that will be used to document and report water hammer and damage to piping and piping support systems. Such reports were requested in our letter to you dated September 2, 1977.