

SEP 25 1979

Docket No. 50-206

Mr. James H. Drake
Vice President
Southern California Edison Company
2244 Walnut Grove Avenue
Post Office Box 800
Rosemead, California 91770

REGULATORY DOCKET FILE COPY

Dear Mr. Drake:

RE: CHARGING PUMP VIBRATIONS - SAN ONOFRE, UNIT NO. 1

We have completed our review of the performance of the positive displacement charging pump in the Chemical Volume and Control System at San Onofre, Unit 1. We have concluded that fatigue failures due to operation of this pump are not anticipated in either the discharge side or the suction side piping system. Our Safety Evaluation on this matter is enclosed.

Sincerely,

"Original Signed by
Thomas V. Wambach"

Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Operating Reactors

Enclosure:
Safety Evaluation

cc w/enclosure:
See next page

DISTRIBUTION:

Docket 50-206

- NRC PDR
- Local PDR
- ORB#2 RDG
- NRR RDG
- DEisenhut
- RVollmer
- BGrimes
- WGammill
- JMiller
- LShao
- TCarter

- OELD
- OI&E(3)
- DLZiemann
- ABurger
- HSmith
- ACRS(16)

Wambach

CF
Apples

7910090

623

OFFICE	DOR:ORB#2	DOR:ORB#2	DOR:ORB#2		
SURNAME	ABurger:sah	HSmith	DLZiemann		
DATE	9/25/79	9/25/79	9/25/79		

Mr. James H. Drake

- 2 -

SEP 25 1979

cc

Charles R. Kocher, Assistant
General Counsel
Southern California Edison Company
Post Office Box 800
Rosemead, California 91770

David R. Pigott
Samuel B. Casey
Chickering & Gregory
Three Embarcadero Center
Twenty-Third Floor
San Francisco, California 94111

Jack E. Thomas
Harry B. Stoehr
San Diego Gas & Electric Company
P. O. Box 1831
San Diego, California 92112

U. S. Nuclear Regulatory Commission
ATTN: Robert J. Pate
P. O. Box 4167
San Clemente, California 92672

Mission Viejo Branch Library
24851 Chrisanta Drive
Mission Viejo, California 92676