

Southern California Edison Company



P. O. BOX 800

2244 WALNUT GROVE AVENUE

ROSEMEAD, CALIFORNIA 91770

ROBERT DIETCH
VICE PRESIDENT

TELEPHONE
213-572-4144

April 4, 1980

Mr. H. R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Gentlemen:

Subject: Docket No. 50-206
Amendment No. 90
San Onofre Nuclear Generating Station
Unit 1

Enclosed are three executed and thirty-seven conformed copies of Amendment No. 90 in Docket No. 50-206. Amendment No. 90 consists of Proposed Change Nos. 91 and 92 to the Technical Specifications incorporated into Provisional Operating License No. DPR-13 as Appendices A and B.

Proposed Change No. 91 is a request to modify the Basis of the existing Technical Specifications to describe the offsite power sources to the station which will be operational at the completion of the cutover to the new switchyard which is under construction in conjunction with San Onofre Units 2 and 3. It is possible that the cutover will not be completed prior to the startup of San Onofre Unit 1 scheduled to commence June 1, 1980, following the refueling outage, so that the minimum number of incoming lines described in the Basis will not be in place. Under these circumstances, the limiting condition for operation as required by the Technical Specifications will still be met since a minimum of two offsite lines will be available prior to startup.

Proposed Change No. 92 is a request to modify the existing Technical Specifications to incorporate the changes required due to the implementation of the Fire Protection modifications which will be completed during the refueling outage for Cycle 8 operation.

A001
S
1/1
w/check:
\$8000.00

8004080491

SEE


Mr. H. R. Denton

-2-

It is respectfully requested that Proposed Change Nos. 91 and 92 be reviewed promptly. It is our desire that such a review be completed and appropriate action taken prior to June 1, 1980 when it is expected that Cycle 8 operation will begin.

Also enclosed is Southern California Edison Company's Check No. T 016498 dated April 3, 1980, in the amount of \$8,000.00 as required by 10CFR170.22.

Very truly yours,



Robert Dietch
Vice President

Enclosures