

Central

Docket No. 50-206

Mr. R. Dietch Vice President Nuclear Engineering and Operations Southern California Edison Company 2244 Walnut Grove Avenue Post Office Box 800 Rosemead, California 91770

SUBJECT: SEP TOPIC VI-4, Containment Isolation System

We are continuing our review of SEP Topic VI-4 and have found that additional information related to the containment purge and venting system for San Onofre Unit 1 described in the enclosure to this letter is needed.

We request your response within 30 days of your receipt of this letter.

Sincerely,

Original signed by:

Dennis Milcutchfield, Chiefector Opérating Reactors: Bnahch #5 Division of Licensing

Enclosure: Request for Additional Information

cc w/enclosure: See next page

ORB#5(:DL

DISTRIBUTION: Docket NRC PDR Local PDR ORB #5 Reading NRR Reading DEisenhut Attorney, OELD OI&E(3)DCrutchfield GLainas TWambach HSmith JRBuchanan, NSIC TERA ACRS (16) E. Adensam

AD

DCnutchfield GLannas.....

SA:DL

...6/.\1//.80......

800,6300 230

OBB#5.:DL

TWambach

6/6/80

SURNAME HSmith:dk.

OFFICE

TO US GOMERNATENT PRINTING OFFICE: 1979-289-369

MP.

ORB

6/11/30



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

JUN 1 2 1980

Docket No. 50-206

Mr. R. Dietch Vice President Nuclear Engineering and Operations Southern California Edison Company 2244 Walnut Grove Avenue Post Office Box 800 Rosemead, California 91770

SUBJECT: SEP TOPIC VI-4, Containment Isolation System

We are continuing our review of SEP Topic VI-4 and have found that additional information related to the containment purge and venting system for San Onofre Unit 1 described in the enclosure to this letter is needed.

We request your response within 30 days of your receipt of this letter.

Sincerely,

Dennis M. Crutchfield, Chief Operating Reactors Branch #5 Division of Licensing

Enclosure: Request for Additional Information

cc w/enclosure: See next page cc Charles R. Kocher, Assistant General Counsel Southern California Edison Company Post Office Box 800 Rosemead, California 91770

David R. Pigott SSamuel B. Casey Chickering & Gregory Three Embarcadero Center Twenty-Third Floor San Francisco, California 94111

Jack E. Thomas Harry B. Stoehr San Diego Gas & Electric Company P. O. Box 1831 San Diego, California 92112

Resident Inspector c/o U. S. NRC P. O. Box AA Oceanside, California 92054

Mission Viejo Branch Library 24851 Chrisanta Drive Mission Viejo, California 92676

Mayor City of San Clemente San Clemente, California 92672

Chairman Board of Supervisors County of San Diego San Diego, California 92101

California Department of Health ATTN: Chief, Environmental Radiation Control Unit Radiological Health Section 714 P Street, Room 498 Sacramento, California 95814 Director, Technical Assessment Division Office of Radiation Programs (AW-459) U. S. Environmental Protection Agency Crystal Mall #2 Arlington, Virginia 20460 U. S. Environmental Protection Agency Region IX Office ATTN: EIS COORDINATOR 215 Freemont Street

San Francisco, California 94111

San Onofre Unit 1

ENCLOSURE .

The docketed information as to the design of the containment purge and venting system includes SCEC letters dated 1/9/79, 12/14/79 and 1/15/80 and does not adequately address the concerns of the NRC generic letter on "Containment Purging during normal plant operation" dated 11/28/78. The following additional information is necessary in order to complete our evaluation of the electrical override/bypass aspects of the containment purge matter:

- 1. Provide the process and instrumentation diagram (P&ID) and schematic diagrams for the purge and vent system.
- 2. SCEC 1/9/79 letter indicates that when a manual override of the safety injection actuation signal is affected, this also overrides the containment spray actuation signal and the containment purge isolation valves. The NRC guidelines require that, for any override, an annuciator be provided for each system impacted when the override is active. Describe how the San Onofre 1 design meets this guideline.
- 3. SCEC 1/9/79 letter describes that manual override of the safety injection actuation signal is accomplished by use of a manual "double-action block switch." The NRC guideline requires that override controls have sufficient physical features (i.e., keylock switches or covered switches) to facilitate adequate administrative control. Describe how the "double-action block switch" satisfies the NRC guideline.
- 4. The NRC guideline requires signals which initiate containment isolation be derived from safety grade equipment. Discuss the qualification of the equipment providing the (a) high containment pressure, (b) high containment radiation and (c) safety injection actuation signals.
- 5. The NRC guideline requires that overriding or resetting of the isolation actuation signal does not cause automatic reopening of any isolation or purge valve. Discuss how the San Onofre Unit 1 design meets this guideline.

Note: If any of the above specific information has been provided in response to "Lessons Learned" or "Bulletins and Orders" requests, the licensee may respond by identifying the date and title of the letter containing the information.

NOTE: The following definitions are given for clarity of use in this issue:

- Override The signal is still present, and it is blocked in order to perform a function contrary to the signal.
- Reset The signal has come and gone, and the circuit is being cleared to return to the normal condition.