

Docket files

REGULATORY DOCKET FILE COPY

Docket No. 50-206

JUL 28 1980

Mr. R. Dietch
Vice President
Nuclear Engineering and Operations
Southern California Edison Company
2244 Walnut Grove Avenue
Post Office Box 800
Rosemead, California 91770

Dear Mr. Dietch:

SUBJECT: ANCHORAGE AND SUPPORT OF SAFETY RELATED ELECTRICAL EQUIPMENT

- References:
1. Letter from D. Eisenhut to SEP Licensees, dated January 1, 1980
 2. Letter from R. Schaffstall to D. Crutchfield, dated July 3, 1980

Reference 1 identified a potential safety concern relative to the anchorage and support of safety related electrical equipment and requested that you initiate a program to resolve this issue including the installation of any required modifications by September 1, 1980. Reference 2 describes a program which was developed by the Systematic Evaluation Program Owners Group in response to comments made by members of the NRC staff at a May 14, 1980 meeting in Bethesda. As a result of your comments and our review of Reference 2, we are providing additional guidance to you as indicated in the Attachments.

Attachment 1 provides guidance as to the expected scope of your investigations and information which should be documented for our review. A suggested format for this documentation is provided in Attachment 2. Due to the lack of clarification relative to certain requirements of Reference 1 and in particular the issue of support of internally attached electrical components, we will permit an extension until December 31, 1980 for completion of this program. This shall include the installation of any modifications which may be required as a result of your investigations. Any modifications shall be made in accordance with 10 CFR 50.59 of the Commission Regulations. We request that formal documentation summarizing your program be submitted to this office by December 31, 1980.

Existing plant floor response spectra or floor response spectra computed or estimated from the NRC Site Specific Spectra Program are acceptable

8008140445

D

OFFICE						
SURNAME						
DATE						

Mr. R. Dietch

-2-

for use in your evaluation. The conservatism of these loadings shall be verified when the final floor response spectra are available.

Sincerely,

Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

Attachments:
As stated

cc w/attachments:
See next page

DISTRIBUTION

Docket
NRC PDR
Local PDR
ORB Reading
SEPB Reading
NRR Reading
DCrutchfield
HSmith
TWambach
JRCarter
WRussell
OELD
OI&E (3)
ACRS (16)
TERA
NSIC
JRBuchanan, NSIC
HLevin
DAllison
DEisenhut
GLainas
RPurple

NA

OFFICE	SEPBDL	SEPBDL	SEPBDL	AD-SA:DL		
SURNAME	HLevin	DAllison	DCrutchfield	GLainas		
DATE	7/28/80	7/28/80	7/28/80	7/1/80		



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JUL 28 1980

Docket No. 50-206

Mr. R. Dietch
Vice President
Nuclear Engineering and Operations
Southern California Edison Company
2244 Walnut Grove Avenue
Post Office Box 800
Rosemead, California 91770

Dear Mr. Dietch:

SUBJECT: ANCHORAGE AND SUPPORT OF SAFETY RELATED ELECTRICAL EQUIPMENT

- References:
1. Letter from D. Eisenhut to SEP Licensees, dated January 1, 1980
 2. Letter from R. Schaffstall to D. Crutchfield, dated July 3, 1980

Reference 1 identified a potential safety concern relative to the anchorage and support of safety related electrical equipment and requested that you initiate a program to resolve this issue including the installation of any required modifications by September 1, 1980. Reference 2 describes a program which was developed by the Systematic Evaluation Program Owners Group in response to comments made by members of the NRC staff at a May 14, 1980 meeting in Bethesda. As a result of your comments and our review of Reference 2, we are providing additional guidance to you as indicated in the Attachments.

Attachment 1 provides guidance as to the expected scope of your investigations and information which should be documented for our review. A suggested format for this documentation is provided in Attachment 2. Due to the lack of clarification relative to certain requirements of Reference 1 and in particular the issue of support of internally attached electrical components, we will permit an extension until December 31, 1980 for completion of this program. This shall include the installation of any modifications which may be required as a result of your investigations. Any modifications shall be made in accordance with 10 CFR 50.59 of the Commission Regulations. We request that formal documentation summarizing your program be submitted to this office by December 31, 1980.

Existing plant floor response spectra or floor response spectra computed or estimated from the NRC Site Specific Spectra Program are acceptable

Mr. R. Dietch

-2-

JUL 28 1980

for use in your evaluation. The conservatism of these loadings shall be verified when the final floor response spectra are available.

Sincerely,

for Thomas V. Wambaruk
Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

Attachments:
As stated

cc w/attachments:
See next page

Mr. R. Dietch

cc

Charles R. Kocher, Assistant
General Counsel
Southern California Edison Company
Post Office Box 800
Rosemead, California 91770

David R. Pigott
SSamuel B. Casey
Chickering & Gregory
Three Embarcadero Center
Twenty-Third Floor
San Francisco, California 94111

Jack E. Thomas
Harry B. Stoehr
San Diego Gas & Electric Company
P. O. Box 1831
San Diego, California 92112

Resident Inspector
c/o U. S. NRC
P. O. Box AA
Oceanside, California 92054

Mission Viejo Branch Library
24851 Chrisanta Drive
Mission Viejo, California 92676

Mayor
City of San Clemente
San Clemente, California 92672

Chairman
Board of Supervisors
County of San Diego
San Diego, California 92101

California Department of Health
ATTN: Chief, Environmental
Radiation Control Unit
Radiological Health Section
714 P Street, Room 498
Sacramento, California 95814

Director, Technical Assessment
Division
Office of Radiation Programs
(AW-459)
U. S. Environmental Protection
Agency
Crystal Mall #2
Arlington, Virginia 20460

U. S. Environmental Protection
Agency
Region IX Office
ATTN: EIS COORDINATOR
215 Freemont Street
San Francisco, California 94111

ATTACHMENT 1
ANCHORAGE AND SUPPORT OF SAFETY
RELATED ELECTRICAL EQUIPMENT
POINTS TO BE ADDRESSED BY SEP
LICENSEES IN DECEMBER 31, 1980
SUBMITTAL

1. Information should be provided not only for the anchorage of electrical equipment but also the entire support that provides a load path (such as bracing and frames), as well as support for internally attached components. The latter is especially important for cabinet or panel type electrical equipment (such as control panels, instrument panels, etc.) which has internally supported components. An example of a potential improperly supported internal component would be a heavy component cantilevered off a front sheet metal panel without additional support to a stronger and stiffer location. These inadequate supports for internal components also should be identified and corrected before December 31, 1980.
2. In order to verify that an anchorage or a support of safety related electrical equipment has adequate capacity, provide justification by test, or analytical means. If expansion anchor bolts exist, justification provided previously for IE Bulletin 79-02 can be utilized if applicable. The acceptance criteria for substantiating these judgements should be provided, this may involve specifying the factor of safety and allowable stress limits used for design and justifying the overturning moment and shear force used.
3. Provide a table listing all (to include both floor and wall mounted) safety related electrical equipment in the plant. For each piece of equipment provide the information described in the attached table (attachment 2).

These investigations of each piece of equipment should determine:

- a. Whether positive anchorage or support exists
 - b. The type of anchorage
 - c. Whether internally attached components are properly supported
 - d. Identify non-seismic Category I equipment, the dislodgement of which during an earthquake may be detrimental to safety related equipment and render them inoperable. Inspection of the anchorages of such non-seismic Category I equipment should be conducted. If positive anchorages do not exist, they should be identified and modified before December 31, 1980.
4. Wherever modifications of anchorages or supports are required, these modifications should be implemented and thoroughly documented.
 5. The seismic design of cable trays may be treated as a separate problem, because of its complexity. Each licensee or the SEP Owner's Group should provide a separate action plan for the resolution of this issue within 30 days of receipt of this letter.

ATTACHMENT 2
SUMMARY OF INVESTIGATION OF ANCHORAGE AND SUPPORT OF
SAFETY RELATED ELECTRICAL EQUIPMENT AND NON-SEISMIC CATEGORY I
ITEMS THAT MAY DAMAGE THIS EQUIPMENT

Equip. Name	Equip. ID	System in Which Installed	Location Bldg. & Elev.	Type of Anchorage*	Was Anchorage Modified Since Jan. 1, 1980	Internally Attached Components			Non-Seismic Cat I Items that could potentially Interact with this equip.			I.D. of Document Supporting Conclusion
						Equip. Name & ID	Type of Support	Was Support Evaluated	Name & ID	Type of Support	Was Support Evaluated	

***Examples of Type of Anchorage:**

1. Bolted to Equipment
2. Bolted to Concrete Wall
3. Bolted to Concrete Slab
4. Bolted to Block Wall
5. Welded to Embedded Channel