

REGULATORY DOCKET FILE COPY

Docket No. 50-206

Mr. R. Dietch, Vice President
 Nuclear Engineering and Operations
 Southern California Edison Company
 2244 Walnut Grove Avenue
 Post Office Box 800
 Rosemead, California 91770

DISTRIBUTION:
 Docket
 NRC-PDR
 LPDR
 TERA
 NSIC
 NRR Reading
 ORB #5 Reading
 DEisenhut
 RPurple
 TNovak
 GLainas
 DKragh (11 - SEP Files)

RTedesco
 J01shinski
 DCrutchfield
 RScholl
 DAllison
 WRussell, SEPB
 OELD
 OI&E (3)
 HSmith
 Project Mgr.
 ACRS (16)
 JHeltemes

Dear Mr. Dietch:

RE: REQUEST FOR ADDITIONAL INFORMATION ON SEP TOPICS VI-7.B, VI-7.C, VI-10, VII-3, VIII-2 AND VIII-3 (SAN ONFORE NUCLEAR GENERATING STATION, UNIT NO. 1)

We are continuing our review of SEP Topics VI-7.B, ESF Switchover from Injection to Recirculation Mode; VI-7.C, ECCS Single Failure Criteria; VI-10.A, Testing of Reactor Trip System and ESF; VI-10.B, Shared Engineered Safety Features; VII-3, Systems Required for Safe Shutdown; VIII-2, Onsite Emergency Power Systems - Diesel Generator; VIII-3.A, Station Battery Test Requirements and VIII-3.B, DC Power System Bus Voltage Monitoring and Annunciation. We have found that additional information described in the enclosure to this letter is needed.

We request your response within 45 days of your receipt of this letter.

Sincerely,

Dennis M. Crutchfield, Chief
 Operating Reactors Branch #5
 Division of Licensing

Enclosure:
 Request for Additional
 Information on SEP
 Topics

cc w/enclosure:
 See next page

8010100117

P



OFFICE	DL:ORB #5/LA	DL:ORB #5/PM	DL:ORB #5/C			
SURNAME	HSmith.rj	SNowicki	DCrutchfield			
DATE	9/19/80	9/10/80	9/16/80			



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

September 16, 1980

Docket No. 50-206

Mr. R. Dietch, Vice President
Nuclear Engineering and Operations
Southern California Edison Company
2244 Walnut Grove Avenue
Post Office Box 800
Rosemead, California 91770

Dear Mr. Dietch:

RE: REQUEST FOR ADDITIONAL INFORMATION ON SEP TOPICS VI-7.B, VI-7.C,
VI-10, VII-3, VIII-2 AND VIII-3 (SAN ONOFRE NUCLEAR GENERATING STATION,
UNIT NO. 1)

We are continuing our review of SEP Topics VI-7.B, ESF Switchover from Injection to Recirculation Mode; VI-7.C, ECCS Single Failure Criteria; VI-10.A, Testing of Reactor Trip System and ESF; VI-10.B, Shared Engineered Safety Features; VII-3, Systems Required for Safe Shutdown; VIII-2, Onsite Emergency Power Systems - Diesel Generator; VIII-3.A, Station Battery Test Requirements and VIII-3.B, DC Power System Bus Voltage Monitoring and Annunciation. We have found that additional information described in the enclosure to this letter is needed.

We request your response within 45 days of your receipt of this letter.

Sincerely,


Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

Enclosure:
Request for Additional
Information on SEP
Topics

cc w/enclosure:
See next page

cc w/enclosure:

Charles R. Kocher, Assistant
General Counsel
Southern California Edison Company
Post Office Box 800
Rosemead, California 91770

David R. Pigott
SSamuel B. Casey
Chickering & Gregory
Three Embarcadero Center
Twenty-Third Floor
San Francisco, California 94111

Jack E. Thomas
Harry B. Stoehr
San Diego Gas & Electric Company
P. O. Box 1831
San Diego, California 92112

Resident Inspector
c/o U. S. NRC
P. O. Box AA
Oceanside, California 92054

Mission Viejo Branch Library
24851 Chrisanta Drive
Mission Viejo, California 92676

Mayor
City of San Clemente
San Clemente, California 92672

Chairman
Board of Supervisors
County of San Diego
San Diego, California 92101

California Department of Health
ATTN: Chief, Environmental
Radiation Control Unit
Radiological Health Section
714 P Street, Room 498
Sacramento, California 95814

Director, Technical Assessment
Division
Office of Radiation Programs
(AW-459)
U. S. Environmental Protection
Agency
Crystal Mall #2
Arlington, Virginia 20460

U. S. Environmental Protection
Agency
Region IX Office
ATTN: EIS COORDINATOR
215 Freemont Street
San Francisco, California 94111

Richard E. Schaffstall
KMC, Incorporated
1747 Pennsylvania Avenue, N. W.
Washington, D. C. 20006

REQUEST FOR ADDITIONAL INFORMATION
ON SEP TOPICS
VI-7.B, VI-7.C, VI-10, VII-3, VIII-2
AND VIII-3

As a result of our preliminary review of the subject topics, we will need the information described below in order to determine: (1) how many inverters may be placed on a single power supply during operation or while shutdown, and (2) the potential consequences of losing such power supplies.

1. Quantify the number of instrument inverters in your plant and for each inverter:
 - a) identify the inverter and its power supplies; and
 - b) describe the switching features that are provided to switch inverter power supplies and inverter loads (including synchronization circuits).
2. Provide the requirements for:
 - a) testing the transfer path's described in your responses to 1 above, and
 - b) limiting the number of redundant load groups that may be placed on any maintenance power source during each operating condition.
3. Describe the consequence of one or more load groups on a single dc source losing power (e.g. automatic initiation of ECCS, automatic initiation of transfer from ECCS injection made to recirculation mode, loss of indication in the control room, loss of annunciators, loss of plant communications, loss of emergency telephones).