

# REGULATORY DOCKET FILE COPY

Docket No. 50-206

Mr. R. Dietch, Vice President  
Nuclear Engineering and Operations  
Southern California Edison Company  
2244 Walnut Grove Avenue  
Post Office Box 800  
Rosemead, California 91770

## DISTRIBUTION:

Docket	RTedesco
NRC-PDR	JOlshinski
LPDR	DCrutchfield
TERA	RScholl
NSIC	DAllison
NRR Reading	WRussell, SEPB
ORB #5 Reading	OELD
DEisenhut	OI&E (3)
RPurple	HSmith
TNovak	Project Mgr.
GLainas	ACRS (16)
DKragh (11 - SEP Files)	JHeltemes

Dear Mr. Dietch:

RE: REQUEST FOR ADDITIONAL INFORMATION ON SEP TOPICS VI-7.B, VI-7.C, VI-10, VII-3, VIII-2 AND VIII-3 (SAN ONFORE NUCLEAR GENERATING STATION, UNIT NO. 1)

We are continuing our review of SEP Topics VI-7.B, ESF Switchover from Injection to Recirculation Mode; VI-7.C, ECCS Single Failure Criteria; VI-10.A, Testing of Reactor Trip System and ESF; VI-10.B, Shared Engineered Safety Features; VII-3, Systems Required for Safe Shutdown; VIII-2, Onsite Emergency Power Systems - Diesel Generator; VIII-3.A, Station Battery Test Requirements and VIII-3.B, DC Power System Bus Voltage Monitoring and Annunciation. We have found that additional information described in the enclosure to this letter is needed.

We request your response within 45 days of your receipt of this letter.

Sincerely,

Dennis M. Crutchfield, Chief  
Operating Reactors Branch #5  
Division of Licensing

Enclosure:  
Request for Additional  
Information on SEP  
Topics

cc w/enclosure:  
See next page

8010100 117 P

OFFICE	DL:ORB #5/LA	DL:ORB #5/PM	DL:ORB #5/C			
SURNAME	HSmith.rj	SNOWICKI	DCrutchfield			
DATE	9/19/80	9/10/80	9/16/80			



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

September 16, 1980

Docket No. 50-206

Mr. R. Dietch, Vice President  
Nuclear Engineering and Operations  
Southern California Edison Company  
2244 Walnut Grove Avenue  
Post Office Box 800  
Rosemead, California 91770

Dear Mr. Dietch:

RE: REQUEST FOR ADDITIONAL INFORMATION ON SEP TOPICS VI-7.B, VI-7.C,  
VI-10, VII-3, VIII-2 AND VIII-3 (SAN ONOFRE NUCLEAR GENERATING STATION,  
UNIT NO. 1)

We are continuing our review of SEP Topics VI-7.B, ESF Switchover from Injection to Recirculation Mode; VI-7.C, ECCS Single Failure Criteria; VI-10.A, Testing of Reactor Trip System and ESF; VI-10.B, Shared Engineered Safety Features; VII-3, Systems Required for Safe Shutdown; VIII-2, Onsite Emergency Power Systems - Diesel Generator; VIII-3.A, Station Battery Test Requirements and VIII-3.B, DC Power System Bus Voltage Monitoring and Annunciation. We have found that additional information described in the enclosure to this letter is needed.

We request your response within 45 days of your receipt of this letter.

Sincerely,

  
Dennis M. Crutchfield, Chief  
Operating Reactors Branch #5  
Division of Licensing

Enclosure:  
Request for Additional  
Information on SEP  
Topics

cc w/enclosure:  
See next page

September 16, 1980

cc w/enclosure:

Charles R. Kocher, Assistant  
General Counsel  
Southern California Edison Company  
Post Office Box 800  
Rosemead, California 91770

David R. Pigott  
Samuel B. Casey  
Chickering & Gregory  
Three Embarcadero Center  
Twenty-Third Floor  
San Francisco, California 94111

Jack E. Thomas  
Harry B. Stoehr  
San Diego Gas & Electric Company  
P. O. Box 1831  
San Diego, California 92112

Resident Inspector  
c/o U. S. NRC  
P. O. Box AA  
Oceanside, California 92054

Mission Viejo Branch Library  
24851 Chrisanta Drive  
Mission Viejo, California 92676

Mayor  
City of San Clemente  
San Clemente, California 92672

Chairman  
Board of Supervisors  
County of San Diego  
San Diego, California 92101

California Department of Health  
ATTN: Chief, Environmental  
Radiation Control Unit  
Radiological Health Section  
714 P Street, Room 498  
Sacramento, California 95814

Director, Technical Assessment  
Division  
Office of Radiation Programs  
(AW-459)  
U. S. Environmental Protection  
Agency  
Crystal Mall #2  
Arlington, Virginia 20460

U. S. Environmental Protection  
Agency  
Region IX Office  
ATTN: EIS COORDINATOR  
215 Freemont Street  
San Francisco, California 94111

Richard E. Schaffstall  
KMC, Incorporated  
1747 Pennsylvania Avenue, N. W.  
Washington, D. C. 20006

REQUEST FOR ADDITIONAL INFORMATION  
ON SEP TOPICS  
VI-7.B, VI-7.C, VI-10, VII-3, VIII-2  
AND VIII-3

As a result of our preliminary review of the subject topics, we will need the information described below in order to determine: (1) how many inverters may be placed on a single power supply during operation or while shutdown, and (2) the potential consequences of losing such power supplies.

1. Quantify the number of instrument inverters in your plant and for each inverter:
  - a) identify the inverter and its power supplies; and
  - b) describe the switching features that are provided to switch inverter power supplies and inverter loads (including synchronization circuits).
2. Provide the requirements for:
  - a) testing the transfer path's described in your responses to 1 above, and
  - b) limiting the number of redundant load groups that may be placed on any maintenance power source during each operating condition.
3. Describe the consequence of one or more load groups on a single dc source losing power (e.g. automatic initiation of ECCS, automatic initiation of transfer from ECCS injection mode to recirculation mode, loss of indication in the control room, loss of annunciators, loss of plant communications, loss of emergency telephones).