



Southern California Edison Company

P. O. BOX 800

2244 WALNUT GROVE AVENUE

ROSEMEAD, CALIFORNIA 91770

April 5, 1989

TELEPHONE
(818) 302-1896

F. R. NANDY
MANAGER OF NUCLEAR LICENSING

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Docket No. 50-206
Radiological Consequences of Feedwater Line Break
Outside Containment
San Onofre Nuclear Generating Station
Unit 1

By letter dated November 20, 1987, SCE submitted the revised Cycle 10 auxiliary feedwater system transient analysis as Enclosure 2. SCE indicated that the radiological consequences for the feedwater line break transient were under review and committed to provide the results of this review to the NRC.

SCE has determined that the radiological consequences for this case are bounded by the results of the previous dose calculations submitted to the NRC by letter dated July 2, 1987 and approved in NRC letter dated July 16, 1987. This dose evaluation has been included in the Updated FSAR for San Onofre Unit 1.

The NRC letter dated July 16, 1987, requested a written notification upon the completion of the single failure modifications to the steam flow/feedwater flow mismatch trip. The Confirmatory Action Letter dated February 8, 1989, further requested a written certification of completion of all commitments prior to the Mode 2 entry. The request for written notification of the completion of the single failure modifications to the mismatch trip will, therefore, be satisfied by the certification letter as requested in the Confirmatory Action Letter.

If you have any questions regarding this matter, please contact me.

Very truly yours,

A009
1/0

cc: J. B. Martin, Regional Administrator, NRC Region V
F. R. Huey, NRC Senior Resident Inspector, San Onofre Units 1, 2 and 3

8904120472 890405
PDR ADOCK 05000206
PDC