

May 1, 1989

Docket No.: 50-206

DISTRIBUTION  
Docket File  
NRC & LPDRs  
CTrammell (2)  
MVirgilio  
JLee  
OGC-White Flint  
PD5 Plant File  
EJordan  
BGrimes  
ACRS (10)  
S. Saba  
F. Burrows

Mr. Kenneth P. Baskin  
Vice President  
Southern California Edison Company  
2244 Walnut Grove Avenue  
Post Office Box 800  
Rosemead, California 91770

Dear Mr. Baskin:

SUBJECT: LOAD SEQUENCER DESIGN DEFICIENCY  
(TAC NO. 72709)

Re: San Onofre Nuclear Generating Station, Unit No. 1

This refers to the design deficiency you reported on March 2, 1989, wherein the closure of one diesel-generator output breaker would prevent the closure of the other diesel-generator output breaker under certain conditions. As discussed more fully in the enclosed Safety Evaluation, we have reviewed your corrective action and find that it eliminates the deficiency and is therefore acceptable.

Sincerely,

original signed by

Charles M. Trammell, Senior Project Manager  
Project Directorate V  
Division of Reactor Projects - III,  
IV, V and Special Projects

Enclosure:  
Safety Evaluation

cc: w/enclosure:  
See next page

*CT*  
DRE PD5  
CTrammell:  
4/27/88

*GM*  
DRE PD5  
GKington  
5/1/88

OFFICIAL RECORD COPY

8905080197 890501  
PDR ADOCK 05000206  
P PIC

*DF01*  
*11*  
*m/A-4*  
*ew*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

May 1, 1989

Docket No.: 50-206

Mr. Kenneth P. Baskin  
Vice President  
Southern California Edison Company  
2244 Walnut Grove Avenue  
Post Office Box 800  
Rosemead, California 91770

Dear Mr. Baskin:

SUBJECT: LOAD SEQUENCER DESIGN DEFICIENCY  
(TAC NO. 72709)

Re: San Onofre Nuclear Generating Station, Unit No. 1

This refers to the design deficiency you reported on March 2, 1989, wherein the closure of one diesel-generator output breaker would prevent the closure of the other diesel-generator output breaker under certain conditions. As discussed more fully in the enclosed Safety Evaluation, we have reviewed your corrective action and find that it eliminates the deficiency and is therefore acceptable.

Sincerely,

A handwritten signature in cursive script that reads "Charles M. Trammell".

Charles M. Trammell, Senior Project Manager  
Project Directorate V  
Division of Reactor Projects - III,  
IV, V and Special Projects

Enclosure:  
Safety Evaluation

cc: w/enclosure:  
See next page

Mr. Kenneth P. Baskin  
Southern California Edison Company

San Onofre Nuclear Generating  
Station, Unit No. 1

cc  
Mr. Kenneth P. Baskin  
Vice President  
Southern California Edison Company  
2244 Walnut Grove Avenue  
Post Office Box 800  
Rosemead, California 91770

Mr. Paul Szalinski, Chief  
Radiological Health Branch  
State Department of Health  
Services  
714 P Street, Office Bldg. #8  
Sacramento, California 95814

David R. Pigott  
Orrick, Herrington & Sutcliffe  
600 Montgomery Street  
San Francisco, California 94111

Charles R. Kocher, Assistant  
General Counsel  
James Beoletto, Esquire  
Southern California Edison Company  
Post Office Box 800  
Rosemead, California 91770

Mr. Robert G. Lacy  
Manager, Nuclear  
San Diego Gas & Electric Company  
P. O. Box 1831  
San Diego, California 92112

Resident Inspector/San Onofre NPS  
U.S. NRC  
P. O. Box 4329  
San Clemente, California 92672

Mayor  
City of San Clemente  
San Clemente, California 92672

Chairman  
Board of Supervisors  
County of San Diego  
1600 Pacific Highway Room 335  
San Diego, California 92101

Director  
Energy Facilities Siting Division  
Energy Resources Conservation &  
Development Commission  
1516 - 9th Street  
Sacramento, California 95814

Regional Administrator, Region V  
U.S. Nuclear Regulatory Commission  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596