



*Southern California Edison Company*

23 PARKER STREET  
IRVINE, CALIFORNIA 92718

R. M. ROSENBLUM  
MANAGER OF  
NUCLEAR REGULATORY AFFAIRS

TELEPHONE  
(714) 587-5420

February 12, 1990

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

Subject: Docket No. 50-206  
Intake Structure Repair (TAC No. 74168)  
San Onofre Nuclear Generating Station  
Unit 1

Reference: Letter, C. M. Trammell, to Harold B. Ray, "Intake Structure  
Repair, San Onofre Nuclear Generating Station, Unit No. 1,"  
dated November 6, 1989

This letter provides the information requested by the NRC in the referenced letter regarding repair of the intake structure at the San Onofre Nuclear Generating Station, Unit 1. Specifically, the enclosure to this letter gives responses to six NRC questions on the current status and adequacy of the intake structure repair. To assist NRC review of this additional information, the enclosure repeats the NRC question followed by the Southern California Edison response for each of the six areas of inquiry.

The information in the enclosure supplements that provided by Southern California Edison in previous correspondence on this issue. This additional information reinforces our conclusion that the surveillance/repair program now in place is sufficient to maintain the intake structure's ability to withstand the Design Basis Earthquake throughout the remaining plant life. This conclusion is based upon i) successful operation of the installed repairs, ii) relatively low rebar corrosion rates observed to date, iii) frequent inspections (every refueling outage), iv) the thoroughness of the surveillance program and v) the conservatism of the repair design (zero load carrying capability assumed for corroded rebar).

Please contact me if you have any remaining questions and/or wish to schedule the review meeting requested in the referenced letter.

Very truly yours,

Enclosure

cc: J. B. Martin, Regional Administrator, NRC Region V  
C. Caldwell, NRC Senior Resident Inspector, San Onofre Units 1, 2 and 3

9002220150 900212  
PDR ADOCK 05000206  
P PNU

A001  
1/1