

February 23, 1990

Docket Nos. 50-206, 50-361  
and 50-362

Mr. Harold B. Ray  
Vice President  
Southern California Edison Co.  
Irvine Operations Center  
23 Parker Street  
Irvine, California 92718

Mr. Gary D. Cotton  
Senior Vice President  
Engineering and Operations  
San Diego Gas & Electric Co.  
101 Ash Street  
San Diego, California 92112

Gentlemen:

SUBJECT: RESPONSE TO GENERIC LETTER 89-13, SERVICE WATER SYSTEM PROBLEMS  
AFFECTING SAFETY-RELATED EQUIPMENT (TAC NOS. 74056, 74057 AND 74058)

Generic Letter 89-13 requests licensees to take certain actions to ensure that their service water systems are in compliance and will be maintained in compliance with 10 CFR 50, Appendix A, General Design Criteria 44, 45 and 46, and with 10 CFR Part 50, Appendix B, Section XI. The generic letter requires licensees to advise the NRC within 180 days of their receipt of the generic letter whether they have established programs to implement the recommended actions and provide schedules for implementation. Additionally, the generic letter requests each licensee to confirm to the NRC that all the recommended actions have been implemented within 30 days of the final implementation date.

We have reviewed your letter dated January 26, 1990, submitted in response to the initial reporting requirements of the generic letter. We conclude that your plans for establishing and implementing programs to address the generic letter recommendations are acceptable. In addition, we commend you for taking the initiative to expand the scope of your review to include additional safety-related heat exchangers that are not within the scope of the generic letter.

Sincerely,

original signed by Lawrence Kokajko

James E. Tatum, Project Manager  
Project Directorate V  
Division of Reactor Projects - III  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

9002280265 900223  
PDR ADOCK 05000204  
P PDC

cc: See next page

DISTRIBUTION

Docket File	NRC & Local PDRs	PDV Reading	J. Tatum
J. Zwolinski	P. Shea	C. Trammell	
L. Kokajko	OGC	ACRS (10)	
A. Chu	E. Jordan	C. Hodge	

[GL 89-13]

DRSP/PDV  
PShea  
2/22/90

DRSP/PDV  
JTatum:sg  
2/22/90

DRSP/PDV  
LKokajko  
2/22/90

(A) DRSP/D/PDV  
CTrammell  
2/22/90

*LFol 1/10*  
*ma/4*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

February 23, 1990

Docket Nos. 50-206, 50-361  
and 50-362

Mr. Harold B. Ray  
Vice President  
Southern California Edison Co.  
Irvine Operations Center  
23 Parker Street  
Irvine, California 92718

Mr. Gary D. Cotton  
Senior Vice President  
Engineering and Operations  
San Diego Gas & Electric Co.  
101 Ash Street  
San Diego, California 92112

Gentlemen:

SUBJECT: RESPONSE TO GENERIC LETTER 89-13, SERVICE WATER SYSTEM PROBLEMS  
AFFECTING SAFETY-RELATED EQUIPMENT (TAC NOS. 74056, 74057 AND 74058)

Generic Letter 89-13 requests licensees to take certain actions to ensure that their service water systems are in compliance and will be maintained in compliance with 10 CFR 50, Appendix A, General Design Criteria 44, 45 and 46, and with 10 CFR Part 50, Appendix B, Section XI. The generic letter requires licensees to advise the NRC within 180 days of their receipt of the generic letter whether they have established programs to implement the recommended actions and provide schedules for implementation. Additionally, the generic letter requests each licensee to confirm to the NRC that all the recommended actions have been implemented within 30 days of the final implementation date.

We have reviewed your letter dated January 26, 1990, submitted in response to the initial reporting requirements of the generic letter. We conclude that your plans for establishing and implementing programs to address the generic letter recommendations are acceptable. In addition, we commend you for taking the initiative to expand the scope of your review to include additional safety-related heat exchangers that are not within the scope of the generic letter.

Sincerely,

A handwritten signature in dark ink, appearing to read "James E. Tatum", is written over a horizontal line.

James E. Tatum, Project Manager  
Project Directorate V  
Division of Reactor Projects - III  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

cc: See next page

Mr. Harold B. Ray  
Southern California Edison Company

cc  
David R. Pigott  
Orrick, Herrington & Sutcliffe  
The Old Federal Reserve Bank Bldg.  
400 Sansome Street  
San Francisco, California 94111

Mr. Robert G. Lacy  
Manager, Nuclear  
San Diego Gas & Electric Company  
P. O. Box 1831  
San Diego, California 92112

Resident Inspector/San Onofre NPS  
U.S. NRC  
P. O. Box 4329  
San Clemente, California 92672

Mayor  
City of San Clemente  
San Clemente, California 92672

Chairman  
Board of Supervisors  
County of San Diego  
1600 Pacific Highway Room 335  
San Diego, California 92101

Regional Administrator, Region V  
U.S. Nuclear Regulatory Commission  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596

Mr. John Hickman, Senior Health  
Physicist  
Environmental Radioactive Mgmt. Unit  
Environmental Management Branch  
State Department of Health Services  
714 P Street, Room 616  
Sacramento, California 95814

Mr. Don Womeldorf  
Chief Environmental Management  
California Department of Health  
714 P Street, Room 616  
Sacramento, California 95814

San Onofre Nuclear Generating  
Station, Units No. 1, 2, and 3

Mr. Gary D. Cotton  
Senior Vice President  
Engineering and Operations  
San Diego Gas & Electric Company  
101 Ash Street, P.O. Box 1831  
San Diego, California 92112

Mr. Charles B. Brinkman  
Combustion Engineering, Inc.  
12300 Twinbrook Parkway, Suite 300  
Rockville, Maryland 20852

Alan R. Watts, Esq.  
Rourke & Woodruff  
701 S. Parker St. No. 7000  
Orange, California 92668-4702

Mr. Sherwin Harris  
Resource Project Manager  
Public Utilities Department  
City of Riverside  
3900 Main Street  
Riverside California 92522

Mr. Phil Johnson  
U.S. Nuclear Regulatory Commission  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94589

Mr. F. B. Marsh, Project Manager  
Bechtel Power Corporation  
P. O. Box 60860  
Terminal Annex  
Los Angeles, California 90060

Charles R. Kocher, Esq.  
James A. Beoletto, Esq.  
Southern California Edison Company  
Irvine Operations Center  
23 Parker  
Irvine, California 92718