

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8108110281 DOC. DATE: 81/08/07 NOTARIZED: NO DOCKET #  
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern California 05000361  
 AUTH. NAME: AUTHOR AFFILIATION  
 BASKIN, K. P. Southern California Edison Co.  
 RECIP. NAME: RECIPIENT AFFILIATION  
 MIRAGLIA, F. Licensing Branch 3

SUBJECT: Forwards Revision 1 to CEN-168 (s), "Comprehensive Vibration Assessment Program Final Rept," "Precritical Vibration Monitoring Program Project Procedure for Visual Insp of Reactor Vessel Internals & procedure for 3410 type plants.

*See subject files*  
 DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 63 SIZE: 21 60  
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES: Send all FSAR & ER amends to L Chandler. 05000361  
 1 cy: J Hanchett (Region V). D Scaletti, 1 cy of all envir info

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTTR	ENCL		ID CODE/NAME	LTTR
ACTION:	A/D LICENSNG	1	0	LIC BR #3 BC	1	0
	LIC BR #3 LA	1	0	ROOD, H.	04	1
INTERNAL:	ACCID EVAL BR26	1	1	AUX SYS BR 27	1	1
	CHEM ENG BR 11	1	1	CONT SYS BR 09	1	1
	CORE PERF BR 10	1	1	EFF TR SYS BR12	1	1
	EMRG PRP DEV 35	1	1	EMRG PRP LIC 36	3	3
	EQUIP QUAL BR13	3	3	FEMA-REP DIV 39	1	1
	GEOSCIENCES 28	2	2	HUM FACT ENG 40	1	1
	HYD/GEO BR 30	2	2	I&C SYS BR 16	1	1
	I&E 06	3	3	LIC GUID BR 33	1	1
	LIC QUAL BR 32	1	1	MATL ENG BR 17	1	1
	MECH ENG BR 18	1	1	MPA	1	0
	NRC PDRI 02	1	1	QELD	1	0
	OP LIC BR 34	1	1	POWER SYS BR 19	1	1
	PROC/TST REV 20	1	1	QA BR 21	1	1
	RAD ASSESS BR22	1	1	REAC SYS BR 23	1	1
	<u>REG FILE</u> 01	1	1	SIT ANAL BR 24	1	1
STRUCT ENG BR25	1	1				
EXTERNAL:	ACRS 41	16	16	LPDR 03	1	1
	NSIC 05	1	1	NTIS	1	1

AUG 13 1981

TOTAL NUMBER OF COPIES REQUIRED: LTTR

63 ENCL 58  
~~62~~ ~~51~~

✓

*Southern California Edison Company*

**SCE**

P. O. BOX 800  
2244 WALNUT GROVE AVENUE  
ROSEMEAD, CALIFORNIA 91770

K. P. BASKIN  
MANAGER OF NUCLEAR ENGINEERING,  
SAFETY, AND LICENSING

August 7, 1981

TELEPHONE  
(213) 572-1401

Director, Office of Nuclear Reactor Regulation  
Attention: Mr. Frank Miraglia, Branch Chief  
Licensing Branch No. 3  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555



Gentlemen:

Subject: Docket No. 50-361  
San Onofre Nuclear Generating Station  
Unit 2

Enclosed are sixty-three (63) copies of the Comprehensive Vibration Assessment Program (CVAP) final report and supporting procedures verifying the design adequacy of reactor internals for San Onofre Unit 2. This submittal satisfies the commitment referred to in SER Section 3.9.2.3 and raw data supporting this submittal is available on site for NRC inspection.

Relevant portions of the information will be incorporated into the FSAR, Section 3.9 and direct distribution of this information will be made as part of the Amendment 26 distribution and will be in accordance with the service list provided by SCE's letter of October 29, 1979. An affidavit attesting to the fact that distribution has been completed will be provided within ten days of docketing of Amendment 26.

If you have any questions or comments concerning this information, please contact me.

Very truly yours,

*KP Baskin / W. C. Moody*

Enclosures

Boo1  
S  
1/63

8108110281 810807  
PDR ADCK 05000361  
A PDR

SOUTHERN CALIFORNIA EDISON COMPANY  
SAN ONOFRE NUCLEAR GENERATING STATION - UNIT 2

SUBMITTAL OF DOCUMENTATION  
REQUIRED BY  
USNRC REGULATORY GUIDE 1.20  
COMPREHENSIVE VIBRATION ASSESSMENT PROGRAM

TABLE OF CONTENTS

<u>Enclosure No.</u>	<u>Title</u>
(1)	C-E Report No. CEN-168(S), Revision 01, dated July 1981, "San Onofre Nuclear Generating Station Unit 2, Docket No. 50-361, Comprehensive Vibration Assessment Program Final Report"
(2)	C-E Specification No. 00000-RCE-413, Revision 00, dated June 12, 1980, "Precritical Vibration Monitoring Program Standard Procedure for Visual Inspection of Reactor Vessel Internals for 3410 Type Plants"
(3)	C-E Specification No. 1370-RCE-413, Revision 00, dated August 13, 1980, "Precritical Vibration Monitoring Program Project Procedure for Southern California Edison Company San Onofre Units 2 and 3"