July 31, 1981

Docket No. 50-361/362 LS05-81-07-087

Ð

Mr. Ken P. Baskin, Chairman CE Owners Group Southern California Edison Co. P. O. Box 800 2244 Walnut Grove Avenue Rosemead, California 91770

Dear Mr. Baskin:

SUBJECT: CE REACTOR VESSEL LEVEL MEASUREMENT SYSTEM

Reference: TMI Action Plan Item II.F.2.3 of NUREG-0737

The NRC staff has completed its review of the CE Heated Junction Thermocouple (HJTC) reactor vessel level measurement system, which was submitted in Amendment 23, dated February 1981, of San Onofre Units 2 and 3 response to NRC Action Plan NUREG-0660. Enclosed is a request for additional information, which is being transmitted for response in regard to all CE plants. Southern California Edison Company has been requested by a separate letter to respond with respect to San Onofre Units 2 and 3.

In order to facilitate our review of San Onofre Units 2 and 3 and other plants using the CE HJTC, the CE Owners Group is requested to also provide a generic submittal covering those aspects of the design and test program which are common for all of these systems. The generic submittal should identify those aspects of the design (e.g., data processing equipment and displays) which are to be addressed on plant-specific dockets.

Your generic submittal should include responses to the attached staff questions. We believe the first 13 questions are generic in nature. Your response should be submitted no later than September 1, 1981.

This information collection is approved under OMB Clearance No. 3150-0011.

Sincerely,

Original signed by

Dennis M. Crutchfield, Chief Operating Reactors Branch #5 Division of Licensing

Enc	closure:	
As	stated	

		Ç U						4	
	cc: CE	License	es		DL: ORB #50	DL: DRB #	5 DL: 0	RB #3_ DV	MARK #5
		and Serv	vice L	ists	JShea:cc	HSUTIER	RCIari	Reclar Dd	utch field
₽ 81082 PD8 A	50750 B	10731			7 39 81	17/30	8/7/20	161 7	121 181
NRC FORM 318 HO/BUTNKC	B/BOFNRCM	PDR		OFFICIAL	RECORD C	OPY	12.1. 1.19.20	<u>/0/</u>	SPO: 1980-329-824

DISTRIBUTION Docket SEPB NRC PDR Local PDR NSTC TERa ORB Reading DCrutchfield HSmith SNowicki OELD 0I&E(3)ACRS (10) RClark JShea LPhillips JDonohew J01shinski

(L)

Œ.

NUCLEAR REGINATION

COMMANS ON

M. S.

Mr. Ken P. Baskin

July 31, 1981

cc M. I. Miller, Esquire Isham, Lincoln & Beale Suite 4200 One First National Plaza Chicago, Illinois 60670

1

Mr. Paul A. Perry, Secretary Consumers Power Company 212 West Michigan Avenue Jackson, Michigan 49201

Judd L. Bacon, Esquire Consumers Power Company 212 West Michigan Avenue Jackson, Michigan 49201

Myron M. Cherry, Esquire Suite 4501 One IBM Plaza Chicago, Illinois 60611

Ms. Mary P. Sinclair Great Lakes Energy Alliance 5711 Summerset Drive Midland, Michigan 48640

Kalamazoo Public Library 315 South Rose Street Kalamazoo, Michigan 49006

Township Supervisor Covert Township Route 1, Box 10 Van Buren County, Michigan 49043

Office of the Governor (2) Room 1 - Capitol Building Lansing, Michigan 48913

William J. Scanlon, Esquire 2034 Pauline Boulevard Ann Arbor, Michigan 48103

Palisades Plant ATTN: Mr. Robert Montross Plant Manager Covert, Michigan 49043 U. S. Environmental Protection Agency Federal Activities Branch Region V Office ATTN: EIS COORDINATOR 230 South Dearborn Street Chicago, Illinois 60604

Charles Bechhoefer, Esq., Chairman Atomic Safety and Licensing Board Panel U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Dr. George C. Anderson Department of Oceanography University of Washington Seattle, Washington 98195

Dr. M. Stanley Livingston 1005 Calle Largo * Santa Fe, New Mexico 87501

Resident Inspector c/o U. S. NRC P. O. Box 87-South Haven, Michigan 49090

Mr. David P. Hoffman Nuclear Licensing Administrator Consumers Power Company 1945 W. Parnall Road Jackson, Michigan 49201

- 2 -

Northeast Nuclear Energy Company - 3 -

July 31, 1981

William H. Cuddy, Esquire Day, Berry & Howard Counselors at Law One Constitution Plaza Hartford, Connecticut 06103

Natural Resources Defense Council 917 15th Street, N.W. Washington, D. C. 20005

Mr. Lawrence Bettencourt, First Selectman Town of Waterford Hall of Records - 200 Boston Post Road Waterford, Connecticut 06385

Northeast Nuclear Energy Company ATTN: Superintendent Millstone Plant Post Office Box 128 Waterford, Connecticut 06385

Waterford Public Library Rope Ferry Road, Route 156 Waterford, Connecticut 06385

U. S. Environmental Protection Agnecy Region I Office ATTN: EIS COORDINATOR John F. Kennedy Federal Building Boston, Massachusetts 02203

Northeast Utilities Service Company ATTN: Mr. James R. Himmelwright Nuclear Engineering and Operations P. O. Box 270 Hartford, Connecticut <u>0</u>6101 Mr. John Shedlosky Resident Inspector/Millstone c/o U.S.N.R.C. P. O. Drawer KK Niantic, CT 06357

Mr. Charles Brinkman Manager - Washington Nuclear Operations C-E Power Systems Combustion Engineering, Inc. 4853 Cordell Aven., Suite A-1 Bethesda, MD 20014

Connecticut Energy Agency ATTN: Assistant Director, Research and Policy Development Department of Planning and Energy Policy 20 Grand Street Hartford, CT 06106

Mr. W. G. counsil, Vice President Nuclear Engineering & Operations Northeast Nuclear Energy CompanyP. O. Box 270Hartford, Connecticut 06101

cc:

Florida Power & Light Company

- 4 -

July 31, 1981

cc: Robert Lowenstein, Esquire Lowenstein, Newman, Reis & Alexrad 1025 Connecticut Avenue, N.W. Washington, D. C. 20036

Norman A. Coll, Esquire McCarthy, Steel, Hector & Davis 14th Floor, First National Bank Building Miami Florida 33131

Indian River Junior College Library 3209 Virginia Avenue Fort Pierce, Florida 33450

Administrator Department of Environmental Regulation Power Plant Siting Section State of Florida 2600 Blair Stone Road Tallahassee, Florida 32301

Mr. Weldon B. Lewis County Administrator St. Lucie County 2300 Virginia Avenue, Room 104 Fort Pierce, Florida 33450

U.S. Environmental Protection Agency Region IV Office ATTN: EIS COORDINATOR 345 Courtland Street, N.E. Atlanta, Georgia 30308

Mr. Charles B. Brinkman Manager - Washington Nuclear Operations C-E Power Systems Combustion Engineering, Inc. 4853 Cordell Avenue, Suite A-1 Bethesda, Maryland 20014 Mr. Jack Schreve Office of the Public Counsel Room 4, Holland Building Tallahassee, Florida 32304

Resident Inspector/St. Lucie Nuclear Power Station c/o U.S.N.R.C. P. O. Box 400 Jensen Beach, Florida 33457

Bureau of Intergovernmental Relations 660 Apalachee Parkway Tallahassee, Florida 32304

Dr. Robert E. Uhrig Vice President Advanced Systems & Technology Florida Power & Light Company P. O. Box 529100 Miami, Florida 33152 Maine Yankee Atomic Power Company - 5 -

July 31, 1981

cc:

E. W. Thurlow, President Maine Yankee Atomic Power Company Edison Drive Augusta, Maine 04336

Mr. Donald E. Vandenburgh Vice President - Engineering Yankee Atomic Electric Company 20 Turnpike Road Westboro, Massachusetts 01581

John A. Ritsher, Esquire Ropes & Gray 225 Franklin Street Boston, Massachusetts 02110

Mr. Rufus E. Brown Deputy Attorney General State of Maine Aŭgusta, Maine 04330

Mr. Nicholas Barth
Executive Director
Sheepscot Valley Conservation
Association, Inc.
P. 0. Box 125
Alan, Maine 04535

Wiscassett Public Library Association High Street Wiscasset, Maine 04578

Mr. Torbet H. Macdonald, Jr. Office of Energy Resources State House Station #53 Augusta, Maine 04333

Robert M. Lazo, Esq., Chairman Atomic Safety and Licensing Board U.S. Nuclear Regulatory Commission Washington, D. C. 20555

Dr. Cadet H. Hand, Jr., Director Bodega Marine Laboratory University of California Bodega Bay, California 94923

Mr. Gustave A. Linenberger Atomic Safety and Licensing Board U.S. Nuclear Regulatory Commission Washington, D. C. 20555 Mrs. L. Patricia Doyle, President SAFE POWER FOR MAINE Post Office Box 774 Camden, Maine 04843

First Selectman of Wiscasset Municipal Building U. S. Route 1 Wiscasset, Maine 04578

Stanley R. Tupper, Esq. Tupper and Bradley 102 Townsend Avenue Boothbay Harbor, Maine 04538

David Santee Miller, Esq. 213 Morgan Street, N. W. Washington, D. C. 20001

Mr. Paul Swetland Resident Inspector/Maine Yankee c/o U.S.N.R.C. P. O. Box E Wiscasset, Maine 04578

Mr. Charles B. Brinkman Manager - Washington Nuclear Operations Combustion Engineering Inc. 4853 Cordell Avenue, Suite A-1 Bethesda, Maryland 20014

Mr. John H. Garrity, Director Nuclear Engineering & Licensing Maine Yankee Atomic Power Company Edison Drive Augusta, Maine 04336

U.S. Environmental Protection Agency Region I Office ATTN: EIS COORDINATOR JFK Federal Building Boston, Massachusetts 02203

Mr. Robert H. Groce Senior Engineer - Licensing Maine Yankee Atomic Power Company 1671 Worcester Road Framingham, Massachusetts 01701

State Planning Office Executive Department 189 State Street Augusts, Maine 04330

Omaha Public Power District



ccc:

Marilyn T. Shaw, Esq. LeBoeuf, Lamb, Leiby & MacRae 1333 New Hampshire Avenue, N.W. Washington, D. C. 20036

Mr. Emmett Rogert Chairman, Washington County Board of Supervisors Blair, Nebraska 68023

U.S. Environmental Protection Agency Region VII ATTN: EIS COORDINATOR 324 East 11th Street Kansas City, Missouri 64106

Mr. Frank Gibson W. Dale Clark Library 215 South 15th Street Omaha, Nebraska 68102

Alan H. Kirshen, Esq. Fellman, Ramsey & Kirshen 1166 Woodmen Tower Omaha, Nebraska 68102

Mr. Dennis Kelley U.S.N.R.C. Resident Inspector P. O. Box 68 Fort Calhoun, Nebraska 68023

Mr. Charles B. Brinkman
Manager - Washington Nuclear
Operations
C-E Power Systems
Combustion Engineering, Inc.
4853 Cordell Avenue, Suite A-1
Bethesda, Maryland 20014

Director, Nebraska Department of Environmental Control P. O. Box 94877, State House Station Lincoln, Nebraska 68509 Mr. W. C. Jones Division Manager, Production Operations Omaha Public Power District 1623 Harney Street Omaha, Nebraska 68102

Baltimore Gas and Electric Company



cc: James A. Biddison, Jr. General Counsel . Baltimore Gas and Electric Company P. O. Box 1475 Baltimore, MD 21203

George F. Trowbridge, Esquire Shaw, Pittman, Potts and Trowbridge 1800 M Street, N. W. Washington, D. C. 20036

Mr. R. C. L. Olson, Principal Engineer Nuclear Licensing Analysis Unit Baltimore Gas and Electric Company Room 922 - G&E Building P. O. Box 1475 / Baltimore, MD 21203

Mr. Leon B. Russell Plant Superintendent Calvert Cliffs Nuclear Power Plant Maryland Routes 2 & 4 Lusby, MD 20657

Bechtel Power Corporation Attn: Mr. J. C. Judd Chief Nuclear Engineer 15740 Shady Grove Road Gaithersburg, MD 20760

Combustion Engineering, Inc. Attn: Mr. P. W. Kruse, Manager Engineering Services P. O. Box 500 Windsor, CT 06095

Public Document Room Calvert County Library Prince Frederick, MD 20678

Director, Department of State Planning 301 West Preston Street Baltimore, MD 21201

Mr. R. M. Douglass, Manager Quality Assurance Department Fort Smallwood Road Complex P. O. Box 1475 Baltimore, MD 21203

Mr. T. L. Syndor, General Supervisor Operations Quality Assurance Calvert Cliffs Nuclear Power Plant Maryland Routes 2 & 4 Lusby, MD 20657 Ms. Mary Harrison, President Calvert County Board of County Commissioners Prince Frederick, MD 20768

U. S. Environmental Protection Agency Region III Office Attn: EIS Coordinator Curtis Building (Sixth Floor) Sixth and Walnut Streets Philadelphia, PA 19106

Mr. Ralph E. Architzel Resident Reactor Inspector NRC Inspection and Enforcement P. O. Bos 437 Lusby, MD 20657

Mr. Charles B. Brinkman Manager - Washington Nuclear Operations Combustion Engineering, Inc. 4853 Cordell Avenue, Suite A-1 Bethesda, MD 20014

Mr. J. A. Tierman, Manager Nuclear Power Department Calvert Cliffs Nuclear Power Plant Maryland Routes 2 & 4 Lusby, MD 20657

Mr. W. J. Lippold, Supervisor Nuclear Fuel Management Baltimore Gas and Electric Company Calvert Cliffs Nuclear Power'Plant P. O. Box 1475 Baltimore, Maryland 21203

Mr. R. E. Denton, General Supervisor Training & Technical Services Calvert Cliffs Nuclear Power Plant Maryland Routes 2 & 4 Lusby, MD 20657

Administrator, Power Plant Siting Program Energy and Coastal Zone Administration Department of Natural Resources Tawes State Office Building Annapolis, MD 21204

Mr. A. E. Lundvall, Jr. Vice President - Supply Baltimore Gas & Electric Company P. O. Box 1475 Baltimore, Maryland 21203 Arkansas Power & Light Company

- 8 -

cc:

Mr. David C. Trimble Manager, Licensing Arkansas Power & Light Company P. O. Box 551 Little Rock, Arkansas 72203

Mr. James P. O'Hanlon General Manager Arkansas Nuclear One P. O. Box 608 Russellville, Arkansas 72801

Mr. Robert B. Borsum Babcock & Wilcox Nuclear Power Generation Division Suite 420 7735 Old Georgetown Road Bethesda, Maryland 20014

Nick Reynolds c/o DeBevoise & Liberman 1200 Seventeenth Street, N.W. Washington, D. C. 20036

Arkansas Polytechnic College Russellville, Arkansas 72801

Mr. Charles B. Brinkman
Manager - Washington Nuclear
Operations
C-E Power Systems
4853 Cordell Avenue, Suite A-1
Bethesda, Maryland 20014

Mr. William Cavanaugh, III Senior Vice President, Energy Supply Department Arkansas Power & Light Company P. O. Box 551 Little Rock, Arkansas 72203 Honorable Ermil Grant Acting County Judge of Pope County Pope County Courthouse Russellville, Arkansas 72801

U.S. Environmental Protection Agency Region VI Office ATTN: EIS COORDINATOR 1201 Elm Street First International Building Dallas, Texas 75270

Director, Bureau of Environmental Health Services 4815 West Markham Street Little Rock, Arkansas 72201

REQUEST FOR ADDITIONAL INFORMATION THROUGH CE OWNERS GROUP

ON CE HEATED JUNCTION THERMOCOUPLE REACTOR

VESSEL LEVEL MEASUREMENT SYSTEM

- 1. In the discussion of a suitable definition of Inadequate Core Cooling, the definition is constrained to fall within bounds of certain core conditions. Please discuss your approach to defining "inadequate core cooling". What are the limiting conditions for the applicability of the heated junction thermocouple level system?"
- 2. Identify the maximum size break for which the system will still allow the operator to take corrective action under ICC procedures. Please include a discussion of the response capabilities of the heated junction thermocouple instrumentation with respect to the system dynamics. These questions should be answered for a small break, such as 3 inch.
- Bescribe the Phase II test program or programs used in the evaluation of the heated junction thermocouple level measurement system. Please provide representative test results including any anomalous results. Explain the results with respect to expected behavior in operating reactors.
- 4. Discuss the survivability and outputs of the heated junction thermocouple level measurement system during and after a large break LOCA and support with test results.
- 5. Provide an analysis to determine if voiding can

occur in the core of a CE reactor while the upper head is still filled with water. Discuss the extent of voiding which can occur and whether or not it can lead to inadequate core cooling. Please analyze the effect on the core-exit thermocouples should such an event occur and discuss how inadequate core cooling conditions would be determined under these conditions. There is experimental evidence that this can occur, i.e in tests SUT-2 (10% break), SUT-5 (2.5% break), SUT-7 (5% break) at Semi-scale, these effects were observed.

- 6. Discuss the expected response of the heated thermocouple level sensors during a repressurization with the water level below the sensor and the possible effects of condensation on the response of the sensors. Could this sequence of events lead to an indication which would imply that the sensor is covered when it is not? Please provide representative test data.
- 7. Discuss the expected time response of the system with respect to the individual components and as a whole. Identify and discuss the factors which limit the time response.
- B. No specific information has been given for the spacing of the sensors in each heated junction thermocouple instrument string. Are the sensors to be spaced evenly from the core alignment plate to the top of the reactor vessel head? Discuss the spacing chosen. Will the spacing be the same in both instrument strings? If not, how would the decrease in resolution due to the loss of a single sensor affect the ability of the system to detect an approach to inadequate core cooling? (i.e. how is the redundancy of the system affected if dissimilar spacings are used in the two detector strings?)
- 9. Discuss how the core-exit thermocouples might be used to estimate the depth of core uncovery. Also discuss how the rate of loss of coolant may affect the core-exit thermocouple response. Provide an evaluation of the pro's and con's of using the indications of the core-exit thermocouples as a measure of the liquid inventory in the vessel if the coolant level is below the top of the core.
- 10. Discuss the expected behavior of the level sensor shroud surrounded by a high velocity two-phase mixture. In particular, discuss how the system is protected from the effects of high velocity steam entering the bottom ports of the shroud and creating a two phase mixture within the shroud. If restrictions are placed in the bottom of the shroud to block the bottom drain paths, discuss or show experimental evidence that there is still adequate drainage and response time.
- 11. Describe the choice of heater power or range of heater powers to be used with the heated junction thermocouple sensors. Describe the heater power supply or heater power control system. Are separate supplies provided for each sensor heater? Discuss the heater supply system with respect to NUREG 0737 "single failure" criterion. Discuss how uncovered sensors are protected from overheating while covered sensors are suppled with

-2-

sufficient power for a clear indication of uncovery. Nill AC or DC power be used? Discuss the possible effects of leakage, particularly at high temperatures on the level measurement with both AC and DC hea er power. Discuss the possible effects of AC pick-up on the instrumentation system.

- 12. Please describe the on-line test procedures for the heated junction thermocouple sensors. One test mentioned is based on a change in indication observed by varying heater power. Discuss how the operator or person testing the system will decide that the sensors are operating, i.e how much temperature change would be expected for a given power change? Discuss the effectiveness of the test procedures under various reactor conditions, i.e. cold shut-down, full power, and post accident.
- 13. Describe how the operational availability will be determined. What criteria are used? Describe the servicing, testing and calibration programs

The following questions refer to the description of the QSPDS.

- 14. Describe how the processor tests operate to determine that the sensor outputs are within range. How are the ranges selected?
- 15. Describe the display measurement units.
- 15. Describe which parameter or parameters would need to be calculated from the sensor inputs. The description of the QSPDS implies that such a calculation might or might not be required. When would it be required? When would it not be required?
- 17. Specifically, describe the automatic on-line surveillance tests.
- 18. Describe the manual on-line diagnostic capability and procedures.
- 19. Discuss the predetermined setpoint for the heated junction thermocouple signals and how it will be selected.