

REGULARY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8206140005 DOC. DATE: 82/06/09 NOTARIZED: NO DOCKET #
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362
 AUTH. NAME AUTHOR AFFILIATION
 BASKIN, K.P. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 MIRAGLIA, F.J. Licensing Branch 3

SUBJECT: Informs that SNURPS final rept re environ qualification of GEMS transmitters will not be issued until 830101. No anomolies reported in preliminary test results. Present intalled level transmitters qualified to IEEE 323-1971 std.

DISTRIBUTION CODE: A048S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1
 TITLE: Equipment Qualification (OR & PRE-OL)

NOTES: J Hanchett 1cy PDR Documents. ELD Chandler 1cy. 05000361
 NRR Scaletti 1cy.
 J Hanchett 1cy PDR Documents. ELD Chandler 1cy. 05000362
 NRR Scaletti 1cy.

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
	LIC BR #3 BC 12		1 0		ROOD, H.	01	1 1
INTERNAL:	ELD/HDS2	12	1 1		GC	13	1 1
	IE FILE	09	1 1		NRR CALVO, J		1 1
	NRR/DE/EQB	07	2 2		NRR/DL DIR	14	1 1
	NRR/DL/GRAB	06	1 1		NRR/DSI/AEB		1 1
	REG FILE	04	1 1		RGNS		1 1
EXTERNAL:	ACRS	15	10 10		LPDR	03	1 1
	NRC PDR	02	1 1		NSIC	05	1 1
	NTIS	31	1 1				
NOTES:			3 3				

Handwritten mark

Southern California Edison Company



P. O. BOX 800
2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770

K. P. BASKIN
MANAGER OF NUCLEAR ENGINEERING,
SAFETY, AND LICENSING

June 9, 1982

TELEPHONE
(213) 572-1401

Director, Office of Nuclear Reactor Regulation
Attention: Mr. Frank Miraglia, Branch Chief
Licensing Branch No. 3
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Gentlemen:

Subject: Docket Numbers 50-361 and 50-³⁶²~~622~~
San Onofre Nuclear Generating Station
Units 2&3

SCE's letter of November 6, 1981 submitted Revision 2 to the "Environmental Qualification Report per Requirements of NUREG-0588" for San Onofre Units 2&3. Item A4 in Table 5-1 of the report stated that the GEMS transmitter qualification to IEEE 323-1974 standards is being performed in the Standard Nuclear Units Power Plant Systems (SNUPPS) tests. Based on existing test data, it was concluded that the installed GEMS transmitters are qualified for the interim period until the SNUPPS program is complete. The interim period will not exceed the first refueling outage. SCE's intent to show full qualification for installed transmitters is based on similarity to the SNUPPS tested model.

On February 2, 1982, SCE submitted an updated status of outstanding items identified in Tables 5-1 and 5-2 of the above mentioned report. Item 1 of the update estimated the GEMS transmitter qualification program would be completed in mid-1982. This estimate has now been revised by the contractor in charge of the SNUPPS tests.

The current schedule indicates testing will be completed in mid-summer, 1982, with issuance of the final report prior to January 1, 1983. No significant anomalies have been reported in preliminary test results at this time. The present installed level transmitters are qualified to IEEE 323-1971 requirements by separate effects testing as stated in previous submittals.

If you have any questions or comments, please contact me.

Very truly yours,

K.P. Baskin

A049

8206140005 820609
PDR ADDCK 05000361
P PDR