

INSERVICE TESTING PROGRAM PLAN

Revision 3

SAN ONOFRE NUCLEAR GENERATING STATION

Unit 2

September 24, 1982

SOUTHERN CALIFORNIA EDISON COMPANY

8209300161 820924
PDR ADCK 05000361
P PDR

CONTENTS

Enclosed is a change page to the Inservice Testing Program Plan portion of the INSERVICE INSPECTION AND TESTING PROGRAM for the San Onofre Nuclear Generating Station, Unit 2 which was submitted to the NRC by letter dated March 3, 1982 and revised by letter dated June 16, 1982 (Revision 1) and August 2, 1982 (Revision 2).

Change Page

APPENDIX B - Pump Testing Summary

Table 1, Page 1 of 2

Basis

This Revision 3 clarifies that flow rate will not be a test parameter for the LPSI and Containment Spray Pumps by making Appendix B, Table 1, page 1 of 2 consistent with Note 1 of Table 1 which states that these pumps have test paths that are "Fixed Resistance Loops," and flow rate does not have to be measured.