	<i>,</i>		÷						
المستنبية فيسة	REGUL	ATURY	INFOR	MATIO	N DISTRIBUTION	SYSIE	M. GRII	)\$)	54
ADGESSIO	N NBR:8211010	880	Duc.	DATE:	82/10/28 NOT	ARTZED	: NO		DOCKET #
FACIL:5	0=362 San Ono	fre Nu	uclear	Stat	ion, Unit 3, S	outher	n Cal	forn	05000362
AUTH.N	AME AU	THOR /	AFFILI	ATION					
BSKIN,	K,P, Sou	thern	Calif	ornia	Edison Co.				
RECIP.	NAME RE	CIPIEN	NT AFF	ILIAT	ION				
KNIGHTO	N,G,W,	Licens	sing B	ranch	3				
SUBJECT	: Clarities p	ositic	on re	insta	llation of ina	dequat	e core	ē;	
	cooling ins	trumer	ntatio	n Stai	tus of instrum	entati	on des	sign	
	const &⇒sta	ntup s	schedu	1e & p	proposed comple	etion	dates	encl,	
									2
DISTRIB	UTION CODE: B	0015		SRECE	EIVED:LTR EI		SIZ	- *. <u></u>	
1 A. 1. L. K. 6. 1	Licensing sub	mitta	li ⊪da	K/FOAR	Amors & Rela	teg to	rrespo	ongenc	e
NOTES:J	Hanchett 1cv	PDR D	)ocume	nts. F	LD Chandler 1				05000362
NI	RR Scaletti 1	су.							0000000
				;					
	PECTRICAT		C0076	c		- <sup>-</sup>	<b>~^^</b>		• .
	TD CODE/NAM	<u> </u>	LTTD	S ENCI			- LUP) ITTD	ENCL	•
	NRR/DIZADI	<b>E</b>	1			"C	L     K		
	NRR LB3 LA		1	0	ROOD.H.	0.1	1	1.	
			•	•		<b>*</b> *	<b>▲</b>	•	
INTERNAL:	ELD/HDS2		.1.	0	IE FILE	•	1	1	
	IE/DEP EPDS	35	1	1	IE/DEP/EPLB	36	3	3	
	NRR/DE/AEAB		1	0	NRR/DE/CEB	1.1	1	. 1	
	NRR/DE/EQB	13	3	3	NRR/DE/GB	28	2	5	
	NRR/DE/HGEB	30	2	2	NRR/DE/MEB	18	1	1	
	NRR/DE/MTEB	17	1 -	1	NRR/DE/QAB	21	1	1	
	NRK/DE/SAB	24	1	1	NRR/DE/SEB	25	1	1	
	NRR/UHFS/HFEI	540	1-	1	NRR/DHFS/LUI	5 32	1	1	
	NER/UNFS/ULB	24	1	1		220	1	1.	
	NERZÜSTZCER	10	1 1	4	NEE/DOI/AOD	<u>c</u> /	1	4	
	NRR/DSI/ETSB	12	1	1	NPP/DST/LCS	3 16°	1	* 1	
	NRR/DST/PSB	19	1	1	NRR/DST/RAB	22	1	1	
	NRR/DSI/RSB	23	1	î	NRR/DST/LGB	33	1	1	
F	REGFILE	04	ī	<b>1</b>	RGN5		2	2	
	RM70DAMI7MIB		ī	Ō	•		-	-	
EVTEDNAL -	ACDO	<i>h</i> •		4			· .		
LA PERNALI	DMB/DSS /AMM	41	<b>9</b> 1	0	EEMALDED NT	1 20	1	° ∔• •	· .
	LPDR	03	. ∔ 1.	1	NRC PDP	02	1	1 · ·	
	NSIC	05	1	- 1	NTTS	V fa	+ 1	+ 1	
	··			-	33 <b>F da W</b>		•	*	
NOTES:			3	3					

.

ENCL

58

52

## Southern California Edison Company

P. O. BOX 800 2244 WALNUT GROVE AVENUE ROSEMEAD. CALIFORNIA 91770

K. P. BASKIN MANAGER OF NUCLEAR ENGINEERING, SAFETY, AND LICENSING

October 28, 1982

Director, Office of Nuclear Reactor Regulation Attention: G. W. Knighton, Branch Chief Licensing Branch No. 3 U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Gentlemen:

- Subject: Docket No. 50-362 San Onofre Nuclear Generating Station Unit 3
- References: A. NUREG-0712, Supplement No. 1, February 1981, Section 22.2, II.F.2
  - B. NUREG-0712, Supplement No. 4, January 1982, Section 22.2, II.F.2
  - C. Summary of Meeting to Discuss Inadequate Core Cooling (ICC) Instrumentation by Harry Rood, dated August 11, 1982
  - D. Letter; K. P. Baskin, SCE to Janis D. Kerrigan, NRC, dated October 4, 1982
  - E. Letter; K. P. Baskin, SCE to Frank Miraglia, NRC, dated May 13, 1982

The purpose of this letter is to clarify the position of Southern California Edison Company (SCE) with regard to the installation of ICC Instrumentation in San Onofre Nuclear Generating Station, Unit 3 (SONGS 3).

Reference C provided a summary of the status of the ICC Instrumentation design and the present construction and startup schedule for Unit 3. Reference D provided SCE's proposed completion dates for ICC Instrumentation for SONGS 3. All of the items [(19).0.1, (19).0.2, (19).0.3and (19).0.5] are proposed for completion by fuel load of Unit 3 except the Safety Parameter Display System (SPDS) [(19).0.4], which is proposed for completion prior to startup following the first refueling outage.



TELEPHONE (213) 572-1401

2001

## Mr. G. W. Knighton

October 28, 1982

The SPDS function for SONGS 3 is achieved through two components: primary display is via the Critical Function Monitoring System (CFMS) and the seismically qualified backup display is via the Qualified Safety Parameter Display System (QSPDS). The equipment for the CFMS and QSPDS displays will be installed by fuel load of SONGS 3, and will display the variables associated with the ICC Instrumentation. This same equipment will be used to display both the SPDS variables and the Regulatory Guide 1.97 variables per Reference E. However, the SPDS and Regulatory Guide 1.97 inputs and associated software will not be implemented until first refueling of SONGS 3.

Table 1, enclosed, summarizes the presently scheduled implementation dates for the various functions to be achieved using the CFMS and QSPDS for both SONGS 2&3. As noted in Table 1 and previously indicated in the subject references, the ICC Instrumentation can be considered operational by fuel load for SONGS 3. However, the other functions of the system (SPDS and Regulatory Guide 1.97) to be achieved through additional inputs to the CFMS and the QSPDS will be implemented prior to startup following the first refueling outage.

If you have any questions concerning the above information, please call me.

Very truly yours,

WP Baskin

Enclosure

## TABLE 1 DISPLAY INSTRUMENTATION FOR ICC, SPDS AND R.G. 1.97 FUNCTIONS

é

.. .

			IMPLEMENTATION D	ATES SONGS 3		
I.	CFMS	(primary display)				
	Α.	NUREG 0737 Phase I*	Existing	Fuel load		
	Β.	ICC Instrumentation Phase II**	lst refueling	Fuel load		
	С.	Additional SPDS and other inputs Phase III	lst refueling	lst refueling		
	D.	R.G. 1.97 Phase IV***	lst refueling	lst refueling		
II.	QSPD:	<u>S</u> (safety grade backup display)				
	Α.	ICC Instrumentation Phase II**	1st refueling	Fuel load		
	Β.	HJTC installed	1st refueling	Fuel load		
	С.	HJTC operational	lst refueling	lst cycle verification and validation		
	D.	Additional SPDS inputs	1st refueling	lst refueling		
	E.	R.G. 1.97 Phase IV***	lst refueling	lst refueling		
*	NURE	G 0737 item III.A.1 Phase I consis	sts of 322 inputs to (	CFMS.		
**	Phase	e II is the inputs and software ch	nanges for: (a) SMM (	upgrade,		
	(b) CETs upgrade and (c) RVLMS installed (verification and validation					
	durir	ng 1st cycle).				
***	Regul	atory Guide 1.97 Phase IV is the	additional inputs to	the QSPDS and		
	CFMS	per Reference E.				
	SMM	= Subcooled Margin Monitor				
	CETs	= Core Exit Thermocouples				
	HJTC	= Heated Junction Thermocouples				
	RVLMS	5 = Reactor Vessel Level Monitorin	g System			