

November 12, 2013

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555

**SUBJECT:** Entergy Nuclear Operations, Inc.  
Pilgrim Nuclear Power Station  
Docket No.: 50-293  
License No.: DPR-35

Revised Submittal Schedule for Supplement to the LER 2013-002-00,  
SRV-3B Safety Relief Valve Declared Inoperable Due to Leakage and  
Setpoint Drift

- REFERENCE:**
1. LER 2013-002-00, "SRV-3B Safety Relief valve Declared Inoperable Due to Leakage and Setpoint Drift", dated March 31, 2013
  2. 10 CFR Part 21 Report, "Notification of a Defect, Bellows Failure", Curtis Wright Flow Control Company (Target Rock) Letter NID # 13307, dated June 17, 2013

**LETTER NUMBER:** 2.13.089

Dear Sir or Madam:

Licensee Event Report (LER) 2013-002-00, "SRV-3B Safety Relief Valve Declared Inoperable Due to Leakage and Setpoint Drift" was submitted on March 31, 2013 (Reference 1); with a target schedule of September 30, 2013 to submit a Supplement to the LER, after completing the root cause analysis.

Since then the vendor (Target Rock) has issued a 10 CFR Part 21 Notification, (Reference 2) confirming defects in safety relief valve bellows. Entergy is incorporating the information related to the reported defect into the root cause analysis. Due to the recent refueling outage, emergent plant events, and vendor 10 CFR, Part 21 Notification, Pilgrim resources were diverted to address the emergent work activities. As such, the review and approval of the SRV-3B root cause incorporating the vendor Part 21 Notification and the lessons learned from the events is taking longer time than expected. Accordingly, the LER Supplement is expected to be submitted by February 14, 2014.

The revised submittal schedule was discussed with the NRC/NRR Project Manager.


This letter contains no commitments.

IE22  
MRD



Please do not hesitate to contact me at (508) 830-8403, if there are any questions.

Sincerely,



Joseph R. Lynch,  
Manager, Pilgrim Licensing

cc: Mr. William M. Dean  
Regional Administrator, Region 1  
U.S. Nuclear Regulatory Commission  
2100 Renaissance Blvd., Suite 100  
King of Prussia, PA 19406-2713

Ms. Nadiyah Morgan, Project Manager  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
One White Flint North  
Mail Stop O-8-C2A  
11555 Rockville Pike  
Rockville, MD. 20852-2738

INPO Records  
700 Galleria Parkway  
Atlanta, GA 30399-5957

USNRC Senior Resident Inspector  
Pilgrim Nuclear Power Station