




**Attachment 2 to GNRO-2013/00088**

**JC -Q1B21-N678-1 Rev. 2 "Reactor Steam Dome Pressure Scram Setpoint"**

<input type="checkbox"/> ANO-1	<input type="checkbox"/> ANO-2	<input checked="" type="checkbox"/> GGNS	<input type="checkbox"/> IP-2	<input type="checkbox"/> IP-3	<input type="checkbox"/> PLP
<input type="checkbox"/> JAF	<input type="checkbox"/> PNPS	<input type="checkbox"/> RBS	<input type="checkbox"/> VY	<input type="checkbox"/> W3	
<input type="checkbox"/> NP-GGNS-3	<input type="checkbox"/> NP-RBS-3				
<b>CALCULATION COVER PAGE</b>		(1) EC # <u>39554</u>	(2) Page 1 of <u>33</u>		
(3) Design Basis Calc. <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		(4) <input checked="" type="checkbox"/> CALCULATION		<input type="checkbox"/> EC Markup	
(5) Calculation No: JC-Q1B21-N678-1				(6) Revision: 002	
(7) Title: Technical Specification Setpoint Determination for Reactor Dome Pressure Scram				(8) Editorial <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
(9) System(s): B21		(10) Review Org (Department): NPE (I&C Design)			
(11) Safety Class:		(12) Component/Equipment/Structure Type/Number:			
<input checked="" type="checkbox"/> Safety / Quality Related		1B21N078A		1B21N678A	
<input type="checkbox"/> Augmented Quality Program		1B21N078B		1B21N678B	
<input type="checkbox"/> Non-Safety Related		1B21N078C		1B21N678C	
(13) Document Type: J05.02		1B21N078D		1B21N678D	
(14) Keywords (Description/Topical Codes): setpoint, uncertainty					
<b>REVIEWS</b>					
(15) Name/Signature/Date		(16) Name/Signature/Date		(17) Name/Signature/Date	
<u>Mary Coffaro /</u>  10/8/13 Responsible Engineer		<u>Robin Smith /</u>  10/8/13 <input checked="" type="checkbox"/> Design Verifier <input type="checkbox"/> Reviewer <input checked="" type="checkbox"/> Comments Attached		_____ /  Supervisor/Approval  <input type="checkbox"/> Comments Attached	



ENTERGY



# CALCULATION SHEET

SHEET 2 OF 33


CALCULATION NO. JC-Q1B21-N678-1

REV. 002

Revision	Record of Revision
0	Original issue.
1	Prepared in response to CR-GGN-2004-0038 & CR 2000-0100.
2	Extended calibration interval to 24 months, incorporated results of drift calculations JC-Q1111-09020. Updated transmitters' environmental zones and parameters per current revision of referenced documents. Revised trip unit calibration interval to 92 days to agree with Technical Specifications. Updated MTE, SE and bias terms to be consistent with current revision of JS09. Updated references and performed general maintenance. Added TSTF-493 Section 6.0.



ENTERGY



# CALCULATION SHEET

SHEET 3 OF 33

CALCULATION NO. JC-Q1B21-N678-1

REV. 002

CALCULATION  
REFERENCE SHEET

CALCULATION NO: JC-Q1B21-N678-1  
REVISION: 002

**I. EC Markups Incorporated NONE**

II. Relationships:		Sht	Rev	Input Doc	Output Doc	Impact Y/N	Tracking No.
1.	JS09	0	001	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
2.	E100.0	0	007	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
3.	06-IC-1B21-Q-1002	--	101	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
4.	06-IC-1B21-R-0001	--	105	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
5.	MS02	0	051	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
6.	ABD01	0	000	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
7.	J1281L	021A	000	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
8.	J1281L	021B	000	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
9.	J1281L	021C	000	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
10.	J1281L	021D	000	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
11.	M1077B	0	034	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
12.	865E520	002	008	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
13.	865E521	002	007	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
14.	164C5150	001	018	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
15.	164C5150	002	017	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
16.	164C5150	003	018	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
17.	184C4571	001	009	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
18.	J1507A	0	001	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
19.	J1507D	0	001	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
20.	460000047	0	300	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
21.	J0400	0	018	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
22.	J0401	0	014	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
23.	CR-GGN-1999-01828	--	0	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
24.	JC-Q1111-09020	0	000	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
25.	A0552	0	018	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
26.	368X543BA	0	044	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
27.	368X559BA	0	039	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
28.	SDC-B21	0	003	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
29.	22A4622	0	007	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
30.	0200-047-0128	0	000	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
31.	A0014	0	009	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
32.	17-S-06-5	--	010	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
33.	22A3856AA	0	012	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
34.	460000944	0	300	<input checked="" type="checkbox"/>	<input type="checkbox"/>		



ENTERGY



# CALCULATION SHEET

SHEET 4 OF 33

CALCULATION NO. JC-Q1B21-N678-1

REV. 002

II. Relationships:	Sht	Rev	Input Doc	Output Doc	Impact Y/N	Tracking No.
35. EAR-E90-0158	--	000	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
36. A0012	0	015	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
37. A0120	0	016	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
38. J301.0-QS-27.0-15-0	--	0	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
39. EC-Q1000-86001	0	003	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
40. 460001972	0	300	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
41. NEDC31336	--	0	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
42. PERR91-6068	--	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
43. 865E522	002	006	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
44. 865E523	002	006	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
45. J1507B	0	001	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
46. J1507C	0	001	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
47. 368X544BA	0	025	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
48. 368X558BA	0	024	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
49. GEXI2000-00134	--	0	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
50.						

### III. CROSS REFERENCES:

1. Technical Specification 3.4.12
2. Asset Suite Equipment Data Base (EDB)
3. "Handbook of Chemistry and Physics, 57th Edition, 1976-1977", published by the Chemical Rubber Co.
4. Tech. Spec./TRM Tables 3.3.1.1-1
5. UFSAR Section 15.2.1.2.2

### IV. SOFTWARE USED:

Title: N/A Version/Release: \_\_\_\_\_ Disk/CD No. \_\_\_\_\_

### V. DISK/CDS INCLUDED:


Title: N/A Version/Release \_\_\_\_\_ Disk/CD No. \_\_\_\_\_

### VI. OTHER CHANGES:

Related references removed from the calculation: CR-GGN-2000-0100, 169C8394, EAR-E90-0158, CR-GGN-1999-01828 CA9, VMN 460000944



ENERGY



# CALCULATION SHEET

SHEET 5 OF 33

CALCULATION NO. JC-Q1B21-N678-1

REV. 002

## TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
1.0 Purpose and Description .....	6
2.0 References.....	7
3.0 Given .....	10
4.0 Assumptions.....	15
5.0 Calculation.....	18
6.0 TSTF Calculations.....	25
7.0 Conclusion.....	27

### Attachments

- |                            |           |
|----------------------------|-----------|
| 1. Design Verification     | (5 pages) |
| 2. Owner's Review Comments | (1 page)  |



ENERGY



# CALCULATION SHEET

SHEET 6 OF 33

CALCULATION NO. JC-Q1B21-N678-1

REV. 002

## 1.0 PURPOSE AND DESCRIPTION

### 1.1. Purpose

The purpose of this calculation is to verify the allowable value and nominal trip setpoint for the Reactor Dome Pressure Scram in the Technical Specifications.

### 1.2. Setpoint Bases

#### 1.2.1. Loop Descriptions

This loop consists of the instruments 1B21-PT-N078A/B/C/D and 1B21-PIS-N678A/B/C/D.

#### 1.2.2. Design Bases

Pressure sensors are furnished which, in conjunction with the Reactor Protection System, scram the reactor if reactor pressure increases, encroaching on the required margin of safety established for safety/relief valve setpoints. (Ref. 2.2.22, 2.2.23, 2.2.27)

### 1.3. Design Bases Event(s)

1.3.1. The DBE for the high dome pressure scram setpoint is the closure of the MSIV's with pressure scram. The normal scram path associated with MSIV closure and High neutron flux are assumed to fail. (Ref. 2.2.45)

1.3.2. When the reactor is operating at less than full power, the high neutron flux scram may not be initiated. Under these conditions, the high dome pressure scram is credited. (Ref. 2.2.29)

1.3.3. Per Reference 2.2.39, the components in these loops are seismic category 1 instruments. Per Reference 2.1.1, seismic effects are not required to be considered for setpoint loops because the reactor will be shutdown following a seismic event. Therefore seismic effects will not be considered for the subject loops.

### 1.4. Analytical and Technical Specification Limits

Analytical Limit (PSIG)	Allowable Value (PSIG)	Nominal Trip Setpoint (PSIG)
1095.0	1079.7	1064.7

Ref. 2.2.1, 2.2.28, 2.2.33



ENTERGY



# CALCULATION SHEET

SHEET 7 OF 33

CALCULATION NO. JC-Q1B21-N678-1 REV. 002

## 2.0 REFERENCES

### 2.1. Relationships

- 2.1.1. JS09, Setpoint Methodology
- 2.1.2. Environmental Parameters Specification No. E100.0
- 2.1.3. Surveillance Procedure 06-IC-1B21-Q-1002
- 2.1.4. Surveillance Procedure 06-IC-1B21-R-0001
- 2.1.5. MS02

### 2.2. Cross References

- 2.2.1. ABD01
- 2.2.2. Setpoint Control Loop Diagram J1281L-021A
- 2.2.3. Setpoint Control Loop Diagram J1281L-021B
- 2.2.4. Setpoint Control Loop Diagram J1281L-021C
- 2.2.5. Setpoint Control Loop Diagram J1281L-021D
- 2.2.6. M1077B
- 2.2.7. 865E520-002
- 2.2.8. 865E521-002
- 2.2.9. PPD 164C5150-001, 164C5150-002, 164C5150-003
- 2.2.10. PPD 184C4571-001
- 2.2.11. J1507A
- 2.2.12. J1507D
- 2.2.13. Rosemount Instruction Manual 4247-1 (Vendor Man. Num. 460000047)
- 2.2.14. Location Dwg. J0400
- 2.2.15. Location Dwg. J0401
- 2.2.16. Not Used
- 2.2.17. JC-Q1111-09020, Drift Calculation for Rosemount Range Code 9 Gage Pressure Transmitters





ENTERGY



## CALCULATION SHEET

SHEET 8 OF 33

CALCULATION NO. JC-Q1B21-N678-1

REV. 002

2.2.18. GEXI2000-00134, Statistical Variation Associated With Published Performance Variable

2.2.19. Radiation Zones A0552

2.2.20. 368X543BA

2.2.21. 368X559BA

2.2.22. SDC-B21

2.2.23. 22A4622

2.2.24. Calculation 0200-047-0128

2.2.25. A0014

2.2.26. Not Used

2.2.27. 17-S-06-5

2.2.28. 22A3856AA

2.2.29. FSAR Section 15.2.1.2.2

2.2.30. Not Used

2.2.31. Not Used

2.2.32. Not Used

2.2.33. Tech. Spec./TRM Tables 3.3.1.1-1

2.2.34. Not Used

2.2.35. A0012

2.2.36. A0120

2.2.37. J301.0-QS-27.0-15-0, Result Of Low Radiation Dose Rate & LO Level LOCA Evaluation For Model 1153 Series B Rosemount Report D8600063 Revision A

2.2.38. EC-Q1000-86001

2.2.39. Asset Suite Equipment Data Base (EDB)

2.2.40. VMN 460001972

2.2.41. "Handbook of Chemistry and Physics, 57th Edition, 1976-1977", published by the Chemical Rubber Co.



ENTERGY



## CALCULATION SHEET

SHEET 9 OF 33  
REV. 002

CALCULATION NO. JC-Q1B21-N678-1

2.2.42. Technical Specification 3.4.12

2.2.43. Not Used

2.2.44. Not Used

2.2.45. NEDC31336

2.2.46. PERR91-6068

2.2.47. Not Used

2.2.48. Not Used

2.2.49. 865E522-002

2.2.50. 865E523-002

2.2.51. J1507B

2.2.52. J1507C

2.2.53. 368X544BA

2.2.54. 368X558BA



ENTERGY



# CALCULATION SHEET


SHEET 10 OF 33

CALCULATION NO. JC-Q1B21-N678-1

REV. 002

## 3.0 GIVEN

### 3.1. Loop Block Diagram



PT: 1B21-PT-N078A/B/C/D Ref. 2.2.2, 2.2.3, 2.2.4, 2.2.5

PIS: 1B21-PIS-N678A/B/C/D Ref. 2.2.2, 2.2.3, 2.2.4, 2.2.5

PS: 1B21-JY-K613A/B/C/D Ref. 2.2.2, 2.2.3, 2.2.4, 2.2.5

3.2. Primary Element See Assumption 4.7

3.3. Instrument Tubing See Assumption 4.7

### 3.4. Environmental Data


#### 3.4.1. Transmitters

<u>Instrument</u>	<u>Room</u>	<u>Panel</u>	<u>Reference</u>
1B21-PT-N078A	Room 1A313	1H22-P004	2.2.2, 2.2.11, 2.2.35
1B21-PT-N078B	Room 1A311	1H22-P027	2.2.3, 2.2.12, 2.2.35
1B21-PT-N078C	Room 1A313	1H22-P005	2.2.4, 2.2.35, 2.2.52
1B21-PT-N078D	Room 1A311	1H22-P026	2.2.5, 2.2.35, 2.2.51

<u>Description</u>	<u>Data</u>	<u>Reference</u>
--------------------	-------------	------------------

Environmental Conditions for Instruments 1B21-PT-N078A/C in room 1A313:

Normal:	Zone N-068	2.1.2
Pressure	-1.0 to -0.10 in. wg.	
Expected Temperature	90°F	
Temperature Range	60°F to 105°F	
Humidity	20% to 90% R.H.	
Dose Rate	0.011 Rad/Hr.	
Radiation (Gamma) TID	3.1 X 10 <sup>3</sup> Rads	



# CALCULATION SHEET

SHEET 11 OF 33

CALCULATION NO. JC-Q1B21-N678-1 REV. 002

Accident*:	Zone A-016	2.1.2
Pressure	Curve Set 2	
Temperature	Curve Set 2	
Humidity	100% R.H.	
Radiation (Gamma) TID	5.6 X 10 <sup>6</sup> Rads (Gamma)	
	2.84 X 10 <sup>8</sup> Rads (Beta)	

**\* See Assumption 4.4**

Seismic Conditions: Not Required Section 1.3.3

<u>Description</u>	<u>Data</u>	<u>Reference</u>
Environmental Conditions for Instruments 1B21-PT-N078B/D in room 1A311		
Normal:	Zone N-069	2.1.2
Pressure	-1.0 to -0.10 in. wg.	
Expected Temperature	90°F	
Temperature Range	60°F to 105°F	
Humidity	20% to 90% R.H.	
Dose Rate	0.026 Rad/Hr.	
Radiation (Gamma) TID	6.3 X 10 <sup>3</sup> Rads	

Accident*:	Zone A-016	2.1.2
Pressure	Curve Set 2	
Temperature	Curve Set 2	
Humidity	100% R.H.	
Radiation (Gamma) TID	5.6 X 10 <sup>6</sup> Rads (Gamma)	
	2.84 X 10 <sup>8</sup> Rads (Beta)	

**\* See Assumption 4.4**


Seismic Conditions: Not Required Section 1.3.3

### 3.4.2. Trip Units & Power Supplies

<u>Instrument</u>	<u>Room</u>	<u>Panel</u>
1B21-PIS-N678A	0C703 (Ref. 2.2.2, 2.2.15, 2.2.25)	1H13-P691
1B21-PIS-N678B	0C504 (Ref. 2.2.3, 2.2.14, 2.2.36)	1H13-P692
1B21-PIS-N678C	0C703 (Ref. 2.2.4, 2.2.15, 2.2.25)	1H13-P693
1B21-PIS-N678D	0C504 (Ref. 2.2.5, 2.2.14, 2.2.36)	1H13-P694
1B21K613A	0C703 (Ref. 2.2.2, 2.2.15, 2.2.25)	1H13-P691
1B21K613B	0C504 (Ref. 2.2.3, 2.2.14, 2.2.36)	1H13-P692



ENTERGY



# CALCULATION SHEET

SHEET 12 OF 33

CALCULATION NO. JC-Q1B21-N678-1 REV. 002

1B21K613C 0C703 (Ref. 2.2.4, 2.2.15, 2.2.25) 1H13-P693  
 1B21K613D 0C504 (Ref. 2.2.5, 2.2.14, 2.2.36) 1H13-P694

<u>Description</u>	<u>Data</u>	<u>Reference</u>
Normal:	Zone N-028	2.1.2
Temperature	69-90°F	
Pressure	+0.1 to 1.0 in wg.	
Humidity	20% to 50% RH	
Radiation (Gamma) (see note below)	1.75E2 rads (40 yr TID)	

Note: Gamma Radiation Dose =  $\frac{0.5 \text{ m Rad}}{\text{hour}} \times \frac{365.25 \text{ days}}{\text{year}} \times \frac{24 \text{ hours}}{\text{day}} \times 40 \text{ years} = 1.75E2 \text{ Rads}$

Accident Environment: Rooms 0C504, 0C703 Same as Normal Ref. 2.1.2

Seismic Conditions: Not Required Section 1.3.3


### 3.5. Vendor Data

#### 3.5.1. Transmitter Data

<u>Description</u>	<u>Data</u>	<u>Reference</u>
Tag Number	1B21-PT-N078A,B,C,D	2.2.2, 2.2.3, 2.2.4, 2.2.5
Manufacturer:	Rosemount	2.2.20, 2.2.21
Model Number:	1153GD9PC	2.2.53, 2.2.54
Span	1500 PSIG / 4 to 20 mAdc	2.1.4, 2.2.39
Upper Range Limit (URL):	3000 PSIG	2.2.40
Calibrated Span	15 to 1515 PSIG / 4 to 20 mAdc	2.1.4, 2.2.39
Reference Accuracy:	± 0.25% span (3σ)	2.2.40, 2.2.18
Drift:	± 0.403% Span for 30 months	2.2.17
Power Supply:	<0.005% span per volt (3σ)	2.2.40, 2.2.18
Temperature Effect	± (0.75% URL + 0.5% Span)*ΔT/100°F (3σ)	2.2.40, 2.2.18
Humidity:	N/A (0% to 100% RH)	2.2.40
Radiation:	± 6.0% URL during and after Exposure to 5.19 x 10 <sup>7</sup> Rads TID (γ)	2.2.40



ENTERGY



# CALCULATION SHEET

SHEET 13 OF 33

CALCULATION NO. JC-Q1B21-N678-1 REV. 002

Seismic Effect:	SE = ± 0.5% URL Seismic Effects (ZPA of 7 g's)	2.2.40
Static Pressure Effect	N/A for Gauge pressure device	2.2.40
Overpressure:	Overpressure effects are not applicable	4.13
Radiation Drift:	Radiation Drift effect is not applicable.	2.2.19, 2.2.38, 4.3

### 3.5.2. Master Trip Unit Data

<u>Description</u>	<u>Data</u>	<u>Reference</u>
Tag Numbers	1B21-PIS-N678A/B/C/D	2.2.2, 2.2.3, 2.2.4, 2.2.5
Manufacturer	Rosemount	2.2.7, 2.2.8, 2.2.9, 2.2.49, 2.2.50
Model	510 DU  OR 710DUOTT	2.2.7, 2.2.8, 2.2.9, 2.2.49, 2.2.50 Assumption 4.12
Repeatability*:	± 0.20% span	2.2.13
* Repeatability based on Adverse Operating Condition and Normal Environment		
Drift:	N/A	Assumption 4.11
Span	1500 PSIG	2.1.3, 2.2.9, 2.2.39

Humidity effects, power supply effects, temperature effects, and drift are included in the reference accuracy.

The trip units are located in a non harsh environment, therefore radiation and radiation drift effects are not applicable.

Static pressure effect and overpressure effect are not applicable to electronic instrumentation.

### 3.5.3. Power Supplies

<u>Description</u>	<u>Data</u>	<u>Reference</u>
Power Supply Tag Nos.	1B21K613A 1B21K613B 1B21K613C 1B21K613D	2.2.2, 2.2.7 2.2.3, 2.2.8 2.2.4, 2.2.49 2.2.5, 2.2.50



ENERGY



# CALCULATION SHEET

SHEET 14 OF 33

CALCULATION NO. JC-Q1B21-N678-1

REV. 002

Manufacturer	GE	2.2.7, 2.2.8, 2.2.10, 2.2.39, 2.2.49, 2.2.50
Model	184C4571P008	2.2.7, 2.2.8, 2.2.10, 2.2.39, 2.2.49, 2.2.50
Power Supply Nominal	24.0 volts	2.2.7, 2.2.8, 2.2.10, 2.2.39, 2.2.49, 2.2.50
Range	23.0 to 28.0 Vdc	2.2.2, 2.2.3, 2.2.4, 2.2.5, 2.2.10
* See Assumption 4.9		



# CALCULATION SHEET

SHEET 15 OF 33

CALCULATION NO. JC-Q1B21-N678-1

REV. 002


## 4.0 ASSUMPTIONS

- 4.1. All uncertainty values are assumed to be 2 sigma values unless specified otherwise.
- 4.2. The M&TE values are assumed to be less than or equal to the reference accuracy of the individual devices unless the actual M&TE values are greater, in which case the more conservative value will be used.
- 4.3. Because of the low dose rate associated with the normal environment for these locations (Total 40 Yr TID <  $10^4$ ), they are not considered "Harsh Conditions" and radiation drift will not be considered. (Ref. 2.2.38)
- 4.4. Environmental Uncertainties for the transmitters are assumed to be determined by normal environmental conditions. The transmitter is not required to act under accident (LOCA) conditions, since this condition would lead to depressurization of the Reactor Vessel and prevent loop trip actuation. Containment pressure and temperature are assumed to remain at their normal operating values until the trip occurs.
- 4.5. Not Used
- 4.6. Not Used
- 4.7. The over pressure analysis takes into account the pressure difference between the RPV bottom and the reactor steam dome pressure when establishing the high pressure scram setpoint. Therefore, no additional process measurement accuracy allowance is needed for the pressure difference between the RPV bottom and the steam dome. The process measurement accuracy allowance due to instrument line temperature is estimated to be less than one inch of water. Further, no primary element exists within the loop which could produce a primary element uncertainty; therefore no primary element uncertainty need be considered. (Ref. 2.2.45)
- 4.8. The transmitter is not required to function in LOCA accident conditions. Any exposure to an elevated temperature for a short period of time is assumed to produce a negligible insulation resistance (IR) change. In addition, any insulation resistance losses will produce a positive bias which will tend to reduce the calculated uncertainty. (Ref. 2.2.24) Therefore it is conservative to assume IR losses are negligible.
- 4.9. The loop power supply is a 24VDC safety related power supply. (Ref. 2.2.2, 2.2.3, 2.2.4, 2.2.5, 2.2.10). The power supply has a full load to no load variance of 23 VDC to 28 VDC. The power supply is assumed to supply a nominal voltage of 24 VDC. Therefore, the maximum voltage variance will occur from the nominal voltage setting condition to a no load condition. The voltage variance used in the calculation will be 4.5 volts. This allows for the 4 volt change from the nominal condition to the no load condition and a 0.5 volt nominal voltage uncertainty to account for voltage ripple effect.
- 4.10. Not Used





ENTERGY



# CALCULATION SHEET

SHEET 16 OF 33

CALCULATION NO. JC-Q1B21-N678-1

REV. 002

- 4.11. The accuracy of the Rosemount trip units ( $\pm 0.20\%$  span) is valid for six months (Ref. 2.2.13). A calibration interval of 92 days plus a 25% grace period (115 days) will be assumed for the trip units (Ref. 2.2.33). Therefore, drift is included in reference accuracy.
- 4.12. The model number of the trip unit is not specified on the PPD 164C5150 (Ref. 2.2.9). It is currently a 510DU2 (except for 1B21N678A which is identified in the EDB as a 710DU0TT) based on the EDB (Ref. 2.2.39) and PERR91-6068 (Ref. 2.2.46). However, this PERR authorized replacement of the obsolete 510DU2 with the 710DU0TT. The accuracy specifications of the 510DU can still be assumed after the replacement since the 710DU has better accuracy specifications.
- 4.13. Overpressure effects are not applicable because the maximum pressure that the transmitters are subjected to is a pressure of 1100 PSIG (Ref. 2.1.5, 2.2.6), which is below the URL of the transmitter (Ref. 2.2.40).
- 4.14. A 24 month refuel cycle will be assumed for the transmitters in this calculation. Applying +25% margin (per Reference 2.1.1) yields a calibration interval of 30 months.
- 4.15. **MTE** Per Reference 2.1.1, the M&TE error is normally considered equivalent to the reference accuracy of the trip unit. Per Reference 2.1.4, a Rosemount 710DU Readout Assembly ( $\pm 0.01$  mAdc, per Reference 2.2.13) is used to calibrate the Rosemount Trip Unit. The actual M&TE error ( $MTE_2$ ) for the Rosemount Trip Unit is  $\pm 0.01$  mAdc, which is equivalent to  $\pm 0.9375$  PSIG

Output Range = 4 to 20 mAdc    Input Range = 0 to 1500 PSIG

$$\frac{1500 \text{ PSIG}}{16 \text{ mAdc}} = \frac{93.75 \text{ PSIG}}{\text{mAdc}} \quad \frac{93.75 \text{ PSIG}}{\text{mAdc}} \times 0.01 \text{ mAdc} = 0.9375 \text{ PSI}$$

This value is less than the equivalent trip unit reference accuracy of  $\pm 0.20\%$  Span = 3.0 PSIG

However, Per Reference 2.1.3 and 2.2.39, the trip unit is calibrated to  $\pm 0.04$  mAdc which is equivalent to:

$$\frac{1500 \text{ PSIG}}{16 \text{ mAdc}} = \frac{93.75 \text{ PSIG}}{\text{mAdc}} \quad \frac{93.75 \text{ PSIG}}{\text{mAdc}} \times 0.04 \text{ mAdc} = 3.75 \text{ PSI}$$

This value is greater than the equivalent trip unit reference accuracy of  $\pm 0.20\%$  Span = 3.00 PSIG and the more conservative of the three values will be used.


### MTE for Trip Unit = 3.75 PSIG

Per Reference 2.1.4, a Heise pressure gauge (0-2000 PSIG) or equivalent (accuracy  $\pm 3.75$  PSIG) and a Fluke model 45 Digital Volt Meter (accuracy  $\pm 0.04$  mAdc) are used to calibrate the transmitter. The setting tolerance is specified as  $\pm 0.04$  mAdc.

DVM Accuracy:                      Output Range = 4 to 20 mAdc



ENTERGY



# CALCULATION SHEET

SHEET 17 OF 33

CALCULATION NO. JC-Q1B21-N678-1

REV. 002

Input Range = 15 to 1515 PSIG = 1500 PSIG

$$\frac{1500 \text{ PSIG}}{16 \text{ mAdc}} = \frac{93.75 \text{ PSIG}}{\text{mAdc}} \quad \frac{93.75 \text{ PSIG}}{\text{mAdc}} \times 0.04 \text{ mAdc} = 3.75 \text{ PSI}$$


SRSS of M&TE Terms ( $MTE_1$ ) for transmitter:  $MTE = \{(3.75)^2 + (3.75)^2\}^{1/2} = 5.30$   
PSIG

This value is greater than the equivalent transmitter unit reference accuracy of  $\pm(2/3)*0.25\%$  Span = 2.50 PSIG and setting tolerance. The most conservative of the three values will be used.

**MTE for Transmitter = 5.30 PSIG**



ENERGY



# CALCULATION SHEET

SHEET 18 OF 33CALCULATION NO. JC-Q1B21-N678-1REV. 002

## 5.0 CALCULATION

### 5.1. Definitions

#### 5.1.1. **Nomenclature**

The nomenclature to be used in this calculation section will be explained.

#### 5.1.2. **Worst Case Calculation**

A single calculation will be done for the worst case equipment in the worst case environment. The equipment and environment will be detailed.

#### 5.1.3. **Device Uncertainties**

For each module, the uncertainty terms applicable to this application will be specified and combined into the following module errors:

- RA – reference accuracy
- L – negative bias uncertainty
- M – positive bias uncertainty
- MTE – measurement and test equipment inaccuracies
- D – drift

#### 5.1.4. **Loop Uncertainties**

The random and bias components of:

- PE – errors associated with the Primary Element
- PM – errors in Process Measurement, and
- IR – errors due to degradation in Insulation Resistance

will be quantified, the loop error equation given, and the device and loop uncertainties combined to produce:

- $A_L$  – SRSS of all device random uncertainties except drift
- $L_L$  – The sum of all negative bias uncertainties
- $M_L$  – The sum of all positive bias uncertainties
- $C_L$  – SRSS of all measurement and test equipment inaccuracies used for calibration
- $D_L$  – SRSS of all drifts
- $LU$  –  $SRSS(A_L, C_L, PE, PM) + IR - L_L + M_L$

#### 5.1.5. **Total Loop Uncertainty**

The total loop uncertainty will be calculated using the Reference 2.1.1 equation:

$$TLU = LU + D_L$$



# CALCULATION SHEET

SHEET 19 OF 33

CALCULATION NO. JC-Q1B21-N678-1

REV. 002

## 5.1.6. Allowable Value

The Allowable Value will be calculated using the Reference 2.1.1 equation:

$$AV = AL \pm LU$$

## 5.1.7. Nominal Trip Setpoint

The nominal trip setpoint will be calculated using the Reference 2.1.1 equation:

$$NTSP = AL \pm TLU$$

## 5.2. Device Uncertainties

### 5.2.1. Transmitter Uncertainties

Using the environmental and vendor data from Section 3.4 & 3.5:

$$URL = 3000 \text{ PSIG}$$

$$SPAN = 1500 \text{ PSIG}$$

$$\begin{aligned} RA_1 &= \pm 0.25\% \text{ span } (3\sigma) \\ &= \pm (2/3) * (0.0025) * (1500 \text{ PSIG}) \\ &= \pm 2.50 \text{ PSIG} \end{aligned}$$

Temperature Effect (Ref. Section 4.5, 4.6)

$$\begin{aligned} TE_1 &= \pm (0.75\% URL + 0.5\% Span) * \Delta T / 100^\circ\text{F} (3\sigma) \\ &= \pm (2/3) * [(0.0075 * 3000 \text{ PSIG}) + (0.005 * 1500 \text{ PSIG})] * (15^\circ\text{F} / 100^\circ\text{F}) \\ &= \pm 3.00 \text{ PSIG} \end{aligned}$$

Where  $\Delta T$  is the maximum temperature variation during normal conditions.


The temperature variation is based on the maximum containment temperature above the normal value. For this case the maximum temperature variation is  $15^\circ\text{F}$  ( $105^\circ\text{F} - 90^\circ\text{F}$ ). Therefore  $\Delta T$  is  $15^\circ\text{F}$ . The temperature variation assumed during calibration ( $90^\circ\text{F} - 65^\circ\text{F}$ ) will be included as a temperature drift. (Ref. 2.1.1)

Temperature Drift

$$\begin{aligned} TD_1 &= \pm (0.75\% URL + 0.5\% Span) * \Delta T / 100^\circ\text{F} (3\sigma) \\ &= \pm (2/3) * [(0.0075 * 3000 \text{ PSIG}) + (0.005 * 1500 \text{ PSIG})] * (25^\circ\text{F} / 100^\circ\text{F}) \\ &= \pm 5.00 \text{ PSIG} \end{aligned}$$

Where  $\Delta T$  is the maximum temperature variation assumed during calibration. For this case the maximum temperature variation is  $25^\circ\text{F}$  ( $90^\circ\text{F} - 65^\circ\text{F}$ ). (Ref. 2.1.1)  
Therefore  $\Delta T$  is  $25^\circ\text{F}$ .

Humidity (HE) has no effect on the sealed transmitter.



# CALCULATION SHEET

SHEET 20 OF 33

CALCULATION NO. JC-Q1B21-N678-1

REV. 002

$$HE_1 = \pm 0.000 \text{ PSIG} \quad 2.2.40$$

Radiation Effect

$$RE_1 = \pm 6.0\% \text{ URL during and after} \quad 2.2.40$$

Exposure to  $5.19 \times 10^7$  Rads TID ( $\gamma$ )

Since this transmitter is not expected to perform under accident conditions, radiation effects are not applicable.

$$RE_1 = \pm 0.000 \text{ PSIG}$$

Seismic Effect

Section 1.3.3

$$SE_1 = \pm 0.000 \text{ PSIG}$$

Per Sections 3.5.3 & 4.9, the worst power supply variations are 4.5 volts.

$$PS_1 = \pm 0.005\% \text{ span / volt variation } (3\sigma)$$
$$= \pm (2/3) * (0.00005) * (1500 \text{ PSIG}) * (4.5 \text{ volts})$$
$$= \pm 0.225 \text{ PSIG}$$

Over-Pressure Effects (OVP) refer to those uncertainties that may occur when pressure transmitters see pressures beyond their upper range limit prior to performing their required function. Overpressure effects are not applicable per Section 4.13

$$OVP_1 = \pm 0.0000 \text{ PSIA}$$

$$SPE_1 = \pm 0.000 \text{ PSIG}$$

$$DR_1 = \pm 0.403\% \text{ Span for 30 months}$$
$$= \pm 0.403\% * 1500 \text{ PSIG}$$
$$= \pm 6.045 \text{ PSIG}$$

Radiation Drift (RD): (Ref. 2.1.2, 2.2.19, 4.3)

$$RD_1 = \pm 0.000 \text{ psig}$$

**Summarizing for the transmitter:**

$$A_1 = \pm \text{SRSS } (RA_1, TE_1, HE_1, RE_1, SE_1, PS_1, OVP_1, SPE_1)$$
$$= \pm \text{SRSS } (2.50, 3.00, 0.00, 0.00, 0.00, 0.225, 0.00, 0.00)$$
$$= \pm 3.92 \text{ PSIG}$$

$$L_1 = - 0.000 \text{ PSIG}$$

$$M_1 = + 0.000 \text{ PSIG}$$

$$MTE_1 = \pm 5.30 \text{ PSIG} \quad (\text{Ref. section 4.15})$$



# CALCULATION SHEET

SHEET 21 OF 33

CALCULATION NO. JC-Q1B21-N678-1

REV. 002

$$\begin{aligned}
D_1 &= \pm \text{SRSS} (DR_1, TD_1, RD_1) \\
&= \pm \text{SRSS} (6.045, 5.00, 0.0000) \\
&= \pm \mathbf{7.85 \text{ PSIG}}
\end{aligned}$$

### 5.2.2. Trip Unit Uncertainties

Using the vendor data from Section 3.5.2:

$$\text{SPAN} = 1500 \text{ PSIG}$$

$$\begin{aligned}
A_2 = RA_2 &= \pm 0.20\% \text{ span} \\
&= \pm (0.0020) * (1500 \text{ PSIG}) \\
&= \pm 3.00 \text{ PSIG}
\end{aligned}$$

$$L_2 = -0.000 \text{ PSIG}$$

$$M_2 = +0.000 \text{ PSIG}$$

$$MTE_2 = \pm 3.75 \text{ PSIG}$$

Assumption 4.15

$$D_2 = \pm 0.00 \text{ PSIG}$$

Assumption 4.11

### 5.3. Loop Uncertainties

#### 5.3.1. Primary Element Accuracy (PE)

$$PE = \pm 0.000 \text{ PSIA}$$

Assumption 4.7

#### 5.3.2. Process Measurement Accuracy (PM)

$$PM = \pm 0.000 \text{ PSIA}$$

Assumption 4.7

#### 5.3.3. Insulation resistance Effects (IR)

$$IR = \pm 0.000 \text{ inHg}$$

Assumption 4.8

#### 5.3.4. Using the equations from Reference 2.1.1 and the values from Section 5.2:

$$\begin{aligned}
A_L &= \pm \text{SRSS} (A_1, A_2) \\
&= \pm \text{SRSS} (3.92, 3.00) \\
&= \pm \mathbf{4.94 \text{ PSIG}}
\end{aligned}$$


$$L_L = -L_1 - L_2 = 0.0 \text{ psig}$$

$$M_L = +M_1 + M_2 = 0.0 \text{ psig}$$

$$\begin{aligned}
C_L &= \pm \text{SRSS} (MTE_1, MTE_2) \\
&= \pm \text{SRSS} (5.30, 3.75) \\
&= \pm \mathbf{6.49 \text{ PSIG}}
\end{aligned}$$



ENTERGY



# CALCULATION SHEET

SHEET 22 OF 33  
REV. 002

CALCULATION NO. JC-Q1B21-N678-1

$$\begin{aligned} D_L &= \pm \text{SRSS}(D_1, D_2) \\ &= \pm \text{SRSS}(7.85, 0.00) \\ &= \pm \mathbf{7.85 \text{ PSIG}} \end{aligned}$$

$$\begin{aligned} LU &= \pm \text{SRSS}(A_L, C_L, PM, PE) \\ &= \pm \text{SRSS}(4.94, 6.49, 0, 0) \\ &= \pm \mathbf{8.16 \text{ PSIG}} \end{aligned}$$

## 5.4. Total Loop Uncertainty

$$\begin{aligned} \text{TLU} &= \pm (LU + D_L) \\ &= \pm 8.16 + 7.85 \\ &= \pm \mathbf{16.01 \text{ PSIG}} \end{aligned}$$

## 5.5. Nominal Trip Setpoint

### 5.5.1. TS Setpoint

The Analytical Limit for this calculation is 1095 PSIG. (Ref. 2.2.1, 2.2.28)

$$\text{NTSP} = \text{AL} - \text{TLU}$$

$$\text{AL} = 1095 \text{ psig}$$

$$1095 \text{ PSIG} - 16.01 \text{ PSIG} = 1078.99 \text{ PSIG}$$

**Calculated Setpoint = 1079.0 PSIG**

TRM Setpoint  $\leq$  1064.7 PSIG (Ref. 2.2.33)

Plant Setpoint = 1064.7 PSIG (Ref. 2.1.3)

**Therefore, the TRM and Plant setpoints are conservative.**

## 5.6. Allowable Value (AV)

$$\begin{aligned} \text{Allowable Value} &= \text{AL} - \text{LU} \\ &= 1095 \text{ PSIG} - 8.16 \text{ PSIG} \\ \text{AV} &= 1086.84 \text{ PSIG} \end{aligned}$$


**Calculated Allowable Value = 1086.9 PSIG**

Technical Specification Allowable Value  $\leq$  1079.7 PSIG (Ref. 2.2.33)

**Therefore, the Technical Specification Allowable Value is conservative.**



ENTERGY



# CALCULATION SHEET

SHEET 23 OF 33

CALCULATION NO. JC-Q1B21-N678-1

REV. 002

## 5.7. Spurious Trip Avoidance

For Spurious Trip Avoidance purposes, the Limiting Operating Transient Variation must be calculated at the highest vessel pressure seen during operation since this value would tend to move the process closer to the trip setpoint.

Highest vessel pressure seen during normal operation = 1040 PSIG (Ref. 2.2.1)

$$Z = \frac{|NTSP - X_T|}{\frac{1}{N} \sqrt{(A_L)^2 + (C_L)^2 + (D_L)^2}}$$

$X_T$  = Limiting Operating Transient Variation

$$X_T = X_0 + T + T_C$$

Where:

$X_0$  = Maximum or Minimum Steady State Operating Value  
= Normal operating pressure = 1040 PSIG (Ref. 2.2.1)

T = Magnitude of Limiting Transient Variation  
= 5 PSIG (Ref. 2.2.41)

$T_C$  = Modeling or Bias Uncertainty  
= 30 PSIG (Ref. 2.2.45)

$$\begin{aligned} X_T &= X_0 + T + T_C \\ &= 1040 + 5 + 30 \\ &= 1075 \text{ PSIG} \end{aligned}$$

$$Z = \frac{|1064.7 - 1075|}{(1/2) \sqrt{(4.94)^2 + (6.49)^2 + (7.85)^2}}^{1/2}$$


$$Z = 1.81$$

This value meets the minimum Spurious Trip Avoidance criteria of 95% probability,  $Z \geq 1.645$ ; therefore, Spurious Trip Avoidance is verified.





ENERGY



# CALCULATION SHEET

SHEET 24 OF 33

CALCULATION NO. JC-Q1B21-N678-1

REV. 002

5.8. **LER Avoidance** (Ref. 2.1.1, App. A)

From section 1.4, the Tech Spec allowable value = 1079.7 PSIG

$$Z = \frac{|AV - NTSP|}{\frac{1}{N} \sqrt{(A_L)^2 + (C_L)^2 + (D_L)^2}}$$


$$Z = \frac{|1079.7 - 1064.7|}{(1/2) * (4.94^2 + 6.49^2 + 7.85^2)^{1/2}}$$

$$Z = 2.65$$

This setpoint exceeds the minimum LER avoidance criteria of 90% probability,  $Z \geq 1.282$ ; therefore, LER avoidance is verified.



ENERGY

**CALCULATION SHEET**SHEET 25 OF 33CALCULATION NO. JC-Q1B21-N678-1REV. 002**6.0 TSTF CALCULATIONS (Ref. 2.1.1)****6.1. As-Left Tolerance**ALT<sub>1</sub> – Transmitter TSTF-493 Calculation

$$\begin{aligned} \text{ALT}_1 &= \text{RA}_1 \\ &= \pm 2.50 \text{ psig} \end{aligned}$$

Converting to loop current:

$$\begin{aligned} \text{ALT}_1 &= \pm (2.50 \text{ psig}/1500 \text{ psig}) * 16 \text{ mA} \\ &= \pm 0.026 \text{ mA} \end{aligned}$$

ALT<sub>2</sub> – Trip Unit TSTF-493 Calculation

$$\begin{aligned} \text{ALT}_2 &= \text{RA}_2 \\ &= \pm 3.00 \text{ psig} \end{aligned}$$

Converting to loop current:

$$\begin{aligned} \text{ALT}_2 &= \pm (3.00 \text{ psig}/1500 \text{ psig}) * 16 \text{ mA} \\ &= \pm 0.03 \text{ mA} \end{aligned}$$

**6.2. As-Found Tolerance (AFT)**AFT<sub>1</sub> – Transmitter TSTF-493 Calculation

The drift value used in this calculation to determine transmitter drift was derived by statistical analysis, therefore per Reference 3.1.1:

$$\text{AFT}_1 = \pm \text{DR}_1$$

$$\text{DR}_1 = \pm 6.045 \text{ psig for 30 months}$$

$$\text{AFT}_1 = \pm 6.045 \text{ psig}$$

Converting to loop current:


$$\begin{aligned} \text{AFT}_1 &= \pm (6.045 \text{ psig}/1500 \text{ psig}) * 16 \text{ mA} \\ &= \pm 0.06 \text{ mA} \end{aligned}$$

AFT<sub>2</sub> – Trip Unit TSTF-493 Calculation

$$\text{AFT}_2 = \pm \text{SRSS}(\text{RA}_2, \text{MTE}_2, \text{DR}_2) \text{ Reference 3.1.1}$$



ENERGY



# CALCULATION SHEET

SHEET 26 OF 33

CALCULATION NO. JC-Q1B21-N678-1

REV. 002

$$\begin{aligned} \text{AFT}_2 &= \pm \text{SRSS}(3.00, 0.9375, 0) \\ &= \pm 3.14 \text{ psig} \end{aligned}$$

Converting to loop current:

$$\begin{aligned} \text{AFT}_2 &= \pm (3.14 \text{ psig}/1500 \text{ psig}) * 16 \text{ mA} \\ &= \pm 0.03 \text{ mA} \end{aligned}$$

## 6.3. Loop Tolerances

$\text{ALT}_L$  – As-Left Loop Tolerance

$$\begin{aligned} \text{ALT}_L &= \pm \text{SRSS}(\text{ALT}_1, \text{ALT}_2) \\ &= \pm \text{SRSS}(2.50, 3.00) \\ &= \pm 3.90 \text{ psig} \end{aligned}$$

Converting to loop current:

$$\begin{aligned} \text{ALT}_L &= \pm (3.90 \text{ psig}/1500 \text{ psig}) * 16 \text{ mA} \\ &= \pm 0.04 \text{ mA} \end{aligned}$$

$\text{AFT}_L$  – As- Found Loop Tolerance

$$\begin{aligned} \text{AFT}_L &= \pm \text{SRSS}(\text{AFT}_1, \text{AFT}_2) \\ &= \pm \text{SRSS}(6.045, 3.14) \\ &= \pm 6.81 \text{ psig} \end{aligned}$$

Converting to loop current:

$$\begin{aligned} \text{AFT}_L &= \pm (6.81 \text{ psig}/1500 \text{ psig}) * 16 \text{ mA} \\ &= \pm 0.07 \text{ mA} \end{aligned}$$



ENTERGY



# CALCULATION SHEET

SHEET 27 OF 33

CALCULATION NO. JC-Q1B21-N678-1

REV. 002

## 7.0 CONCLUSION

The Plant Setpoint and Technical Specification Allowable Value are conservative.


SUMMARY OF RESULTS	
SYSTEM	B21
LOOP NUMBER	N678
TOTAL LOOP UNCERTAINTY	± 16.01 PSIG
LOOP UNCERTAINTY	± 8.16 PSIG
DRIFT ALLOWANCE	± 7.85 PSIG
M&TE ALLOWANCE	± 6.49 PSIG

	SPECIFIED VALUE	CALCULATION
<b>ANALYTICAL LIMIT</b>	1095 PSIG	-----
<b>ALLOWABLE VALUE</b>	1079.7 PSIG	1086.9 PSIG
<b>TRIP SETPOINT</b>	1064.7 PSIG	1079.0 PSIG
<b>TRM SETPOINT</b>	1064.7 PSIG	1079.0 PSIG

SUMMARY OF CALIBRATION TOLERANCES	
As-Left Transmitter TSTF-493 (ALT <sub>1</sub> )	±2.50 psig, ±0.026 mA
As-Left Trip Unit TSTF-493 (ALT <sub>2</sub> )	±3.00 psig, ±0.03 mA
As-Found Transmitter TSTF-493 (AFT <sub>1</sub> )	±6.045 psig, ±0.06 mA
As-Found Trip Unit TSTF-493 (AFT <sub>2</sub> )	±3.14 psig, ±0.03 mA
As-Left Loop Tolerance (ALT <sub>L</sub> )	±3.90 psig, ±0.04 mA
As-Found Loop Tolerance (AFT <sub>L</sub> )	±6.81 psig, ±0.07 mA

**DESIGN VERIFICATION COVER PAGE**

<input type="checkbox"/> ANO-1	<input type="checkbox"/> ANO-2	<input type="checkbox"/> IP-2	<input type="checkbox"/> IP-3	<input type="checkbox"/> JAF	<input type="checkbox"/> PLP
<input type="checkbox"/> PNPS	<input type="checkbox"/> VY	<input checked="" type="checkbox"/> GGNS	<input type="checkbox"/> RBS	<input type="checkbox"/> W3	<input type="checkbox"/> NP
Document No. JC-Q1B21-N678-1		Revision No. 2	Page 1 of 4		
Title: Technical Specification Setpoint Determination for Reactor Dome Pressure Scram					
DV Method: <input checked="" type="checkbox"/> Quality Related		<input type="checkbox"/> Augmented Quality Related			
<input checked="" type="checkbox"/> Design Review		<input type="checkbox"/> Alternate Calculation		<input type="checkbox"/> Qualification Testing	

VERIFICATION REQUIRED	DISCIPLINE	VERIFICATION COMPLETE AND COMMENTS RESOLVED (DV print, sign, and date)
<input type="checkbox"/>	Electrical	
<input type="checkbox"/>	Mechanical	
<input checked="" type="checkbox"/>	Instrument and Control	Robin Smith  10/8/13
<input type="checkbox"/>	Civil/Structural	
<input type="checkbox"/>	Nuclear	
<input type="checkbox"/>		
<input type="checkbox"/>		

Originator:	Mary Coffaro / <u>MQ Coffaro 10/8/13</u> Print/Sign/Date After Comments Have Been Resolved
-------------	-----------------------------------------------------------------------------------------------

**ATTACHMENT 1  
DESIGN VERIFICATION FORM**

JC-Q1B21-N678-1, REV. 2  
SHEET 29 OF 33

**ATTACHMENT 9.6**

**DESIGN VERIFICATION CHECKLIST**

Sheet 1 of 3

IDENTIFICATION:			DISCIPLINE:
Document Title: <b>Technical Specification Setpoint Determination for Reactor Dome Pressure Scram</b>			<input type="checkbox"/> Civil/Structural
Doc. No.: JC-Q1B21-N678-1	Rev. 2	QA Cat. 1	<input type="checkbox"/> Electrical
Verifier: <u>Robin Smith</u>	<u>[Signature]</u>	<u>10/8/13</u>	<input checked="" type="checkbox"/> I & C
Print	Sign	Date	<input type="checkbox"/> Mechanical
Manager authorization for supervisor performing Verification.			<input type="checkbox"/> Nuclear
<input checked="" type="checkbox"/> N/A	_____	_____	<input type="checkbox"/> Other
Print	Sign	Date	
METHOD OF VERIFICATION:			
Design Review <input checked="" type="checkbox"/>		Alternate Calculations <input type="checkbox"/>	Qualification Test <input type="checkbox"/>

The following basic questions are addressed as applicable, during the performance of any design verification. [ANSI N45.2.11 – 1974] [NP QAPD, Part II, Section 3][NP NQA-1-1994, Part I, BR 3, Supplement 3S-1].

**NOTE** The reviewer can use the "Comments/Continuation sheet" at the end for entering any comment/resolution along with the appropriate question number. Additional items with new question numbers can also be entered.

- Design Inputs** – Were the inputs correctly selected and incorporated into the design?  
(Design inputs include design bases, plant operational conditions, performance requirements, regulatory requirements and commitments, codes, standards, field data, etc. All information used as design inputs should have been reviewed and approved by the responsible design organization, as applicable.  
All inputs need to be retrievable or excerpts of documents used should be attached.  
See site specific design input procedures for guidance in identifying inputs.)

Yes       No       N/A
- Assumptions** – Are assumptions necessary to perform the design activity adequately described and reasonable? Where necessary, are assumptions identified for subsequent re-verification when the detailed activities are completed? *Are the latest applicable revisions of design documents utilized?*

Yes       No       N/A
- Quality Assurance** – Are the appropriate quality and quality assurance requirements specified?

Yes       No       N/A

**ATTACHMENT 1**  
**DESIGN VERIFICATION FORM**

**JC-Q1B21-N678-1, REV. 2**  
**SHEET 30 OF 33**

**ATTACHMENT 9.6**

**DESIGN VERIFICATION CHECKLIST**

**Sheet 2 of 3**

4. Codes, Standards and Regulatory Requirements – Are the applicable codes, standards and regulatory requirements, including issue and addenda properly identified and are their requirements for design met?  
Yes  No  N/A
5. Construction and Operating Experience – Have applicable construction and operating experience been considered?  
Yes  No  N/A
6. Interfaces – Have the design interface requirements been satisfied and documented?  
Yes  No  N/A
7. Methods – Was an appropriate design or analytical (for calculations) method used?  
Yes  No  N/A
8. Design Outputs – Is the output reasonable compared to the inputs?  
Yes  No  N/A
9. Parts, Equipment and Processes – Are the specified parts, equipment, and processes suitable for the required application?  
Yes  No  N/A
10. Materials Compatibility – Are the specified materials compatible with each other and the design environmental conditions to which the material will be exposed?  
Yes  No  N/A
11. Maintenance requirements – Have adequate maintenance features and requirements been specified?  
Yes  No  N/A
12. Accessibility for Maintenance – Are accessibility and other design provisions adequate for performance of needed maintenance and repair?  
Yes  No  N/A
13. Accessibility for In-service Inspection – Has adequate accessibility been provided to perform the in-service inspection expected to be required during the plant life?  
Yes  No  N/A
14. Radiation Exposure – Has the design properly considered radiation exposure to the public and plant personnel?  
Yes  No  N/A
15. Acceptance Criteria – Are the acceptance criteria incorporated in the design documents sufficient to allow verification that design requirements have been satisfactorily accomplished?  
Yes  No  N/A

16. Test Requirements – Have adequate pre-operational and subsequent periodic test requirements been appropriately specified?  
Yes  No  N/A
17. Handling, Storage, Cleaning and Shipping – Are adequate handling, storage, cleaning and shipping requirements specified?  
Yes  No  N/A
18. Identification Requirements – Are adequate identification requirements specified?  
Yes  No  N/A
19. Records and Documentation – Are requirements for record preparation, review, approval, retention, etc., adequately specified? Are all documents prepared in a clear legible manner suitable for microfilming and/or other documentation storage method? Have all impacted documents been identified for update as necessary?  
Yes  No  N/A
20. Software Quality Assurance- ENN sites: For a calculation that utilized software applications (e.g., GOTHIC, SYMCORD), was it properly verified and validated in accordance with EN- IT-104 or previous site SQA Program? ENS sites: This is an EN-IT-104 task. However, per ENS-DC-126, for exempt software, was it verified in the calculation?  
Yes  No  N/A
21. Has adverse impact on peripheral components and systems, outside the boundary of the document being verified, been considered?  
Yes  No  N/A





ATTACHMENT 2  
OWNER'S REVIEW COMMENTS

JC-Q1B21-N678-1, REV. 2  
SHEET 33 OF 33



ATTACHMENT 9.10  
SHEET 1 OF 1

ENGINEERING CHANGE COMMENT FORM

Page 1 of 1

Comment No.	Reviewer	Department / Discipline / Program	Comment	Comment Date	Resolution	Date Resolved
<b>Owner's Review Comments to JC-Q1B21-N678-1 (EC 18458)</b>						
<u>General Issues</u>						
1	D. Hollis	DE-E	No comments	8/15/12	None required	N/A