

APPENDIX B

Southern California Edison Company
P. O. Box 800
2244 Walnut Grove Avenue
Rosemead, California 41770

Docket No. 50-206
License No. DPR-13

NOTICE OF DEVIATION

Based on the results of an NRC inspection conducted on February 5-16, 1979, it appears that one of your activities was not conducted in conformance with your commitments to the Commission as indicated below:

Contrary to Southern California Edison Company's commitment in Appendix D to the Final Safety Analysis Report (FSAR) to conform to the guidance of ANSI Standard N18.7 - 1972, and to Section 4.2.1 of ANSI N18.7 - 1972 which requires that the written charter of the review and audit group shall contain specific features, the licensee's written charter for the Nuclear Audit and Review Committee (NARC) did not describe the mechanism used for initiating NARC audits, nor did it identify the management position to which NARC auditors from the QA organization will report while performing NARC audits.

8003280 441